

POHANG AP, Korea, Republic of

WMO: 471390

Lat: 35.988N

Lon: 129.420E

Elev: 21

StdP: 101.07

Time Zone: 9.00 (E09)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.1	-5.8	-19.1	0.7	-3.2	-17.1	0.8	-2.9	11.2	3.3	10.1	1.3	5.6	270	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.4	34.0	25.9	32.7	25.4	31.0	24.8	26.8	32.0	26.2	30.9	25.6	29.8	4.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.2	20.4	29.2	24.9	20.1	29.0	24.2	19.1	28.3	84.5	32.5	81.4	30.9	78.9	29.8	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
9.6	8.4	7.4	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			-10.9	29.1	2.0	0.7	-12.4	29.6	-13.5	30.0	-14.7	30.4	-16.1	30.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.1	1.6	3.3	7.4	13.3	17.9	21.0	25.2	26.0	21.3	16.1	10.3	5.0
	DBStd	8.79	3.42	3.52	3.04	3.61	3.21	3.17	3.58	2.66	2.70	3.03	3.57	3.47
	HDD10.0	749	260	189	92	9	0	0	0	0	0	2	39	157
	HDD18.3	2233	518	422	340	156	48	8	1	0	4	80	242	413
	CDD10.0	2244	0	1	11	109	246	331	471	496	340	189	47	2
	CDD18.3	686	0	0	0	6	35	89	214	238	94	10	0	0
	CDH23.3	5464	0	0	1	47	279	607	1963	2081	436	49	1	0
	CDH26.7	1951	0	0	0	9	57	198	802	772	108	4	0	0
Wind	WSAvg	3.5	4.4	4.0	3.9	3.7	3.2	2.9	3.0	3.2	3.1	3.1	3.4	3.9
Precipitation	PrecAvg	1128	35	41	63	81	79	126	196	198	171	66	46	26
	PrecMax	2099	140	158	162	177	272	374	577	579	618	262	158	143
	PrecMin	600	0	0	2	7	12	10	14	20	11	0	0	0
	PrecStd	295	30	34	39	42	47	83	127	121	124	63	44	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.1	16.2	19.8	28.2	30.8	33.9	35.9	35.9	32.1	27.0	22.2	17.1
		MCWB	7.3	10.7	10.8	17.6	19.3	22.9	26.8	26.4	25.1	19.2	14.7	10.4
	2%	DB	9.9	12.2	17.0	24.2	28.2	31.0	34.1	34.0	29.2	24.8	19.8	14.2
		MCWB	5.4	7.1	9.9	15.5	18.1	22.1	26.1	26.3	23.3	17.8	13.8	8.8
	5%	DB	8.4	10.1	14.9	22.1	26.6	28.9	32.9	32.5	27.4	22.9	17.9	12.2
		MCWB	4.6	5.9	8.6	14.2	17.5	21.5	25.7	25.9	22.2	17.1	12.8	7.5
	10%	DB	7.1	8.8	12.9	20.0	24.8	26.9	31.1	31.0	25.9	21.2	16.1	10.8
		MCWB	3.8	4.9	7.6	13.3	17.0	20.6	25.3	25.5	21.8	16.6	12.2	6.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.8	12.5	13.8	20.2	21.8	25.0	28.0	27.8	26.0	20.9	16.6	12.1
		MCDB	10.8	15.9	16.5	23.1	26.7	30.2	33.6	32.7	30.7	24.0	19.6	16.5
	2%	WB	6.7	8.7	11.3	17.6	20.3	23.7	26.9	27.0	24.7	19.4	15.3	9.9
		MCDB	8.4	11.6	15.2	23.6	25.6	28.1	32.5	32.1	28.2	22.5	18.0	13.3
	5%	WB	5.2	6.6	9.8	15.5	19.1	22.6	26.2	26.4	23.6	18.4	13.9	8.3
		MCDB	7.6	9.0	12.7	20.3	24.5	26.9	31.3	31.0	26.4	21.5	17.0	11.5
	10%	WB	4.0	5.3	8.4	14.0	17.8	21.3	25.6	25.9	22.4	17.4	12.7	6.8
		MCDB	6.7	7.8	11.7	18.2	22.9	25.9	30.2	29.9	24.8	20.6	15.6	9.9
Mean Daily Temperature Range	5% DB	MDBR	8.6	8.4	8.8	9.6	9.7	7.5	6.7	6.4	6.9	9.1	9.5	9.2
		MCDBR	9.9	11.1	12.3	13.4	13.5	11.8	9.7	9.6	9.8	11.2	11.8	11.9
		MCWBR	7.5	7.6	7.6	7.3	6.5	5.6	4.5	4.3	5.1	6.2	7.6	8.0
	5% WB	MCDBR	9.4	8.5	10.1	11.3	11.0	9.8	9.0	8.4	7.9	8.8	10.2	11.0
		MCWBR	7.9	6.6	7.4	7.5	6.8	5.4	4.6	4.3	4.8	5.9	7.5	8.1
Clear-Sky Solar Irradiance	taub	0.416	0.474	0.559	0.592	0.601	0.642	0.609	0.561	0.498	0.473	0.438	0.408	
	taud	2.038	1.924	1.754	1.733	1.757	1.735	1.874	1.990	2.107	2.053	2.059	2.073	
	Ebn at Noon	739	739	712	717	719	688	708	734	760	734	710	718	
	Edh at Noon	130	164	213	228	226	231	200	174	148	142	127	119	
All-Sky Solar Radiation	RadAvg	2.65	3.26	4.22	4.94	5.43	4.89	4.46	4.48	3.76	3.46	2.65	2.41	
	RadStd	0.21	0.40	0.42	0.37	0.54	0.43	0.66	0.53	0.42	0.34	0.35	0.18	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (26 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page