

DAEGU INTL, Korea, Republic of

WMO: 471420

Lat: 35.894N

Lon: 128.659E

Elev: 35

StdP: 100.90

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -8.1	(c) -6.8	(d) -20.9	(e) 0.6	(f) -1.9	(g) -19.0	(h) 0.7	(i) -1.6	(j) 10.3	(k) -0.1	(l) 9.5	(m) -0.3	(n) 2.9	(o) 310	(p) 0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 8.5	(c) 35.0	(d) 25.3	(e) 33.2	(f) 24.7	(g) 32.0	(h) 24.1	(i) 26.6	(j) 31.7	(k) 26.0	(l) 30.9	(m) 25.5	(n) 30.1	(o) 3.2	(p) 300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.4	28.5	24.9	20.0	28.4	24.1	19.1	28.0	83.3	31.8	80.9	31.1	78.5	29.9	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.8	7.6	6.6	-10.8	36.3	2.1	1.3	-12.3	37.2	-13.5	37.9	-14.6	38.7	-16.2	39.6		
			-12.2	27.7	1.9	0.9	-13.6	28.3	-14.7	28.9	-15.8	29.4	-17.2	30.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.3	0.4	3.3	8.0	14.0	19.3	23.1	26.4	27.0	22.0	15.9	9.1	2.5		
	DBStd	9.64	3.11	3.62	3.45	3.49	2.67	2.38	2.94	2.75	2.82	3.17	3.68	3.50		
	HDD10.0	873	298	191	81	7	0	0	0	0	0	2	60	234		
	HDD18.3	2313	556	422	320	136	20	1	0	0	3	87	277	492		
	CDD10.0	2443	0	2	19	126	289	392	509	527	359	186	33	1		
	CDD18.3	843	0	0	0	5	51	143	251	268	113	12	0	0		
	CDH23.3	7696	0	0	2	95	540	1129	2425	2699	730	75	1	0		
	CDH26.7	2948	0	0	0	13	144	383	1033	1172	199	3	0	0		
(14) Wind	WSAvg	2.5	2.8	2.8	2.9	2.9	2.6	2.5	2.3	2.3	2.1	2.0	2.3	2.7		
(15) Precipitation	PrecAvg	1028	20	26	51	74	77	132	223	197	133	43	37	15		
	PrecMax	1458	111	90	152	170	143	419	533	395	398	136	136	56		
	PrecMin	568	0	0	7	19	15	12	44	12	3	0	3	0		
	PrecStd	226	21	23	33	40	39	87	114	96	101	34	31	14		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	17.8	22.2	28.2	32.1	34.0	36.9	36.9	32.9	27.1	22.0	14.2		
		MCWB	6.0	11.0	11.9	16.0	17.9	20.6	26.2	25.7	24.0	17.8	15.2	9.9		
	2%	DB	9.2	14.1	19.2	26.0	29.9	32.0	35.0	35.1	30.7	25.2	19.2	12.1		
		MCWB	4.3	8.3	10.4	15.1	17.2	20.9	25.8	25.4	23.0	17.1	13.0	7.4		
	5%	DB	7.9	12.0	17.1	23.9	28.1	30.2	33.2	33.9	29.0	23.9	17.8	10.1		
		MCWB	3.1	6.3	9.4	13.6	16.7	20.3	25.3	25.3	21.7	16.7	11.9	6.2		
	10%	DB	6.1	10.0	15.1	21.9	26.8	29.0	31.9	32.2	27.2	22.1	15.8	8.8		
		MCWB	2.3	4.7	8.8	12.5	16.5	20.1	24.8	25.0	20.9	15.8	11.1	5.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.2	14.2	14.9	19.0	22.3	24.9	27.6	27.3	25.7	21.7	17.0	11.1		
		MCDB	9.6	15.6	17.0	23.3	25.4	28.3	33.8	32.2	29.8	24.0	19.1	13.4		
	2%	WB	5.2	9.1	12.9	16.7	20.3	23.8	26.7	26.7	24.5	19.8	14.7	8.6		
		MCDB	7.7	12.6	17.1	22.8	25.4	27.5	32.1	31.6	28.5	22.5	18.1	10.9		
	5%	WB	4.1	7.0	10.6	15.2	18.9	22.7	26.1	26.2	23.5	18.3	13.1	7.0		
		MCDB	6.5	10.4	15.9	21.1	24.3	26.9	31.1	31.0	27.1	21.8	16.3	9.2		
	10%	WB	2.7	5.5	9.1	13.9	17.8	21.7	25.6	25.7	22.3	16.7	11.7	5.3		
		MCDB	5.7	8.9	14.1	19.8	23.6	26.4	30.2	30.3	25.6	20.8	15.1	8.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.1	10.6	11.7	12.5	12.3	10.0	8.1	8.5	9.5	11.5	11.0	9.7		
		MCDBR	12.4	14.0	15.4	16.3	16.0	13.3	10.4	10.8	11.2	13.0	13.5	11.9		
	5% WB	MCWBR	8.2	8.7	8.3	7.3	6.4	4.6	3.4	3.3	4.5	6.1	7.9	8.2		
		MCWBR	10.6	11.7	13.1	12.9	11.5	9.2	9.2	9.0	8.7	8.9	10.8	10.8		
(40) Clear-Sky Solar Irradiance	taub		0.410	0.463	0.547	0.582	0.592	0.645	0.605	0.558	0.490	0.463	0.434	0.404		
	taud		2.031	1.934	1.765	1.740	1.759	1.711	1.865	1.979	2.112	2.065	2.054	2.067		
	Ebn at Noon		746	751	722	725	725	686	711	737	767	745	715	722		
	Edh at Noon		131	163	210	227	225	236	201	176	147	141	127	119		
(44) All-Sky Solar Radiation	RadAvg		2.73	3.40	4.37	5.00	5.57	5.02	4.43	4.45	3.88	3.61	2.72	2.45		
	RadStd		0.19	0.34	0.41	0.38	0.53	0.42	0.62	0.57	0.43	0.33	0.33	0.16		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+74	N/A

Nomenclature: See separate page