

DAEGU AFB, Korea, Republic of

WMO: 471430

Lat: 35.828N

Lon: 128.652E

Elev: 55

StdP: 100.67

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.0	(c) -5.4	(d) -21.6	(e) 0.5	(f) -1.9	(g) -19.5	(h) 0.7	(i) -1.4	(j) 8.4	(k) 1.1	(l) 7.4	(m) 0.1	(n) 3.0	(o) 290	(p) 0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 7.2	(c) 34.5	(d) 24.1	(e) 33.2	(f) 23.7	(g) 31.8	(h) 23.2	(i) 25.7	(j) 30.6	(k) 25.2	(l) 30.1	(m) 24.8	(n) 29.6	(o) 3.1	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.6	19.7	27.7	24.0	19.0	27.5	23.4	18.3	27.5	79.9	30.9	77.7	30.2	75.8	29.7	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 7.0	(b) 6.1	(c) 5.3	(e) -9.7	(f) 36.1	(g) 2.2	(h) 1.3	(i) -11.3	(j) 37.1	(k) -12.5	(l) 37.8	(m) -13.7	(n) 38.6	(o) -15.3	(p) 39.6		
			DB													
			WB													
				(e) -11.5	(f) 26.4	(g) 1.9	(h) 0.8	(i) -12.9	(j) 27.0	(k) -14.0	(l) 27.4	(m) -15.1	(n) 27.8	(o) -16.5	(p) 28.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.8	1.3	3.7	8.6	14.6	19.8	23.3	26.6	27.1	22.2	16.6	9.8	3.2		
	DBStd	9.46	3.24	3.59	3.59	3.45	2.85	2.54	3.02	2.79	2.76	3.02	3.64	3.44		
	HDD10.0	785	271	179	71	4	0	0	0	0	0	1	48	211		
	HDD18.3	2178	529	411	303	121	18	1	0	0	2	69	257	468		
	CDD10.0	2532	0	2	26	141	303	401	516	529	367	206	41	1		
	CDD18.3	884	0	0	0	7	62	151	258	271	119	16	0	0		
	CDH23.3	8019	0	0	2	80	524	1165	2637	2824	729	58	0	0		
	CDH26.7	2991	0	0	0	9	131	378	1110	1179	181	3	0	0		
(14) Wind	WSAvg	2.3	2.5	2.5	2.6	2.6	2.4	2.4	2.2	2.2	2.0	1.8	2.0	2.3		
(15) Precipitation	PrecAvg	1028	20	26	51	74	77	132	223	197	133	43	37	15		
	PrecMax	1458	111	90	152	170	143	419	533	395	398	136	136	56		
	PrecMin	568	0	0	7	19	15	12	44	12	3	0	3	0		
	PrecStd	226	21	23	33	40	39	87	114	96	101	34	31	14		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	17.3	22.4	28.0	31.8	33.5	36.3	36.1	32.5	26.8	21.5	14.1		
		MCWB	6.7	10.6	11.5	16.2	17.1	20.4	24.5	24.7	22.8	17.5	14.6	9.4		
	2%	DB	9.3	13.8	19.3	25.6	29.6	31.7	34.5	34.8	30.3	24.9	19.2	11.8		
		MCWB	4.4	7.3	10.0	14.1	16.7	20.1	24.4	24.4	21.5	16.7	12.9	6.6		
	5%	DB	7.6	11.5	17.2	23.6	28.0	30.4	33.2	33.4	28.7	23.5	17.4	10.2		
		MCWB	3.0	5.8	9.3	13.1	16.1	19.6	24.1	24.3	20.9	16.2	11.8	5.7		
	10%	DB	6.3	9.6	15.2	21.6	26.4	29.0	31.8	32.0	27.3	22.0	15.7	8.8		
		MCWB	2.3	4.3	8.4	12.2	15.7	19.4	23.9	24.0	20.3	15.7	10.6	4.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	13.4	14.3	18.9	21.1	24.1	26.2	26.8	24.6	21.5	16.8	10.2		
		MCDB	10.3	15.8	16.6	22.6	25.4	28.4	30.9	31.0	29.0	23.0	19.4	12.7		
	2%	WB	5.4	8.5	12.5	16.7	19.5	23.1	25.7	26.0	23.8	19.3	14.3	7.9		
		MCDB	7.9	11.9	17.1	22.1	24.4	27.4	30.6	30.8	27.8	22.2	17.3	10.7		
	5%	WB	4.1	6.4	10.3	15.1	18.3	22.2	25.2	25.5	22.9	18.0	12.9	6.4		
		MCDB	6.7	10.4	15.8	20.5	23.9	26.8	30.3	30.2	26.9	21.2	16.2	9.4		
	10%	WB	2.8	5.1	8.8	13.6	17.4	21.3	24.8	25.0	21.8	16.6	11.6	5.1		
		MCDB	5.8	8.8	14.2	19.1	23.3	26.0	29.9	29.6	25.2	20.7	14.9	8.5		
(35) Mean Daily Temperature Range	MDBR		7.8	8.7	9.7	10.6	10.5	8.7	7.0	7.2	7.9	9.4	9.0	8.1		
	5% DB	MCDBR	9.5	11.4	13.0	14.0	13.8	11.7	9.1	9.4	9.8	10.9	11.3	10.4		
		MCWBR	6.0	6.7	6.7	5.6	4.5	3.4	2.2	2.2	3.1	4.3	5.9	6.5		
	5% WB	MCDBR	8.2	9.7	10.9	10.8	10.0	7.9	7.7	7.8	7.2	7.6	8.9	9.4		
(40) Clear-Sky Solar Irradiance	taub		0.409	0.462	0.546	0.581	0.591	0.643	0.604	0.557	0.490	0.462	0.433	0.403		
	taud		2.033	1.936	1.768	1.742	1.762	1.714	1.868	1.980	2.111	2.067	2.056	2.069		
	Ebn at Noon		747	752	723	726	727	687	712	737	768	746	716	724		
	Edh at Noon		131	162	210	226	225	236	201	176	147	140	127	119		
(44) All-Sky Solar Radiation	RadAvg		2.74	3.40	4.38	5.00	5.57	5.01	4.44	4.46	3.89	3.62	2.73	2.46		
	RadStd		0.19	0.34	0.41	0.38	0.53	0.42	0.63	0.57	0.43	0.33	0.33	0.16		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	-2.08	N/A	N/A	N/A	N/A	N/A	+43
Regional (38 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	+72	N/A

Nomenclature: See separate page