

JEONJU, Korea, Republic of

WMO: 471460

Lat: 35.8408N

Lon: 127.1172E

Elev: 205

StdP: 14.59

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.4	19.7	1.9	6.1	24.0	5.4	7.3	26.0	13.6	32.7	12.1	34.3	3.2	160	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.0	92.1	77.5	89.9	76.8	87.8	75.3	81.0	86.7	79.5	85.3	78.2	84.2	6.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.5	154.1	84.2	78.0	146.7	83.1	76.6	139.6	81.8	44.9	86.8	43.4	85.4	42.0	84.0	87.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
12.9	11.4	9.9	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			11.5	95.5	3.9	2.1	8.7	97.1	6.4	98.3	4.2	99.5	1.4	101.0
			9.8	81.7	3.7	2.5	7.2	83.5	5.1	85.0	3.0	86.4	0.3	88.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	57.3	32.2	36.1	44.7	55.8	65.8	73.5	79.7	80.4	72.1	60.8	48.5	36.3	(6)
(7)		DBStd	17.75	6.75	6.85	6.84	6.75	4.93	3.50	4.19	4.30	4.85	5.77	7.26	6.90	(7)
(8)		HDD50	1703	554	393	192	22	0	0	0	0	0	4	113	425	(8)
(9)		HDD65	4329	1018	810	629	282	51	0	0	0	4	151	496	888	(9)
(10)		CDD50	4361	1	3	28	198	488	706	921	943	663	340	68	2	(10)
(11)		CDD65	1512	0	0	0	8	74	257	456	478	217	21	1	0	(11)
(12)		CDH74	12889	0	0	2	75	584	1664	4301	4800	1361	100	2	0	(12)
(13)		CDH80	4189	0	0	0	8	106	413	1512	1835	311	4	0	0	(13)
(14)	Wind	WSAvg	4.0	3.6	3.9	4.5	4.6	4.4	4.0	4.3	4.1	3.6	3.4	3.6	3.6	(14)
(15)	Precipitation	PrecAvg	50.6	1.3	1.5	2.3	3.6	3.8	6.5	10.7	9.8	5.6	2.3	2.3	1.2	(15)
(16)		PrecMax	69.8	4.9	4.1	6.7	14.3	9.7	16.1	22.4	23.0	12.6	5.0	6.4	2.8	(16)
(17)		PrecMin	27.8	0.1	0.0	0.3	1.1	0.2	0.9	2.3	1.8	0.1	0.0	0.7	0.1	(17)
(18)		PrecStd	10.7	1.0	1.1	1.3	2.4	2.0	4.2	4.6	4.8	4.0	1.6	1.4	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.4	63.0	70.1	80.5	86.5	89.0	94.8	96.1	89.1	80.1	71.9	59.2	(19)
(20)		MCWB	46.8	53.6	54.1	61.3	63.1	69.1	78.2	78.4	72.7	64.7	59.6	50.1	50.1	(20)
(21)		2%	DB	49.4	55.5	64.7	75.8	82.9	86.5	91.8	92.7	86.1	76.8	66.9	54.2	(21)
(22)		MCWB	42.9	46.8	51.2	58.7	62.9	68.7	77.6	77.8	71.3	63.2	56.9	46.9	46.9	(22)
(23)		5%	DB	45.6	51.4	61.0	72.3	80.1	84.4	89.7	90.9	83.5	74.1	63.6	50.6	(23)
(24)		MCWB	39.7	43.1	49.8	56.4	62.0	68.5	77.4	77.7	70.6	61.9	55.1	44.4	44.4	(24)
(25)		10%	DB	42.3	47.4	57.2	68.7	77.1	82.4	87.5	88.7	81.2	71.1	60.3	47.4	(25)
(26)		MCWB	37.3	40.4	47.2	55.1	61.5	68.6	76.8	76.9	69.9	60.6	52.7	42.0	42.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.9	56.3	58.8	67.6	71.5	76.8	82.7	83.3	78.6	72.0	62.9	53.0	(27)
(28)		MCDWB	52.1	60.1	63.7	73.3	76.9	81.7	88.4	90.0	81.9	75.7	67.5	56.7	56.7	(28)
(29)		2%	WB	43.7	48.6	55.0	62.8	68.1	74.8	81.0	81.4	76.0	67.9	59.8	48.1	(29)
(30)		MCDWB	48.4	53.3	61.2	70.7	74.8	79.9	86.5	87.5	81.4	71.4	64.4	52.7	52.7	(30)
(31)		5%	WB	40.7	44.1	51.4	59.8	65.8	73.4	79.6	80.0	74.4	65.1	56.8	45.2	(31)
(32)		MCDWB	44.5	49.4	58.2	67.6	73.7	78.9	85.2	85.9	79.9	70.0	61.8	49.7	49.7	(32)
(33)		10%	WB	37.8	41.3	48.4	57.3	64.2	71.8	78.3	78.7	72.6	62.6	54.0	42.4	(33)
(34)		MCDWB	41.8	46.9	55.5	64.8	72.7	77.7	84.2	84.8	78.0	68.5	58.9	47.3	47.3	(34)
(35)	Mean Daily Temperature Range	MDBR	14.2	16.2	18.5	20.6	20.0	16.2	12.1	13.0	15.7	18.4	16.6	14.3	14.3	(35)
(36)		5% DB	MCDBR	17.6	20.9	24.4	25.8	25.3	20.5	15.2	16.0	18.0	21.3	20.0	19.0	(36)
(37)		MCWBR	12.1	13.0	13.7	11.9	9.8	7.2	5.0	5.1	6.4	8.9	11.2	13.0	13.0	(37)
(38)		5% WB	MCDBR	15.1	17.6	19.5	19.5	17.3	13.6	12.7	13.7	13.0	15.2	16.0	17.0	(38)
(39)		MCWBR	11.8	13.0	13.5	11.6	9.2	6.6	5.5	5.7	6.5	9.1	11.4	13.1	13.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.447	0.487	0.568	0.591	0.605	0.674	0.621	0.571	0.498	0.478	0.463	0.445	0.445	(40)
(41)		taud	1.921	1.861	1.711	1.708	1.724	1.650	1.818	1.936	2.071	1.994	1.964	1.940	1.940	(41)
(42)		Ebn at Noon	222	230	223	228	227	211	222	230	241	231	216	212	212	(42)
(43)		Edh at Noon	47	56	70	74	74	80	67	58	49	48	44	43	43	(43)
(44)	All-Sky Solar Radiation	RadAvg	782	1032	1377	1588	1759	1585	1372	1412	1294	1152	812	689	689	(44)
(45)		RadStd	53	87	130	126	173	144	190	201	136	96	92	49	49	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
										+133	+76

Nomenclature: See separate page