

JEONJU, Korea, Republic of

WMO: 471460

Lat: 35.8408N

Lon: 127.1172E

Elev: 63

StdP: 100.58

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.7	-6.8	-16.7	0.9	-4.4	-14.8	1.0	-3.3	6.1	0.4	5.4	1.3	1.4	160	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.2	33.4	25.3	32.2	24.9	31.0	24.0	27.2	30.4	26.4	29.6	25.7	29.0	2.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.4	22.0	29.0	25.6	21.0	28.4	24.8	19.9	27.7	86.6	30.5	83.0	29.7	79.8	28.9	30.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.8	5.1	4.4	-11.4	35.3	2.2	1.2	-13.0	36.1	-14.2	36.8	-15.4	37.5	-17.0	38.4
			-12.3	27.6	2.0	1.4	-13.8	28.6	-15.0	29.4	-16.1	30.2	-17.6	31.2
			DB											
			WB											

Monthly Climatic Design Conditions

			Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
			(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.0	0.1	2.3	7.1	13.2	18.8	23.1	26.5	26.9	22.3	16.0	9.2	2.4	(6)
(7)		DBStd	9.86	3.75	3.81	3.80	3.75	2.74	1.94	2.33	2.39	2.70	3.21	4.03	3.83	(7)
(8)		HDD10.0	946	308	218	107	12	0	0	0	0	0	2	63	236	(8)
(9)		HDD18.3	2405	566	450	349	157	28	0	0	2	84	276	493	(9)	
(10)		CDD10.0	2423	1	2	16	110	271	392	512	524	368	189	38	1	(10)
(11)		CDD18.3	840	0	0	0	4	41	143	253	266	121	12	1	0	(11)
(12)		CDH23.3	7161	0	0	1	42	324	924	2389	2667	756	56	1	0	(12)
(13)		CDH26.7	2327	0	0	0	4	59	229	840	1019	173	2	0	0	(13)
(14)	Wind	WSAvg	1.8	1.6	1.8	2.0	2.1	2.0	1.8	1.9	1.8	1.6	1.5	1.6	1.6	(14)
(15)	Precipitation	PrecAvg	1286	33	39	59	91	96	164	272	250	143	59	58	30	(15)
(16)		PrecMax	1774	124	104	170	363	246	409	570	584	320	128	162	70	(16)
(17)		PrecMin	707	2	1	7	27	6	24	58	46	2	0	17	3	(17)
(18)		PrecStd	272	26	27	34	62	52	106	118	121	102	40	36	16	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.0	17.2	21.2	26.9	30.3	31.6	34.9	35.6	31.7	26.7	22.2	15.1	(19)
(20)			MCWB	8.2	12.0	12.3	16.3	17.3	20.6	25.7	25.8	22.6	18.2	15.3	10.0	(20)
(21)		2%	DB	9.7	13.1	18.2	24.3	28.3	30.3	33.2	33.7	30.0	24.9	19.4	12.3	(21)
(22)			MCWB	6.0	8.2	10.7	14.8	17.2	20.4	25.3	25.5	21.8	17.3	13.8	8.3	(22)
(23)		5%	DB	7.6	10.8	16.1	22.4	26.7	29.1	32.1	32.7	28.6	23.4	17.6	10.3	(23)
(24)			MCWB	4.3	6.2	9.9	13.6	16.7	20.3	25.2	25.4	21.4	16.6	12.8	6.9	(24)
(25)		10%	DB	5.7	8.6	14.0	20.4	25.1	28.0	30.8	31.5	27.3	21.7	15.7	8.6	(25)
(26)			MCWB	2.9	4.7	8.5	12.9	16.4	20.3	24.9	24.9	21.1	15.9	11.5	5.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.4	13.5	14.9	19.8	22.0	24.9	28.1	28.5	25.9	22.2	17.2	11.6	(27)
(28)			MCDWB	11.2	15.6	17.6	23.0	24.9	27.6	31.3	32.2	27.7	24.3	19.7	13.7	(28)
(29)		2%	WB	6.5	9.2	12.8	17.1	20.1	23.8	27.2	27.4	24.5	20.0	15.5	8.9	(29)
(30)			MCDWB	9.1	11.8	16.2	21.5	23.8	26.6	30.3	30.9	27.4	21.9	18.0	11.5	(30)
(31)		5%	WB	4.8	6.7	10.8	15.4	18.8	23.0	26.5	26.6	23.6	18.4	13.8	7.3	(31)
(32)			MCDWB	6.9	9.7	14.6	19.8	23.2	26.1	29.6	30.0	26.6	21.1	16.6	9.8	(32)
(33)		10%	WB	3.2	5.2	9.1	14.0	17.9	22.1	25.7	26.0	22.5	17.0	12.2	5.8	(33)
(34)			MCDWB	5.4	8.3	13.1	18.2	22.6	25.4	29.0	29.3	25.6	20.3	15.0	8.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.9	9.0	10.3	11.5	11.1	9.0	6.7	7.2	8.7	10.2	9.2	8.0	(35)
(36)			MCDBR	9.8	11.6	13.5	14.3	14.1	11.4	8.5	8.9	10.0	11.8	11.1	10.5	(36)
(37)			MCWBR	6.7	7.2	7.6	6.6	5.4	4.0	2.8	2.8	3.6	5.0	6.2	7.2	(37)
(38)		5% WB	MCDBR	8.4	9.8	10.8	10.8	9.6	7.5	7.1	7.6	7.2	8.4	8.9	9.4	(38)
(39)			MCWBR	6.5	7.2	7.5	6.5	5.1	3.7	3.1	3.2	3.6	5.0	6.3	7.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.447	0.487	0.568	0.591	0.605	0.674	0.621	0.571	0.498	0.478	0.463	0.445	(40)	
(41)		taud	1.921	1.861	1.711	1.708	1.724	1.650	1.818	1.936	2.071	1.994	1.964	1.940	(41)	
(42)		Ebn at Noon	700	725	704	718	716	666	699	726	760	728	680	669	(42)	
(43)		Edh at Noon	147	175	222	234	234	251	211	184	153	151	140	136	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.46	3.25	4.34	5.01	5.54	5.00	4.32	4.45	4.08	3.63	2.56	2.17	(44)	
(45)		RadStd	0.17	0.27	0.41	0.40	0.55	0.45	0.60	0.63	0.43	0.30	0.29	0.16	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (48 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+74	+42

Nomenclature: See separate page