

MOKPO, Korea, Republic of

WMO: 471650

Lat: 34.8169N

Lon: 126.3811E

Elev: 129

StdP: 14.63

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.0	25.5	11.0	9.7	31.4	13.7	11.1	31.2	30.9	32.8	27.9	33.9	7.7	50	0.434

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.2	89.7	78.8	87.5	78.2	85.3	77.3	81.5	85.5	80.0	84.3	78.9	83.3	9.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.6	159.5	83.4	78.9	150.8	82.4	77.6	144.2	81.6	45.4	85.5	43.8	84.3	42.6	83.5	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	26.0	22.6	19.1	92.4	3.6	2.8	16.5	94.4	14.4	96.1	12.3	97.7	9.7	99.7		
(5)			17.0	81.7	2.9	2.4	14.9	83.4	13.2	84.8	11.6	86.1	9.5	87.8	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	57.8	35.5	37.8	44.8	54.7	64.0	71.4	78.0	80.0	72.7	62.7	51.1	39.8	(6)
		DBStd	16.12	5.50	5.87	5.78	5.47	4.18	2.97	4.22	3.99	4.18	4.96	6.36	5.99	(7)
		HDD50	1374	451	343	179	18	0	0	0	0	1	63	319		(8)
		HDD65	3985	916	760	626	310	70	1	0	2	101	418	781		(9)
		CDD50	4228	1	2	19	160	433	641	867	931	681	395	95	3	(10)
		CDD65	1364	0	0	0	2	38	192	402	466	232	31	1	0	(11)
		CDH74	9443	0	0	0	4	123	615	3165	4386	1089	61	0	0	(12)
		CDH80	2445	0	0	0	0	6	49	837	1393	159	1	0	0	(13)
(14)	Wind	WSAvg	8.1	9.4	9.7	9.5	8.4	7.4	6.4	7.4	6.7	6.5	7.6	8.6	9.1	(14)
(15)	Precipitation	PrecAvg	44.6	1.3	1.7	2.4	3.5	3.5	6.1	8.4	7.2	5.2	2.1	2.0	1.3	(15)
(16)		PrecMax	68.9	4.7	5.0	6.0	9.3	9.7	20.8	19.0	18.5	23.0	8.0	6.8	3.6	(16)
(17)		PrecMin	24.1	0.2	0.2	0.2	0.2	0.2	0.6	0.6	0.8	0.1	0.0	0.0	0.1	(17)
(18)		PrecStd	11.2	0.9	1.0	1.5	2.0	1.9	4.4	4.4	4.3	4.5	1.7	1.5	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	54.6	60.4	65.2	73.5	80.5	83.6	92.6	93.2	86.6	78.7	70.3	59.2		(19)
(20)		0.4% MCWB	49.4	55.9	54.6	60.3	64.4	68.0	79.0	80.0	74.6	67.4	59.7	52.9		(20)
(21)		2% DB	49.5	54.6	61.1	70.0	77.2	81.4	88.8	90.7	83.7	75.6	66.4	54.5		(21)
(22)		2% MCWB	44.2	49.0	53.7	57.9	63.0	68.7	78.8	79.1	73.1	64.7	58.5	48.6		(22)
(23)		5% DB	46.3	50.3	58.0	67.2	74.7	79.5	86.7	88.7	81.7	73.2	63.6	51.5		(23)
(24)		5% MCWB	41.1	44.5	50.9	57.1	62.6	69.0	78.3	78.6	72.1	63.8	57.4	46.4		(24)
(25)		10% DB	43.5	46.9	54.8	64.3	72.3	77.6	84.6	86.8	79.7	70.7	60.6	48.7		(25)
(26)		10% MCWB	38.8	41.7	48.4	55.8	62.2	69.1	77.9	78.0	71.4	62.6	55.0	43.7		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	50.3	57.5	59.6	65.8	70.2	75.7	83.5	84.3	78.1	73.1	63.8	54.1		(27)
(28)		0.4% MCDB	52.6	59.4	61.7	69.2	74.1	78.1	86.4	88.7	83.2	76.5	67.0	57.3		(28)
(29)		2% WB	45.5	50.0	55.8	62.6	67.6	74.2	81.5	82.0	76.5	69.1	61.2	50.1		(29)
(30)		2% MCDB	48.7	53.6	59.5	66.6	72.0	76.7	85.0	86.0	80.8	71.5	64.7	53.4		(30)
(31)		5% WB	42.1	45.7	52.3	59.6	66.1	72.9	79.9	80.6	75.0	66.2	58.5	47.0		(31)
(32)		5% MCDB	45.4	49.4	56.2	64.2	70.8	75.7	83.7	85.1	79.0	70.3	62.0	50.6		(32)
(33)		10% WB	39.4	42.4	49.2	57.3	64.6	71.6	78.7	79.5	73.5	63.9	55.8	44.4		(33)
(34)		10% MCDB	42.5	45.7	53.8	62.1	69.7	75.1	82.9	84.0	77.6	68.8	59.9	48.1		(34)
(35)	Mean Daily Temperature Range	MDBR	10.8	12.4	14.0	14.6	14.0	11.2	9.0	10.2	11.9	13.5	12.7	11.4		(35)
(36)		5% DB MCDBR	14.7	17.5	18.6	18.5	17.9	14.8	11.8	12.8	13.8	16.0	15.4	15.4		(36)
(37)		5% DB MCWBR	10.5	12.4	11.6	9.3	7.9	5.8	4.5	4.4	5.9	7.8	9.7	11.3		(37)
(38)		5% WB MCDBR	13.7	15.9	16.3	14.0	13.6	9.1	10.3	11.2	10.6	12.2	12.2	14.1		(38)
(39)		5% WB MCWBR	11.1	13.0	12.7	10.2	8.2	5.3	5.3	5.0	5.9	8.2	9.9	11.9		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.453	0.495	0.558	0.572	0.589	0.647	0.608	0.557	0.502	0.476	0.465	0.452		(40)
(41)		taud	1.943	1.875	1.747	1.768	1.783	1.738	1.881	2.017	2.098	2.030	1.991	1.955		(41)
(42)		Ebn at Noon	224	230	227	233	231	218	225	235	241	234	219	214		(42)
(43)		Edh at Noon	46	56	69	70	70	73	63	54	48	47	44	43		(43)
(44)	All-Sky Solar Radiation	RadAvg	745	1002	1381	1607	1742	1548	1473	1528	1347	1183	824	660		(44)
(45)		RadStd	61	93	122	128	192	146	199	207	130	105	86	45		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	+1.98	N/A	+1.62	+2.16	+101	N/A	N/A	N/A
Regional (26 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+110	N/A

Nomenclature: See separate page