

MOKPO, Korea, Republic of

WMO: 471650

Lat: 34.8169N

Lon: 126.3811E

Elev: 39

StdP: 100.85

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.0	-3.6	-11.7	1.4	-0.3	-10.1	1.6	-0.5	13.8	0.4	12.5	1.1	3.4	50	0.434

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.6	32.0	26.0	30.8	25.7	29.6	25.2	27.5	29.7	26.7	29.0	26.0	28.5	4.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.0	22.8	28.6	26.1	21.5	28.0	25.3	20.6	27.6	87.8	29.7	84.0	29.1	81.1	28.6	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.6	10.1	8.8	-7.2	33.6	2.0	1.6	-8.6	34.7	-9.8	35.6	-10.9	36.5	-12.4	37.6		
			-8.4	27.6	1.6	1.3	-9.5	28.6	-10.4	29.3	-11.4	30.1	-12.5	31.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.3	1.9	3.2	7.1	12.6	17.8	21.9	25.5	26.7	22.6	17.1	10.6	4.3	(6)
(7)		DBStd	8.96	3.05	3.26	3.21	3.04	2.32	1.65	2.34	2.22	2.32	2.75	3.53	3.33	(7)
(8)		HDD10.0	763	251	191	99	10	0	0	0	0	1	35	177		(8)
(9)		HDD18.3	2214	509	422	348	172	39	1	0	1	56	232	434		(9)
(10)		CDD10.0	2349	1	1	11	89	241	356	482	517	378	219	53	2	(10)
(11)		CDD18.3	758	0	0	0	1	21	107	223	259	129	17	1	0	(11)
(12)		CDH23.3	5246	0	0	0	2	68	342	1758	2437	605	34	0	0	(12)
(13)		CDH26.7	1358	0	0	0	0	3	27	465	774	88	1	0	0	(13)
(14)	Wind	WSAvg	3.6	4.2	4.4	4.2	3.8	3.3	2.8	3.3	3.0	2.9	3.4	3.8	4.0	(14)
(15)	Precipitation	PrecAvg	1133	33	42	61	88	90	154	213	182	132	54	51	33	(15)
(16)		PrecMax	1751	119	127	153	236	247	529	483	470	584	203	172	92	(16)
(17)		PrecMin	613	6	5	6	6	6	16	15	20	3	0	1	3	(17)
(18)		PrecStd	284	23	26	39	50	48	112	112	108	114	44	37	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.6	15.8	18.5	23.1	26.9	28.6	33.6	34.0	30.3	26.0	21.3	15.1	(19)
(20)		0.4%	MCWB	9.7	13.3	12.6	15.7	18.0	20.0	26.1	26.7	23.7	19.7	15.4	11.6	(20)
(21)		2%	DB	9.7	12.6	16.1	21.1	25.1	27.5	31.6	32.6	28.7	24.2	19.1	12.5	(21)
(22)		2%	MCWB	6.8	9.4	12.0	14.4	17.2	20.4	26.0	26.2	22.8	18.1	14.7	9.2	(22)
(23)		5%	DB	7.9	10.2	14.4	19.6	23.7	26.4	30.4	31.5	27.6	22.9	17.5	10.8	(23)
(24)		5%	MCWB	5.1	6.9	10.5	14.0	17.0	20.6	25.7	25.9	22.3	17.7	14.1	8.0	(24)
(25)		10%	DB	6.4	8.3	12.7	18.0	22.4	25.3	29.2	30.4	26.5	21.5	15.9	9.3	(25)
(26)		10%	MCWB	3.8	5.4	9.1	13.2	16.8	20.6	25.5	25.6	21.9	17.0	12.8	6.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	14.2	15.3	18.8	21.2	24.3	28.6	29.0	25.6	22.8	17.7	12.3	(27)
(28)		0.4%	MCDWB	11.5	15.2	16.5	20.7	23.4	25.6	30.2	31.5	28.5	24.7	19.4	14.1	(28)
(29)		2%	WB	7.5	10.0	13.2	17.0	19.8	23.5	27.5	27.8	24.7	20.6	16.2	10.1	(29)
(30)		2%	MCDWB	9.3	12.0	15.3	19.2	22.2	24.8	29.5	30.0	27.1	22.0	18.2	11.9	(30)
(31)		5%	WB	5.6	7.6	11.3	15.4	18.9	22.7	26.6	27.0	23.9	19.0	14.7	8.4	(31)
(32)		5%	MCDWB	7.5	9.6	13.4	17.9	21.5	24.3	28.7	29.5	26.1	21.3	16.6	10.4	(32)
(33)		10%	WB	4.1	5.8	9.5	14.0	18.1	22.0	25.9	26.4	23.0	17.7	13.2	6.9	(33)
(34)		10%	MCDWB	5.9	7.6	12.1	16.7	20.9	23.9	28.3	28.9	25.3	20.5	15.5	9.0	(34)
(35)	Mean Daily Temperature Range	MDBR	6.0	6.9	7.8	8.1	7.8	6.2	5.0	5.6	6.6	7.5	7.0	6.3	(35)	
(36)		5% DB	MCDBR	8.1	9.7	10.4	10.3	10.0	8.2	6.6	7.1	7.7	8.9	8.5	8.5	(36)
(37)		5% DB	MCWBR	5.9	6.9	6.5	5.2	4.4	3.2	2.5	2.5	3.3	4.3	5.4	6.3	(37)
(38)		5% WB	MCDBR	7.6	8.8	9.0	7.8	7.6	5.1	5.7	6.2	5.9	6.8	6.8	7.8	(38)
(39)		5% WB	MCWBR	6.2	7.2	7.0	5.7	4.6	2.9	2.9	2.8	3.3	4.6	5.5	6.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.453	0.495	0.558	0.572	0.589	0.647	0.608	0.557	0.502	0.476	0.465	0.452	(40)	
(41)		taud	1.943	1.875	1.747	1.768	1.783	1.738	1.881	2.017	2.098	2.030	1.991	1.955	(41)	
(42)		Ebn at Noon	705	726	717	735	729	686	710	740	761	738	690	675	(42)	
(43)		Edh at Noon	146	175	216	221	221	230	199	170	150	148	139	137	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.35	3.16	4.35	5.07	5.49	4.88	4.64	4.82	4.25	3.73	2.60	2.08	(44)	
(45)		RadStd	0.19	0.29	0.38	0.40	0.60	0.46	0.63	0.65	0.41	0.33	0.27	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
(47)	Regional (26 neighbors)	N/A	N/A	+1.10	N/A	+0.90	+1.20	+56	N/A	N/A	N/A	(47)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+61	N/A	

Nomenclature: See separate page