

YEOSU, Korea, Republic of

WMO: 471680

Lat: 34.7392N

Lon: 127.7406E

Elev: 66

StdP: 100.54

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.9	(c) -3.4	(d) -18.7	(e) 0.7	(f) -0.2	(g) -16.5	(h) 0.9	(i) 0.2	(j) 13.6	(k) 1.3	(l) 12.5	(m) 1.3	(n) 6.3	(o) 320	(p) 0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 4.4	(c) 30.9	(d) 25.3	(e) 29.8	(f) 25.0	(g) 28.7	(h) 24.6	(i) 26.6	(j) 29.0	(k) 26.0	(l) 28.4	(m) 25.4	(n) 27.8	(o) 4.0	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 25.9	(b) 21.4	(c) 27.9	(d) 25.3	(e) 20.6	(f) 27.5	(g) 24.7	(h) 19.9	(i) 27.1	(j) 83.5	(k) 29.2	(l) 81.0	(m) 28.4	(n) 78.6	(o) 27.9	(p) 28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.0	10.4	9.2	-7.4	32.7	1.9	1.6	-8.7	33.9	-9.8	34.8	-10.8	35.7	-12.2	36.8
			-9.4	26.7	1.6	1.0	-10.5	27.5	-11.5	28.1	-12.4	28.6	-13.5	29.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.9	2.9	4.6	8.4	13.5	18.1	21.4	24.9	26.3	22.8	17.9	11.6	5.4		
	DBStd	8.38	3.27	3.44	3.18	2.62	2.18	1.64	2.35	2.02	2.11	2.66	3.52	3.60		
	HDD10.0	618	220	153	68	4	0	0	0	0	0	1	24	147		
	HDD18.3	1991	478	385	307	146	31	1	0	0	0	38	204	402		
	CDD10.0	2396	1	2	19	109	252	341	462	507	384	247	71	4		
	CDD18.3	728	0	0	0	1	24	92	203	248	134	26	1	0		
	CDH23.3	4360	0	0	0	1	48	169	1373	2211	537	21	0	0		
	CDH26.7	901	0	0	0	0	2	7	290	551	52	1	0	0		
(14) Wind	WSAvg	4.1	5.0	4.8	4.6	4.1	3.6	3.2	3.6	3.7	4.2	4.1	4.2	4.7		
(15) Precipitation	PrecAvg	1422	23	42	76	135	142	204	263	246	155	59	49	24		
	PrecMax	2451	103	131	224	301	432	834	611	662	509	201	220	97		
	PrecMin	863	0	0	10	12	0	28	62	20	5	0	0	0		
	PrecStd	326	20	30	46	62	75	144	139	151	128	49	44	21		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	14.7	17.7	21.7	26.5	27.6	32.5	32.6	29.6	25.3	20.6	15.0		
		MCWB	9.5	11.4	11.6	14.3	16.2	19.9	25.7	25.7	23.8	19.7	15.5	11.4		
	2%	DB	10.1	12.6	15.8	20.1	24.6	26.1	30.6	31.2	28.0	23.7	18.9	12.9		
		MCWB	6.1	8.6	10.9	13.3	16.1	20.0	25.5	25.3	22.9	18.2	14.9	9.0		
	5%	DB	8.7	10.9	14.4	18.7	23.2	25.2	29.4	30.3	27.0	22.8	17.6	11.6		
		MCWB	4.9	6.7	10.1	12.9	15.7	19.7	25.1	25.1	22.1	17.6	13.7	7.6		
	10%	DB	7.5	9.5	13.2	17.6	21.9	24.2	28.2	29.4	26.1	21.7	16.4	10.3		
		MCWB	3.8	5.5	9.1	12.6	15.6	19.7	24.7	24.8	21.7	16.8	12.5	6.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.4	13.1	14.6	17.9	20.4	23.4	27.2	27.4	25.5	22.5	17.6	12.2		
		MCDB	11.8	14.0	15.7	18.8	22.2	24.5	29.9	29.6	27.6	23.5	19.1	13.8		
	2%	WB	7.1	9.7	12.7	16.5	19.2	22.7	26.4	26.7	24.6	20.3	16.0	9.8		
		MCDB	9.3	11.7	14.5	18.0	21.1	23.8	28.8	29.1	26.7	22.7	17.9	12.2		
	5%	WB	5.7	7.5	11.2	15.1	18.2	22.0	25.9	26.2	23.9	18.9	14.6	8.4		
		MCDB	8.1	10.0	13.5	17.3	20.6	23.3	28.1	28.8	26.1	21.6	17.0	11.1		
	10%	WB	4.3	6.1	9.8	13.9	17.4	21.2	25.4	25.7	23.0	17.7	13.2	7.0		
		MCDB	7.0	8.8	12.4	16.2	20.1	22.9	27.6	28.2	25.1	20.7	16.0	9.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.0	6.5	6.6	6.4	6.0	4.5	4.0	4.4	4.9	5.8	5.9	6.0		
		MCDBR	6.6	7.5	7.5	7.8	8.1	6.3	5.6	5.5	5.7	6.3	6.4	6.6		
	5% WB	MCWBR	4.7	5.2	5.3	4.4	4.2	3.0	2.3	2.2	2.9	3.5	4.5	5.1		
		MCWBR	5.9	6.5	6.6	5.9	5.7	3.8	5.0	4.6	4.6	5.1	5.6	6.1		
(40) Clear-Sky Solar Irradiance	taub		0.418	0.463	0.534	0.556	0.572	0.618	0.587	0.544	0.492	0.455	0.430	0.413		
	taud		2.051	1.974	1.819	1.821	1.833	1.802	1.937	2.050	2.142	2.121	2.099	2.082		
	Ebn at Noon		749	759	739	749	743	707	726	751	771	761	732	726		
	Edh at Noon		131	158	201	210	210	216	188	165	144	135	124	121		
(44) All-Sky Solar Radiation	RadAvg		2.67	3.37	4.39	5.02	5.44	4.75	4.52	4.67	4.07	3.73	2.78	2.43		
	RadStd		0.20	0.30	0.36	0.40	0.61	0.45	0.67	0.59	0.43	0.34	0.28	0.13		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page