

NAMWON, Korea, Republic of

WMO: 471730

Lat: 35.4214N

Lon: 127.3964E

Elev: 134

StdP: 99.73

Time Zone: 9.00 (E09)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.4	-9.4	-18.7	0.7	-2.7	-16.9	0.9	-3.8	5.5	-1.0	5.2	0.4	1.1	340	0.384

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.9	33.1	24.4	31.8	23.8	30.4	23.1	25.6	29.7	25.1	29.2	24.7	28.6	2.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.7	20.0	26.9	24.1	19.4	26.8	23.6	18.7	26.6	79.9	29.7	77.9	29.5	75.9	28.8	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.8	5.1	4.4	-14.0	34.8	2.6	1.0	-15.9	35.5	-17.4	36.1	-18.9	36.7	-20.8	37.4		
(5)			-14.5	26.4	2.4	0.6	-16.3	26.8	-17.7	27.2	-19.1	27.5	-20.9	27.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.9	-1.5	1.5	6.3	11.8	17.9	22.4	25.7	26.0	21.2	14.7	7.9	0.7		
	DBStd	10.06	3.90	3.95	3.88	3.68	2.74	1.87	2.19	2.44	2.58	3.29	4.31	3.86		
	HDD10.0	1135	358	239	129	24	0	0	0	0	4	91	288			
	HDD18.3	2683	616	472	374	196	41	1	0	0	5	120	313	546		
	CDD10.0	2209	0	2	13	79	245	372	486	497	337	149	28	1		
	CDD18.3	716	0	0	0	1	28	122	228	238	92	7	1	0		
	CDH23.3	5906	0	0	1	31	349	819	1964	2181	536	25	1	0		
	CDH26.7	1839	0	0	0	2	66	190	656	823	102	1	0	0		
(14) Wind	WSAvg	1.6	1.5	1.6	1.9	2.1	1.9	1.6	1.6	1.5	1.5	1.5	1.5	1.4		
(15) Precipitation	PrecAvg	1322	31	43	50	102	94	182	311	226	143	59	46	33		
	PrecMax	1904	112	113	96	244	182	443	661	397	399	150	101	72		
	PrecMin	800	7	3	8	18	2	12	40	74	12	5	14	0		
	PrecStd	317	24	32	21	60	50	111	162	107	114	40	25	18		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.8	16.2	21.5	26.6	30.5	31.5	34.1	34.9	31.1	25.7	21.2	13.7		
		MCWB	6.0	12.6	11.7	13.6	16.5	19.6	24.7	24.6	23.1	18.1	15.6	10.7		
	2%	DB	8.4	13.2	18.7	23.9	28.4	30.0	32.8	33.6	29.1	23.8	18.5	10.7		
		MCWB	4.1	7.7	10.2	12.9	16.0	19.7	24.6	24.5	21.7	16.8	13.8	7.2		
	5%	DB	6.5	11.0	16.3	21.8	26.9	28.8	31.5	32.5	27.7	22.3	16.7	8.7		
		MCWB	2.7	5.8	9.4	12.0	15.7	19.3	24.1	24.4	20.5	16.0	12.3	5.5		
	10%	DB	4.6	8.6	14.1	19.8	25.3	27.6	30.2	31.1	26.5	20.9	14.9	6.9		
		MCWB	1.3	4.2	8.6	11.2	15.6	19.2	23.9	24.2	20.0	15.2	11.2	3.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.0	13.7	14.4	16.6	21.2	23.7	26.2	26.5	24.7	21.2	17.5	12.0		
		MCDB	9.5	15.4	16.5	20.9	23.1	26.7	29.8	30.9	28.8	23.4	20.3	12.6		
	2%	WB	4.8	10.0	12.7	15.1	19.1	22.8	25.6	25.7	23.6	19.7	15.1	8.0		
		MCDB	8.0	11.4	15.9	19.8	23.5	25.8	29.2	30.2	26.5	22.1	16.8	10.0		
	5%	WB	3.4	6.6	11.1	14.0	17.7	21.7	25.1	25.3	22.7	18.1	13.4	5.9		
		MCDB	5.8	9.7	15.7	18.0	23.1	25.1	29.1	29.5	25.6	20.0	15.7	8.1		
	10%	WB	1.7	4.6	8.9	12.9	16.9	20.9	24.7	24.9	21.6	16.2	11.8	4.2		
		MCDB	4.2	8.0	13.4	17.6	22.5	24.8	28.7	28.9	25.0	19.5	14.6	6.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.0	10.5	12.2	13.2	13.0	9.6	7.1	7.9	9.5	11.7	10.8	9.2		
		MCDBR	12.0	14.0	16.0	17.2	16.6	12.2	9.3	10.2	11.1	13.2	12.5	11.2		
	5% WB	MCWBR	7.7	8.7	8.6	7.5	5.9	3.6	2.6	2.7	4.2	6.1	7.1	7.7		
		MCWBR	10.4	11.3	12.1	10.7	11.1	7.6	7.7	8.2	7.8	7.0	9.5	9.8		
(40) Clear-Sky Solar Irradiance	taub		0.438	0.482	0.563	0.587	0.600	0.664	0.616	0.570	0.498	0.471	0.452	0.435		
		taud	1.944	1.878	1.721	1.719	1.730	1.668	1.831	1.939	2.073	2.020	1.991	1.967		
	Ebn at Noon		715	734	710	722	720	674	704	728	761	738	697	686		
		Edh at Noon	145	173	221	232	232	247	209	184	153	148	137	133		
(44) All-Sky Solar Radiation	RadAvg		2.56	3.32	4.36	4.99	5.50	4.86	4.28	4.40	4.02	3.64	2.65	2.27		
	RadStd		0.18	0.26	0.40	0.40	0.55	0.45	0.60	0.61	0.43	0.32	0.29	0.15		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+63	N/A

Nomenclature: See separate page