

JINJU, Korea, Republic of

WMO: 471920

Lat: 35.1639N

Lon: 128.0400E

Elev: 98

StdP: 14.64

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.7	19.4	-5.0	4.2	31.7	-1.2	5.2	32.0	17.7	35.5	14.8	35.7	1.4	0	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.8	91.8	76.6	89.4	75.9	87.1	74.9	79.1	86.9	78.2	85.4	77.2	83.9	5.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.1	141.4	82.7	76.1	137.0	82.0	75.3	132.9	81.4	42.7	87.3	41.8	85.7	40.9	84.0	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.9	11.7	9.8	10.4	95.6	2.9	2.7	8.3	97.5	6.5	99.0	4.9	100.5	2.8	102.5		
			9.0	80.6	2.8	1.2	7.0	81.4	5.3	82.1	3.7	82.7	1.6	83.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	56.9	33.4	37.3	45.2	55.3	64.6	71.7	78.3	79.5	71.2	60.3	48.0	36.8	(6)
(7)		DBStd	16.72	5.28	5.97	5.93	5.69	4.41	3.62	4.58	4.20	4.99	5.68	6.49	5.61	(7)
(8)		HDD50	1592	516	359	173	17	0	0	0	0	0	4	114	409	(8)
(9)		HDD65	4288	981	777	615	293	62	2	0	0	7	167	511	873	(9)
(10)		CDD50	4104	0	2	23	176	451	651	876	914	635	322	53	1	(10)
(11)		CDD65	1327	0	0	0	3	48	204	412	449	191	20	0	0	(11)
(12)		CDH74	10891	0	0	0	44	503	1242	3564	4212	1214	111	1	0	(12)
(13)		CDH80	3431	0	0	0	1	84	277	1223	1565	278	3	0	0	(13)
(14)	Wind	WSAvg	3.1	3.1	3.3	3.8	3.8	3.5	3.2	3.5	3.1	2.8	2.4	2.5	2.7	(14)
(15)	Precipitation	PrecAvg	60.1	1.3	1.9	2.8	5.8	5.2	8.7	12.1	11.3	6.9	2.0	1.8	0.9	(15)
(16)		PrecMax	86.3	6.5	5.6	8.7	10.7	13.8	20.2	23.5	23.7	19.1	6.9	6.1	2.2	(16)
(17)		PrecMin	36.7	0.0	0.0	0.4	0.9	0.3	1.3	3.5	2.2	0.7	0.0	0.1	0.0	(17)
(18)		PrecStd	14.4	1.5	1.5	1.7	3.1	3.1	4.8	6.2	6.4	5.1	1.9	1.5	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.1	61.9	69.0	78.5	86.2	89.0	95.5	95.0	88.8	80.0	70.9	59.2	(19)
(20)		MCWB	44.9	52.2	51.9	58.8	63.8	68.7	77.3	77.2	73.1	65.3	58.2	49.5	(20)	
(21)		2%	DB	49.7	56.8	64.6	74.7	82.1	85.5	91.9	92.2	85.7	77.2	66.7	54.5	(21)
(22)		MCWB	40.4	45.5	50.4	56.9	61.8	68.0	77.2	77.0	72.1	63.0	55.2	45.1	(22)	
(23)		5%	DB	46.6	53.2	61.4	71.4	79.3	83.2	89.1	90.2	83.3	74.4	63.5	51.3	(23)
(24)		MCWB	37.6	43.1	49.2	55.5	60.9	67.5	76.8	76.4	70.9	61.7	53.4	42.4	(24)	
(25)		10%	DB	43.8	49.5	58.3	68.2	76.5	80.9	86.6	88.0	80.8	71.6	60.1	48.1	(25)
(26)		MCWB	35.9	39.7	47.2	54.2	60.2	67.1	76.1	76.0	69.3	60.4	51.4	40.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.3	56.1	58.4	66.1	69.8	75.6	80.1	80.6	77.7	70.8	62.5	51.7	(27)
(28)		MADB	51.0	59.6	61.8	70.8	73.6	80.3	89.6	89.0	84.3	74.6	67.5	56.7	(28)	
(29)		2%	WB	42.2	48.1	54.7	62.1	67.3	74.0	79.0	79.4	76.1	67.7	58.7	47.0	(29)
(30)		MADB	47.2	54.3	60.4	67.9	74.0	78.9	87.3	87.1	81.6	72.3	63.3	52.1	(30)	
(31)		5%	WB	39.7	43.9	51.4	59.2	65.3	72.3	78.1	78.5	74.5	64.8	55.9	44.1	(31)
(32)		MADB	44.4	50.4	58.9	65.8	72.8	77.7	85.6	85.7	79.6	71.0	61.0	49.4	(32)	
(33)		10%	WB	37.1	41.2	48.3	56.9	63.6	70.6	77.2	77.7	72.4	62.4	53.0	41.3	(33)
(34)		MADB	42.7	47.6	55.6	64.1	71.4	76.6	84.1	84.4	77.5	69.0	58.3	47.1	(34)	
(35)	Mean Daily Temperature Range	MDBR	20.6	21.6	22.2	22.8	21.5	16.4	12.3	13.8	16.7	21.9	22.4	21.5	(35)	
(36)		5% DB	MCDBR	24.4	26.8	27.4	28.7	27.7	22.5	17.2	17.8	19.3	24.2	26.2	25.7	(36)
(37)		MCWBR	15.5	16.2	14.7	12.7	10.3	7.5	5.4	5.3	7.1	10.8	14.4	16.2	(37)	
(38)		5% WB	MCDBR	20.3	22.9	21.8	19.2	18.6	12.9	14.1	14.3	13.6	17.5	19.6	22.8	(38)
(39)		MCWBR	14.4	15.8	14.7	11.8	9.7	6.4	5.2	5.2	6.6	9.3	12.9	16.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.429	0.480	0.562	0.590	0.604	0.658	0.617	0.573	0.509	0.473	0.446	0.424	(40)	
(41)		taud	1.995	1.909	1.744	1.732	1.747	1.703	1.850	1.953	2.071	2.044	2.030	2.026	(41)	
(42)		Ebn at Noon	232	234	226	228	228	215	223	231	239	234	224	224	(42)	
(43)		Edh at Noon	44	53	69	73	73	76	65	57	49	46	42	40	(43)	
(44)	All-Sky Solar Radiation	RadAvg	856	1075	1394	1591	1750	1543	1416	1445	1269	1169	875	771	(44)	
(45)		RadStd	63	97	122	125	182	140	205	187	136	106	97	45	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page