

JINJU, Korea, Republic of

WMO: 471920

Lat: 35.1639N

Lon: 128.0400E

Elev: 30

StdP: 100.97

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.5	-7.0	-20.6	0.6	-0.2	-18.4	0.7	0.0	7.9	2.0	6.6	2.1	0.6	0	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.6	33.2	24.8	31.9	24.4	30.6	23.8	26.2	30.5	25.6	29.7	25.1	28.8	2.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.0	20.2	28.2	24.5	19.6	27.8	24.0	19.0	27.4	81.5	30.7	79.3	29.8	77.1	28.9	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.2	5.2	4.4	-12.0	35.3	1.6	1.5	-13.2	36.4	-14.1	37.2	-15.1	38.1	-16.2	39.1		
			-12.8	27.0	1.6	0.6	-13.9	27.4	-14.8	27.8	-15.7	28.2	-16.9	28.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.8	0.8	2.9	7.3	13.0	18.1	22.1	25.7	26.4	21.8	15.7	8.9	2.7
	DBStd	9.29	2.93	3.32	3.29	3.16	2.45	2.01	2.55	2.34	2.77	3.16	3.60	3.12
	HDD10.0	884	287	199	96	9	0	0	0	0	0	2	63	227
	HDD18.3	2382	545	432	342	163	34	1	0	0	4	93	284	485
	CDD10.0	2280	0	1	13	98	251	362	487	508	353	179	29	1
	CDD18.3	737	0	0	0	2	27	113	229	249	106	11	0	0
	CDH23.3	6051	0	0	0	24	279	690	1980	2340	674	62	1	0
	CDH26.7	1906	0	0	0	1	47	154	679	869	154	2	0	0
Wind	WSAvg	1.4	1.4	1.5	1.7	1.7	1.5	1.4	1.6	1.4	1.2	1.1	1.1	1.2
Precipitation	PrecAvg	1526	33	49	70	148	131	221	307	288	174	51	45	23
	PrecMax	2193	165	143	220	271	351	513	598	601	486	176	156	56
	PrecMin	931	0	0	9	23	8	34	90	57	17	0	2	0
	PrecStd	366	37	39	43	78	78	122	158	163	130	47	38	18
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.3	16.6	20.5	25.8	30.1	31.7	35.3	35.0	31.6	26.7	21.6	15.1
		MCWB	7.2	11.2	11.1	14.9	17.7	20.4	25.2	25.1	22.9	18.5	14.5	9.7
	2%	DB	9.8	13.8	18.1	23.7	27.8	29.7	33.3	33.5	29.8	25.1	19.3	12.5
		MCWB	4.7	7.5	10.2	13.8	16.6	20.0	25.1	25.0	22.3	17.2	12.9	7.3
	5%	DB	8.1	11.8	16.3	21.9	26.3	28.4	31.7	32.3	28.5	23.6	17.5	10.7
		MCWB	3.1	6.2	9.5	13.1	16.1	19.7	24.9	24.6	21.6	16.5	11.9	5.8
	10%	DB	6.6	9.7	14.6	20.1	24.7	27.1	30.3	31.1	27.1	22.0	15.6	9.0
		MCWB	2.2	4.3	8.4	12.3	15.7	19.5	24.5	24.5	20.7	15.8	10.8	4.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	13.4	14.7	19.0	21.0	24.2	26.7	27.0	25.4	21.6	16.9	10.9
		MCDB	10.6	15.3	16.5	21.5	23.1	26.8	32.0	31.6	29.0	23.6	19.7	13.7
	2%	WB	5.6	8.9	12.6	16.7	19.6	23.3	26.1	26.3	24.5	19.8	14.8	8.4
		MCDB	8.4	12.4	15.8	19.9	23.3	26.0	30.7	30.6	27.6	22.4	17.4	11.2
	5%	WB	4.3	6.6	10.8	15.1	18.5	22.4	25.6	25.8	23.6	18.2	13.3	6.7
		MCDB	6.9	10.2	15.0	18.8	22.6	25.4	29.8	29.8	26.4	21.6	16.1	9.7
	10%	WB	2.8	5.1	9.0	13.8	17.5	21.4	25.1	25.4	22.4	16.9	11.6	5.2
		MCDB	5.9	8.7	13.1	17.8	21.9	24.8	28.9	29.1	25.3	20.6	14.6	8.4
Mean Daily Temperature Range	5% DB	MDBR	11.4	12.0	12.3	12.6	11.9	9.1	6.8	7.6	9.3	12.2	12.4	11.9
		MCDBR	13.6	14.9	15.2	15.9	15.4	12.5	9.5	9.9	10.7	13.4	14.5	14.3
		MCWBR	8.6	9.0	8.2	7.0	5.7	4.1	3.0	2.9	4.0	6.0	8.0	9.0
	5% WB	MCDBR	11.3	12.7	12.1	10.7	10.3	7.2	7.8	7.9	7.6	9.7	10.9	12.7
		MCWBR	8.0	8.8	8.2	6.6	5.4	3.6	2.9	2.9	3.7	5.1	7.2	8.9
Clear-Sky Solar Irradiance	taub	0.429	0.480	0.562	0.590	0.604	0.658	0.617	0.573	0.509	0.473	0.446	0.424	
	taud	1.995	1.909	1.744	1.732	1.747	1.703	1.850	1.953	2.071	2.044	2.030	2.026	
	Ebn at Noon	730	739	712	720	718	678	704	727	754	738	707	706	
	Edh at Noon	138	168	216	229	229	239	205	181	154	145	132	126	
All-Sky Solar Radiation	RadAvg	2.70	3.39	4.39	5.02	5.52	4.86	4.46	4.56	4.00	3.69	2.76	2.43	
	RadStd	0.20	0.30	0.39	0.39	0.57	0.44	0.65	0.59	0.43	0.34	0.30	0.14	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page