

MURORAN YAKUMO, Japan

WMO: 474230

Lat: 42.3117N

Lon: 140.9753E

Elev: 50

StdP: 100.73

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.7	(c) -6.6	(d) -13.8	(e) 1.1	(f) -6.6	(g) -12.5	(h) 1.3	(i) -5.7	(j) 14.9	(k) -3.1	(l) 13.6	(m) -3.3	(n) 6.8	(o) 300	(p) 0.566

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 4.3	(c) 26.5	(d) 22.8	(e) 25.0	(f) 22.0	(g) 23.8	(h) 21.4	(i) 23.6	(j) 25.5	(k) 22.8	(l) 24.3	(m) 22.0	(n) 23.3	(o) 3.7	(p) 290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.0	17.8	24.8	22.2	17.0	23.8	21.5	16.2	23.0	70.9	25.6	67.9	24.4	64.8	23.3	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 12.5	(b) 11.0	(c) 9.6	(e) -9.0	(f) 28.9	(g) 1.4	(h) 1.4	(i) -10.0	(j) 29.9	(k) -10.8	(l) 30.7	(m) -11.6	(n) 31.5	(o) -12.6	(p) 32.6		
(4) 12.5	(5) 11.0	(6) 9.6	(7) -9.0	(8) 28.9	(9) 1.4	(10) 1.4	(11) -10.0	(12) 29.9	(13) -10.8	(14) 30.7	(15) -11.6	(16) 31.5	(17) -12.6	(18) 32.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.1	-1.9	-1.6	1.5	6.3	11.0	14.7	18.9	21.2	18.7	12.9	6.3	0.5	(6)
(7)		DBStd	8.48	2.57	2.70	2.77	2.75	2.83	2.72	2.75	2.33	2.43	2.90	3.84	3.16	(7)
(8)		HDD10.0	1520	370	325	264	115	21	1	0	0	0	9	121	294	(8)
(9)		HDD18.3	3544	628	558	522	360	227	112	26	4	24	168	361	553	(9)
(10)		CDD10.0	1194	0	0	0	5	53	143	277	346	261	99	10	0	(10)
(11)		CDD18.3	176	0	0	0	0	0	4	45	92	34	0	0	0	(11)
(12)		CDH23.3	371	0	0	0	0	1	6	97	223	44	0	0	0	(12)
(13)		CDH26.7	32	0	0	0	0	0	0	6	24	2	0	0	0	(13)
(14)	Wind	WSAvg	4.6	5.7	5.3	4.9	4.4	4.1	3.6	3.5	3.4	3.8	4.6	5.5	6.1	(14)
(15)	Precipitation	PrecAvg	1223	73	57	54	72	102	93	147	175	162	101	101	86	(15)
(16)		PrecMax	1480	130	129	100	129	169	235	317	353	319	148	271	149	(16)
(17)		PrecMin	1011	41	26	19	14	34	28	37	69	33	52	60	52	(17)
(18)		PrecStd	132	22	25	20	33	37	48	64	76	72	29	42	26	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.9	6.1	10.8	17.1	21.8	24.2	27.5	28.9	26.5	20.5	16.0	10.8	(19)
(20)			MCWB	4.3	4.1	6.7	10.9	14.2	19.0	22.9	24.3	22.7	16.9	13.2	9.4	(20)
(21)		2%	DB	4.1	4.4	8.4	14.3	19.2	22.1	25.7	27.1	24.5	19.0	14.5	8.6	(21)
(22)			MCWB	2.6	2.5	5.3	9.3	13.3	17.7	22.0	23.4	21.5	16.1	12.1	7.0	(22)
(23)		5%	DB	2.9	3.3	6.7	12.1	17.2	20.3	24.3	25.6	23.3	18.0	13.2	6.7	(23)
(24)			MCWB	1.1	1.4	4.2	7.9	12.5	16.8	21.3	22.7	20.7	15.5	11.0	4.8	(24)
(25)		10%	DB	1.8	2.3	5.4	10.4	15.3	18.8	22.9	24.4	22.2	17.0	12.0	5.3	(25)
(26)			MCWB	0.1	0.5	3.1	6.9	11.6	16.1	20.6	22.1	19.9	14.6	9.8	3.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.6	4.6	7.5	11.8	15.8	19.9	23.7	25.1	23.7	18.6	14.2	9.5	(27)
(28)			MCDWB	5.5	5.6	9.8	15.7	20.1	23.2	26.1	27.8	25.1	19.3	15.3	10.5	(28)
(29)		2%	WB	2.9	2.9	5.9	9.8	14.2	18.5	22.8	24.1	22.6	17.0	12.6	7.2	(29)
(30)			MCDWB	3.9	4.0	7.8	13.6	17.7	21.1	24.9	26.2	23.7	18.2	14.0	8.4	(30)
(31)		5%	WB	1.5	1.8	4.6	8.6	13.1	17.4	21.8	23.3	21.5	16.0	11.3	5.1	(31)
(32)			MCDWB	2.6	2.9	6.3	11.2	16.1	19.6	23.6	24.9	22.6	17.5	12.9	6.6	(32)
(33)		10%	WB	0.2	0.8	3.4	7.6	12.1	16.4	20.9	22.5	20.4	15.0	10.0	3.4	(33)
(34)			MCDWB	1.6	2.1	5.1	9.8	14.5	18.3	22.4	23.9	21.7	16.7	11.9	5.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.0	4.3	5.1	6.1	6.2	5.3	4.6	4.3	5.1	5.6	5.1	4.1	(35)
(36)			MCDBR	5.1	5.3	6.8	8.6	9.5	7.9	7.0	6.2	5.8	5.9	6.4	6.0	(36)
(37)			MCWBR	4.7	4.7	5.0	5.1	5.3	4.5	3.9	3.5	3.8	4.5	5.8	6.0	(37)
(38)		5% WB	MCDWB	5.3	5.3	6.6	7.7	8.3	6.9	6.1	5.5	4.7	5.2	6.3	6.1	(38)
(39)			MCWBR	5.4	5.2	5.5	5.1	5.1	4.3	3.7	3.3	3.4	4.5	6.2	6.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.346	0.395	0.469	0.528	0.548	0.523	0.513	0.481	0.422	0.407	0.389	0.363	(40)	
(41)		taud	2.102	1.962	1.849	1.794	1.839	1.986	2.085	2.192	2.310	2.209	2.152	2.091	(41)	
(42)		Ebn at Noon	756	772	759	748	747	768	770	784	807	761	702	692	(42)	
(43)		Edh at Noon	106	144	182	208	204	177	158	138	114	112	101	99	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.43	2.17	3.38	4.51	5.02	4.82	4.25	4.13	3.66	2.74	1.63	1.18	(44)	
(45)		RadStd	0.09	0.17	0.23	0.48	0.46	0.43	0.43	0.35	0.35	0.17	0.14	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	+0.50	N/A	N/A	+0.86	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page