

ESASHI, Japan

WMO: 474280

Lat: 41.8672N

Lon: 140.1242E

Elev: 12

StdP: 101.18

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.6	-5.5	-12.4	1.3	-4.8	-11.3	1.4	-3.9	16.9	-1.5	15.8	-2.5	8.3	300	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.3	27.7	23.5	26.6	22.8	25.6	22.1	24.3	26.9	23.6	25.9	22.8	25.1	3.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	18.3	26.1	22.7	17.5	25.4	21.9	16.6	24.8	73.6	27.1	70.5	25.9	67.7	25.1	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.5	13.1	11.8	-8.7	30.0	1.6	1.7	-9.9	31.2	-10.8	32.2	-11.8	33.1	-12.9	34.3		
(5)			-9.8	25.0	1.4	1.2	-10.8	25.8	-11.6	26.5	-12.4	27.2	-13.4	28.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	-0.9	-0.3	2.7	7.6	12.3	16.5	20.8	22.9	19.5	13.5	7.2	1.6	(6)
(7)		DBStd	8.60	2.60	2.95	2.93	2.71	2.47	2.25	2.18	2.11	2.70	2.91	3.70	3.14	(7)
(8)		HDD10.0	1307	338	290	227	82	7	0	0	0	5	98	261		(8)
(9)		HDD18.3	3202	597	523	485	323	186	64	4	1	17	151	333	519	(9)
(10)		CDD10.0	1432	0	0	0	9	79	194	336	399	286	114	15	0	(10)
(11)		CDD18.3	284	0	0	0	0	0	8	81	141	53	1	0	0	(11)
(12)		CDH23.3	983	0	0	0	0	1	11	187	626	158	0	0	0	(12)
(13)		CDH26.7	96	0	0	0	0	0	1	16	64	16	0	0	0	(13)
(14)	Wind	WSAvg	4.6	7.1	6.7	5.9	4.4	3.2	2.5	2.6	2.7	3.1	4.4	6.2	7.2	(14)
(15)	Precipitation	PrecAvg	1229	85	68	62	74	99	76	127	168	144	103	117	106	(15)
(16)		PrecMax	1572	137	163	99	132	226	178	370	430	265	183	218	173	(16)
(17)		PrecMin	939	45	24	29	9	40	27	55	55	43	54	67	51	(17)
(18)		PrecStd	158	25	28	21	32	43	37	63	87	62	32	37	29	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.2	9.1	11.8	17.7	21.6	25.0	28.4	29.6	28.7	22.0	17.5	12.0	(19)
(20)			MCWB	4.9	6.8	8.3	11.7	14.9	19.1	23.1	24.8	23.5	17.7	14.3	9.5	(20)
(21)		2%	DB	5.5	6.7	9.9	15.1	19.6	22.4	26.5	28.2	26.3	20.6	15.9	9.7	(21)
(22)			MCWB	3.2	4.4	7.1	10.6	14.1	18.1	22.4	24.0	22.2	16.6	12.7	7.3	(22)
(23)		5%	DB	4.3	5.3	8.6	13.2	17.9	21.1	25.2	27.2	25.1	19.5	14.6	8.0	(23)
(24)			MCWB	1.9	3.0	6.1	9.5	13.6	17.4	21.9	23.4	21.3	15.7	11.6	5.4	(24)
(25)		10%	DB	3.1	4.1	7.4	11.9	16.4	20.1	24.2	26.3	23.9	18.4	13.2	6.4	(25)
(26)			MCWB	0.8	1.7	5.0	8.9	13.0	17.1	21.5	22.9	20.2	14.7	10.2	3.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.3	7.4	9.1	13.1	16.2	20.0	24.3	25.6	24.2	18.9	14.9	9.6	(27)
(28)			MCDWB	7.0	8.7	10.8	16.0	19.5	22.6	27.2	28.1	27.5	21.3	16.9	11.7	(28)
(29)		2%	WB	3.5	4.6	7.7	11.4	15.1	19.0	23.4	24.8	23.1	17.3	13.2	7.6	(29)
(30)			MCDWB	5.2	6.5	9.7	14.3	18.1	21.2	25.3	27.4	25.8	19.7	15.4	9.6	(30)
(31)		5%	WB	2.2	3.2	6.4	10.2	14.3	18.2	22.7	24.1	22.0	16.2	11.9	5.6	(31)
(32)			MCDWB	4.0	5.1	8.2	12.6	17.0	20.4	24.6	26.6	24.4	18.8	14.4	7.8	(32)
(33)		10%	WB	0.9	1.9	5.2	9.2	13.4	17.5	21.9	23.4	20.7	15.2	10.5	3.9	(33)
(34)			MCDWB	2.9	3.9	7.2	11.5	16.0	19.7	23.9	25.8	23.4	18.1	13.0	6.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.3	4.5	5.3	6.1	6.1	5.5	4.9	5.3	6.4	6.6	5.6	4.6	(35)
(36)			MCDBR	5.8	6.2	6.9	8.4	8.8	7.5	6.4	6.3	7.0	7.4	7.6	7.0	(36)
(37)			MCWBR	5.5	5.8	5.9	5.7	5.3	4.4	3.7	3.6	4.1	5.2	6.7	6.4	(37)
(38)		5% WB	MCDWB	5.8	6.3	6.6	7.3	7.3	5.8	5.2	5.2	5.8	6.7	7.4	7.0	(38)
(39)			MCWBR	5.7	6.2	6.2	5.5	4.9	3.8	3.2	3.3	4.0	5.5	7.0	6.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.365	0.412	0.484	0.540	0.556	0.526	0.523	0.484	0.427	0.414	0.403	0.384	(40)	
(41)		taud	2.077	1.947	1.850	1.786	1.830	1.987	2.069	2.193	2.305	2.191	2.114	2.056	(41)	
(42)		Ebn at Noon	737	757	747	740	742	766	764	782	805	756	689	670	(42)	
(43)		Edh at Noon	110	147	183	210	206	177	161	138	116	115	107	105	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.22	1.97	3.28	4.54	5.04	4.97	4.37	4.40	3.79	2.78	1.56	1.06	(44)	
(45)		RadStd	0.09	0.20	0.26	0.46	0.48	0.47	0.42	0.39	0.36	0.19	0.15	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page