

KANAZAWA, Japan

WMO: 476050

Lat: 36.5897N

Lon: 136.6347E

Elev: 111

StdP: 14.64

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.8	31.1	19.1	14.4	38.6	21.1	15.9	37.7	32.2	37.8	29.3	38.0	9.2	90	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.5	91.8	76.7	90.0	76.4	88.1	76.0	78.7	87.4	77.9	86.5	77.0	85.6	11.4	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.3	137.9	83.7	75.3	133.2	83.2	74.4	128.9	82.7	42.3	87.5	41.4	86.6	40.6	85.7	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.1	22.4	19.5	26.9	96.6	1.7	1.7	25.7	97.9	24.8	98.9	23.8	99.9	22.6	101.1		
(5)			24.9	80.4	1.5	0.9	23.8	81.1	22.9	81.7	22.0	82.2	20.9	82.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.4	39.0	39.6	45.3	54.9	64.3	71.3	79.2	81.9	74.2	64.2	53.4	44.1
	DBStd	15.56	4.45	4.97	5.88	6.30	5.03	4.30	4.57	3.80	5.13	5.16	5.64	5.33
	HDD50	1053	341	294	171	24	0	0	0	0	0	0	29	194
	HDD65	3586	805	711	611	309	73	3	0	0	1	77	349	647
	CDD50	4480	1	3	25	169	443	638	905	988	726	439	131	12
	CDD65	1539	0	0	0	4	51	191	440	523	278	51	1	0
	CDH74	12939	0	0	1	36	254	857	4094	5766	1775	154	2	0
	CDH80	4367	0	0	0	4	30	148	1434	2268	458	25	0	0
(14) Wind	WSAvg	8.8	10.5	9.7	9.7	9.1	8.2	7.5	7.6	7.5	7.7	8.1	9.3	10.7
(15) Precipitation	PrecAvg	98.3	10.6	7.2	6.2	5.7	5.8	7.3	9.4	6.9	9.6	7.4	10.1	12.1
	PrecMax	130.7	19.2	12.9	11.7	9.0	12.7	16.1	26.9	19.6	24.0	19.2	23.6	24.3
	PrecMin	63.1	5.0	3.7	2.2	1.7	1.9	2.3	1.4	0.2	2.4	1.5	4.4	5.4
	PrecStd	14.7	2.8	2.1	1.8	1.9	2.6	3.2	6.3	4.1	4.9	2.9	3.9	4.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.9	63.5	70.0	78.5	83.6	88.0	94.0	95.1	91.8	83.1	72.4	63.3
		MCWB	49.5	51.9	53.8	59.5	65.2	73.4	76.5	77.1	74.6	69.1	60.2	53.0
	2%	DB	52.1	55.6	64.5	73.3	79.6	83.8	91.2	92.5	88.1	77.6	68.7	58.3
		MCWB	44.4	47.8	51.8	57.9	63.4	70.4	76.4	77.0	74.8	66.4	58.8	50.7
	5%	DB	49.1	51.5	59.5	69.3	76.7	81.1	89.2	90.8	85.0	74.8	65.6	55.5
		MCWB	42.7	44.3	48.9	56.1	61.8	69.4	76.1	77.0	73.9	64.6	57.2	49.2
	10%	DB	46.5	48.1	55.5	66.0	73.9	78.8	87.2	89.1	82.1	72.5	62.9	52.9
		MCWB	41.3	42.1	47.5	54.7	61.2	68.5	75.6	76.7	72.5	63.5	55.7	46.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.3	53.9	56.5	64.9	69.8	75.5	79.3	80.4	77.7	72.0	63.7	56.2
		MCDB	55.6	60.1	65.8	73.3	77.5	83.5	88.3	89.5	86.4	79.5	67.9	59.8
	2%	WB	45.7	48.8	53.1	60.6	66.7	73.7	78.1	79.2	76.2	69.0	61.2	52.3
		MCDB	50.5	54.2	60.4	68.8	74.4	80.6	87.0	87.8	84.4	75.5	66.6	57.1
	5%	WB	43.5	45.4	50.6	58.2	64.6	72.0	77.2	78.4	75.1	67.0	58.6	49.6
		MCDB	48.0	50.4	57.3	66.2	72.5	78.4	86.0	86.9	82.8	72.6	63.8	54.6
	10%	WB	41.5	42.4	48.2	56.2	63.1	70.3	76.4	77.7	73.8	64.9	56.4	47.3
		MCDB	45.9	47.4	54.9	63.2	70.9	76.5	84.8	86.2	80.7	70.8	61.9	52.3
(35) Mean Daily Temperature Range	5% DB	MDBR	9.6	11.2	13.5	14.8	14.3	11.6	10.7	11.5	11.7	12.9	12.7	10.9
		MCDBR	14.2	17.9	21.3	20.9	19.3	15.2	13.7	13.8	14.6	15.5	16.5	15.0
	5% WB	MCWBR	10.0	12.6	13.5	11.1	9.5	7.0	5.6	6.1	6.7	8.1	10.5	10.5
		MCDWR	13.4	16.7	18.1	17.1	15.1	12.4	12.0	12.0	12.8	12.8	14.2	14.0
(40) Clear-Sky Solar Irradiance	taub		0.438	0.468	0.534	0.558	0.558	0.576	0.567	0.543	0.490	0.458	0.441	0.439
		taud	1.916	1.861	1.787	1.801	1.861	1.898	1.983	2.057	2.154	2.129	2.083	1.965
	Ebn at Noon		222	234	232	235	238	233	234	237	243	237	223	212
		Edh at Noon	46	55	65	67	64	62	57	52	44	42	39	42
(44) All-Sky Solar Radiation	RadAvg		496	746	1133	1459	1660	1595	1536	1606	1238	984	646	434
	RadStd		50	73	95	121	182	127	225	170	97	80	57	59

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page