

KANAZAWA, Japan

WMO: 476050

Lat: 36.5897N

Lon: 136.6347E

Elev: 34

StdP: 100.92

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.2	-0.5	-7.2	2.1	3.7	-6.1	2.3	3.2	14.4	3.2	13.1	3.3	4.1	90	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.4	33.2	24.8	32.2	24.7	31.2	24.4	26.0	30.8	25.5	30.3	25.0	29.8	5.1	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.6	19.7	28.7	24.1	19.0	28.4	23.5	18.4	28.2	80.5	30.8	78.5	30.3	76.5	29.9	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.7	10.0	8.7	DB	-2.8	35.9	0.9	1.0	-3.5	36.6	-4.0	37.2	-4.5	37.7	-5.2	38.4	(4)
			WB	-4.0	26.9	0.8	0.5	-4.6	27.3	-5.1	27.6	-5.5	27.9	-6.2	28.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.2	3.9	4.2	7.4	12.7	17.9	21.8	26.2	27.7	23.4	17.9	11.9	6.7
	DBStd	8.64	2.47	2.76	3.27	3.50	2.80	2.39	2.54	2.11	2.85	2.87	3.13	2.96
	HDD10.0	585	189	163	95	13	0	0	0	0	0	16	108	
	HDD18.3	1992	447	395	339	172	41	2	0	0	1	43	194	359
	CDD10.0	2489	1	2	14	94	246	354	503	549	403	244	73	7
	CDD18.3	855	0	0	0	2	28	106	244	291	154	28	1	0
	CDH23.3	7188	0	0	1	20	141	476	2274	3203	986	86	1	0
	CDH26.7	2426	0	0	0	2	17	82	797	1260	254	14	0	0
Wind	WSAvg	3.9	4.7	4.3	4.4	4.1	3.6	3.3	3.4	3.4	3.5	3.6	4.1	4.8
Precipitation	PrecAvg	2497	269	182	158	145	148	185	240	174	244	189	257	308
	PrecMax	3320	488	328	297	229	323	409	682	498	610	487	599	616
	PrecMin	1604	126	95	57	43	48	59	35	5	60	37	112	138
	PrecStd	374	72	53	45	48	65	82	159	105	124	74	100	106
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.4	17.5	21.1	25.8	28.6	31.1	34.4	35.0	33.2	28.4	22.5	17.4
		MCWB	9.7	11.1	12.1	15.3	18.4	23.0	24.7	25.1	23.7	20.6	15.7	11.7
	2%	DB	11.2	13.1	18.1	22.9	26.5	28.8	32.9	33.6	31.2	25.4	20.4	14.6
		MCWB	6.9	8.8	11.0	14.4	17.5	21.4	24.7	25.0	23.8	19.1	14.9	10.4
	5%	DB	9.5	10.8	15.3	20.7	24.8	27.3	31.8	32.7	29.5	23.8	18.7	13.1
		MCWB	6.0	6.8	9.4	13.4	16.6	20.8	24.5	25.0	23.3	18.1	14.0	9.6
	10%	DB	8.0	8.9	13.0	18.9	23.3	26.0	30.7	31.7	27.8	22.5	17.2	11.6
		MCWB	5.2	5.6	8.6	12.6	16.2	20.3	24.2	24.8	22.5	17.5	13.1	8.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	12.2	13.6	18.3	21.0	24.2	26.3	26.9	25.4	22.2	17.6	13.5
		MCDB	13.1	15.6	18.8	23.0	25.3	28.6	31.3	31.9	30.2	26.4	20.0	15.5
	2%	WB	7.6	9.3	11.7	15.9	19.3	23.1	25.6	26.2	24.6	20.6	16.2	11.3
		MCDB	10.3	12.3	15.8	20.5	23.6	27.0	30.6	31.0	29.1	24.2	19.2	13.9
	5%	WB	6.4	7.4	10.4	14.6	18.1	22.2	25.1	25.8	23.9	19.4	14.8	9.8
		MCDB	8.9	10.2	14.1	19.0	22.5	25.8	30.0	30.5	28.2	22.6	17.7	12.5
	10%	WB	5.3	5.8	9.0	13.4	17.3	21.3	24.7	25.4	23.2	18.3	13.6	8.5
		MCDB	7.7	8.5	12.7	17.3	21.6	24.7	29.3	30.1	27.1	21.6	16.6	11.3
Mean Daily Temperature Range	5% DB	MDBR	5.3	6.2	7.5	8.2	7.9	6.4	6.0	6.4	6.5	7.2	7.0	6.0
		MCDBR	7.9	9.9	11.8	11.6	10.7	8.4	7.6	7.7	8.1	8.6	9.2	8.3
		MCWBR	5.5	7.0	7.5	6.1	5.3	3.9	3.1	3.4	3.7	4.5	5.8	5.8
	5% WB	MCDBR	7.4	9.3	10.1	9.5	8.4	6.9	6.7	6.7	7.1	7.1	7.9	7.8
		MCWBR	5.6	7.2	7.2	5.8	4.8	3.4	3.0	3.3	3.5	4.2	5.8	6.0
Clear-Sky Solar Irradiance	taub	0.438	0.468	0.534	0.558	0.558	0.576	0.567	0.543	0.490	0.458	0.441	0.439	
	taud	1.916	1.861	1.787	1.801	1.861	1.898	1.983	2.057	2.154	2.129	2.083	1.965	
	Ebn at Noon	701	737	730	742	750	735	739	747	766	747	703	669	
	Edh at Noon	146	173	205	212	203	196	179	163	140	131	123	131	
All-Sky Solar Radiation	RadAvg	1.56	2.35	3.57	4.60	5.23	5.03	4.84	5.06	3.90	3.10	2.04	1.37	
	RadStd	0.16	0.23	0.30	0.38	0.57	0.40	0.71	0.54	0.30	0.25	0.18	0.19	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (22 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page