

GIFU, Japan

WMO: 476320

Lat: 35.4003N

Lon: 136.7630E

Elev: 17

StdP: 101.12

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.4	-0.5	-9.7	1.7	5.9	-8.4	1.9	5.7	8.5	5.2	7.8	5.6	2.0	290	0.399

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.0	35.4	25.1	34.1	24.8	32.7	24.4	26.2	32.1	25.8	31.3	25.3	30.4	4.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.9	20.0	28.1	24.4	19.4	28.0	24.0	18.9	27.9	81.7	32.1	79.7	31.6	77.8	30.5	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.1	6.2	DB	-3.6	37.2	1.2	1.3	-4.5	38.2	-5.2	38.9	-5.9	39.6	-6.8	40.5	(4)
(5)			WB	-4.6	27.2	1.0	0.5	-5.3	27.5	-5.9	27.8	-6.4	28.1	-7.2	28.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	4.7	5.6	9.1	14.7	19.8	23.5	27.6	29.0	25.0	19.1	12.7	7.2	(6)	
	DBStd	8.77	2.21	2.69	3.04	3.23	2.46	2.28	2.59	2.15	2.77	2.78	3.05	2.84	(7)	
	HDD10.0	452	165	125	54	4	0	0	0	0	0	0	9	95	(8)	
	HDD18.3	1731	423	356	287	114	13	1	0	0	0	23	169	345	(9)	
	CDD10.0	2847	0	3	26	144	303	404	546	590	449	283	91	8	(10)	
	CDD18.3	1085	0	0	0	5	58	154	288	332	199	48	1	0	(11)	
	CDH23.3	10014	0	0	1	35	331	986	3019	3873	1576	193	1	0	(12)	
(13) Wind	CDH26.7	3912	0	0	0	3	62	266	1279	1781	502	21	0	0	(13)	
	WSAvg	2.6	2.5	2.8	3.0	2.9	2.8	2.5	2.6	2.6	2.5	2.3	2.2	2.3	(14)	
	PrecAvg	1776	74	85	125	141	177	210	235	158	247	145	100	78	(15)	
	PrecMax	2199	166	163	230	242	342	374	525	358	509	399	252	127	(16)	
	PrecMin	1188	29	40	40	17	65	80	49	26	61	11	12	14	(17)	
	PrecStd	281	38	33	47	63	65	73	120	89	117	76	58	33	(18)	
	DB	13.3	16.6	20.8	26.6	30.7	33.0	36.8	37.5	34.1	28.7	22.7	17.0	13.3	(19)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	MCWB	7.6	10.1	12.0	15.4	17.9	23.1	25.4	25.6	24.3	20.7	15.5	11.1	7.6	(20)	
	DB	11.6	13.9	18.4	24.1	28.3	30.9	35.2	35.9	32.4	27.0	20.9	15.0	11.1	(21)	
	MCWB	6.4	8.2	11.1	15.0	17.6	21.7	25.2	25.2	23.5	19.1	14.1	9.8	6.4	(22)	
	DB	10.2	12.2	16.6	22.2	26.7	29.5	33.8	34.6	31.0	25.5	19.4	13.4	10.2	(23)	
	MCWB	5.8	7.1	10.0	14.1	17.1	21.1	24.9	25.0	22.9	18.6	13.5	8.9	5.8	(24)	
	DB	8.9	10.6	14.8	20.5	25.1	28.1	32.3	33.4	29.6	24.1	17.9	12.0	8.9	(25)	
	MCWB	4.9	6.2	9.3	13.7	16.7	20.5	24.6	24.8	22.5	17.7	13.1	8.0	4.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	9.7	11.5	14.6	19.8	21.7	25.0	26.9	26.9	25.9	23.5	17.7	13.3	9.7	(27)	
	MCDB	11.2	14.3	16.6	22.0	24.5	29.0	33.8	33.4	29.8	25.5	19.8	15.0	11.2	(28)	
	WB	7.6	9.6	13.1	17.4	20.3	24.0	26.2	26.3	25.1	21.6	16.3	11.1	7.6	(29)	
	MCDB	10.1	12.4	16.3	20.9	24.1	27.9	32.3	32.3	29.0	24.7	18.6	13.4	10.1	(30)	
	WB	6.4	8.0	11.7	16.2	19.2	23.2	25.7	26.0	24.6	20.2	15.2	9.6	6.4	(31)	
	MCDB	9.2	10.8	15.0	19.9	23.6	27.0	31.3	31.7	28.4	23.7	17.7	12.7	9.2	(32)	
	WB	5.4	6.6	10.1	15.0	18.2	22.3	25.2	25.6	24.0	18.9	14.0	8.4	5.4	(33)	
(34) Mean Daily Temperature Range	MCDB	8.4	10.1	13.9	18.9	22.6	26.2	30.2	31.0	27.9	22.6	16.9	11.5	8.4	(34)	
	MDBR	7.4	8.2	9.1	9.6	9.2	7.8	7.3	8.0	7.6	8.3	8.3	7.6	7.4	(35)	
	5% DB	9.2	10.3	11.8	12.3	12.1	10.1	9.3	9.5	9.0	9.7	9.9	9.4	9.2	(36)	
	MCWBR	5.7	6.3	6.7	5.9	5.0	3.8	3.0	2.9	3.3	4.3	5.3	5.8	5.7	(37)	
	5% WB	8.1	8.9	8.8	8.6	8.6	7.4	8.2	8.2	7.1	7.3	7.5	7.9	8.1	(38)	
	MCWBR	5.7	6.4	6.7	5.2	4.8	3.2	3.0	2.8	3.1	4.2	5.1	5.7	5.7	(39)	
	taub	0.396	0.434	0.502	0.542	0.550	0.577	0.565	0.544	0.494	0.456	0.416	0.395	0.396	(40)	
(41) Clear-Sky Solar Irradiance	taud	2.130	2.042	1.902	1.860	1.905	1.910	1.997	2.049	2.153	2.171	2.185	2.157	2.130	(41)	
	Ebn at Noon	771	786	765	759	759	736	742	749	768	758	746	744	771	(42)	
	Edh at Noon	120	147	184	201	195	194	177	165	142	128	113	110	120	(43)	
	RadAvg	2.21	2.93	3.90	4.72	5.22	4.76	4.82	4.97	3.98	3.27	2.45	1.95	2.21	(44)	
(45) All-Sky Solar Radiation	RadStd	0.16	0.23	0.29	0.44	0.57	0.42	0.69	0.47	0.36	0.30	0.21	0.17	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	-0.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page