

GIFU AB, Japan

WMO: 476340

Lat: 35.394N

Lon: 136.869E

Elev: 138

StdP: 14.62

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.3	28.1	14.1	11.3	37.6	16.2	12.5	38.2	20.4	40.3	18.5	41.2	2.8	100	0.382

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.3	94.9	78.2	91.8	77.2	89.7	76.5	79.9	88.7	79.0	87.4	78.2	86.1	8.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.4	143.4	82.4	77.0	141.4	82.3	75.6	134.5	81.8	43.5	89.4	42.6	86.9	41.7	86.1	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.5	16.1	13.8	DB	21.3	97.8	2.2	2.0	19.7	99.3	18.4	100.4	17.2	101.6	15.6	103.0
			WB	19.9	81.8	1.8	1.5	18.5	82.9	17.5	83.8	16.5	84.6	15.1	85.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.1	38.2	40.2	46.6	57.0	66.1	72.9	80.3	82.6	75.5	64.8	52.9	42.9	(6)
	DBStd	16.03	4.30	5.07	5.69	5.98	4.37	3.96	4.35	3.75	5.03	5.15	5.69	5.60	(7)
	HDD50	1054	365	277	137	12	0	0	0	0	0	0	34	229	(8)
	HDD65	3499	830	695	572	246	40	1	0	0	1	67	362	685	(9)
	CDD50	4748	0	3	31	222	499	688	938	1010	766	459	123	9	(10)
	CDD65	1714	0	0	0	6	73	239	473	545	317	61	0	0	(11)
	CDH74	15177	0	0	0	55	510	1465	4618	5941	2337	251	0	0	(12)
	CDH80	5627	0	0	0	4	90	350	1872	2580	707	24	0	0	(13)
(14) Wind	WSAvg	4.9	5.0	5.7	6.3	5.9	5.3	4.6	4.5	4.7	4.5	4.2	4.1	4.6	(14)
(15) Precipitation	PrecAvg	69.9	2.9	3.3	4.9	5.6	7.0	8.3	9.3	6.2	9.7	5.7	3.9	3.1	(15)
	PrecMax	86.6	6.5	6.4	9.1	9.5	13.5	14.7	20.7	14.1	20.0	15.7	9.9	5.0	(16)
	PrecMin	46.8	1.1	1.6	1.6	0.7	2.6	3.1	1.9	1.0	2.4	0.4	0.5	0.6	(17)
	PrecStd	11.1	1.5	1.3	1.9	2.5	2.6	2.9	4.7	3.5	4.6	3.0	2.3	1.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.5	61.1	68.2	79.1	86.2	90.0	97.1	98.5	92.9	82.6	71.7	62.6	(19)
		MCWB	45.7	51.2	53.8	60.6	65.4	74.4	78.5	78.2	77.1	69.3	59.5	54.1	(20)
	2%	DB	52.0	56.9	64.4	75.2	82.4	86.3	94.7	95.2	89.5	79.1	68.4	58.7	(21)
		MCWB	43.4	47.0	51.1	59.9	64.5	71.5	77.9	78.3	75.2	66.9	57.5	49.7	(22)
	5%	DB	49.8	53.4	60.9	71.7	79.1	84.2	91.6	93.2	86.4	76.9	66.1	55.5	(23)
		MCWB	42.4	44.4	49.9	57.6	63.2	70.6	77.0	78.1	74.1	66.1	56.4	47.7	(24)
	10%	DB	46.8	50.2	57.5	68.3	76.8	82.0	89.4	91.2	84.2	73.8	62.8	53.2	(25)
		MCWB	40.0	42.3	48.3	56.5	62.4	69.8	76.5	77.4	72.9	63.8	55.6	46.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.3	53.8	58.8	67.6	71.6	78.1	80.6	81.8	79.6	74.2	63.8	56.3	(27)
		MCDB	51.8	59.1	61.9	71.5	77.0	84.1	91.2	90.5	85.9	78.1	67.2	59.4	(28)
	2%	WB	45.3	49.5	55.5	63.5	68.7	76.0	79.2	80.4	78.2	70.8	61.2	52.2	(29)
		MCDB	49.2	53.3	60.1	69.9	75.5	81.9	89.0	89.4	84.3	75.8	64.8	56.2	(30)
	5%	WB	43.0	46.1	52.6	61.2	66.5	74.4	78.5	79.5	76.8	68.3	59.1	49.2	(31)
		MCDB	47.6	50.2	58.4	68.0	75.0	79.8	87.6	87.9	82.9	73.7	63.7	53.6	(32)
	10%	WB	41.0	43.2	49.8	59.0	64.7	72.5	77.6	78.8	75.5	66.1	57.0	46.7	(33)
		MCDB	46.0	49.1	55.7	65.9	72.9	78.5	85.9	86.7	81.4	72.0	61.5	51.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	16.1	17.4	18.4	19.2	18.4	14.8	14.1	15.3	14.4	16.1	17.1	16.1	(35)
		MCDBR	19.1	21.3	23.0	24.3	23.8	18.9	18.4	18.4	16.9	18.2	19.8	18.7	(36)
	5% WB	MCWBR	12.7	13.8	14.1	12.4	10.7	7.8	6.5	6.2	6.9	8.8	11.4	12.1	(37)
		MCWBR	16.6	17.1	17.7	17.3	17.7	13.6	15.7	15.4	13.6	13.9	15.3	15.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.393	0.432	0.501	0.542	0.550	0.578	0.565	0.545	0.494	0.456	0.415	0.392	(40)
		taud	2.137	2.047	1.903	1.858	1.903	1.906	1.995	2.042	2.150	2.170	2.189	2.165	(41)
	Ebn at Noon		246	250	243	241	241	233	235	237	243	241	237	237	(42)
		Edh at Noon	38	46	58	64	62	62	56	53	45	41	36	35	(43)
(44) All-Sky Solar Radiation	RadAvg		715	944	1247	1503	1660	1507	1532	1578	1264	1039	785	632	(44)
	RadStd		51	72	91	141	181	134	219	149	114	98	67	55	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page