

CHUBU CENTRAIR INTL, Japan

WMO: 476345

Lat: 34.858N

Lon: 136.805E

Elev: 15

StdP: 14.69

Time Zone: 9.00 (E09)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.8	35.6	19.7	14.8	39.8	22.6	17.0	40.3	38.4	41.9	35.1	41.2	15.5	350	0.539

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.2	89.8	79.3	88.0	78.8	86.2	78.1	80.7	86.6	79.9	85.4	79.2	84.4	11.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.0	150.7	85.2	78.5	148.1	84.6	77.2	141.6	83.3	44.5	87.6	43.6	85.6	42.7	85.1	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
33.7	30.1	27.2	30.8	93.3	2.5	1.8	29.0	94.6	27.6	95.7	26.2	96.7	24.3	98.0
			27.2	82.7	1.6	1.6	26.1	83.8	25.1	84.8	24.3	85.7	23.1	86.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.0	42.9	43.7	48.8	57.3	66.1	72.8	79.8	82.5	76.4	67.3	57.1	47.6
	DBStd	14.24	3.51	4.13	4.59	4.78	3.75	3.87	3.72	3.04	4.24	4.29	4.58	4.56
	HDD50	590	221	182	79	4	0	0	0	0	0	3	101	
	HDD65	2852	685	597	503	234	31	1	0	0	24	239	538	
	CDD50	4953	1	5	41	223	499	683	922	1008	793	536	214	28
	CDD65	1740	0	0	0	2	66	234	457	543	343	94	1	0
	CDH74	13583	0	0	0	2	94	838	4085	5956	2424	184	0	0
	CDH80	3755	0	0	0	0	3	120	1118	2051	456	7	0	0
Wind	WSAvg	12.4	15.7	15.1	14.1	12.6	11.5	9.7	9.5	9.9	11.0	11.8	12.8	15.5
Precipitation	PrecAvg	65.9	2.2	2.8	4.4	5.4	6.8	8.2	7.1	5.7	10.8	6.4	3.9	2.2
	PrecMax	87.0	6.6	5.7	8.2	9.2	15.2	11.9	14.3	15.9	21.4	20.2	10.4	4.8
	PrecMin	39.6	0.3	1.1	1.9	1.5	3.2	3.0	1.7	1.0	1.9	0.9	0.3	0.2
	PrecStd	11.5	1.6	1.3	1.6	2.3	3.0	2.5	3.6	3.6	5.0	3.7	2.6	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.0	58.6	64.5	72.0	79.2	87.7	91.5	93.0	89.4	80.7	69.9	62.7
		MCWB	47.0	53.4	54.9	61.9	67.2	77.4	80.2	80.2	79.0	71.9	61.7	57.2
	2%	DB	52.0	54.0	60.9	69.4	76.8	82.8	89.4	90.0	86.2	78.4	67.9	59.1
		MCWB	45.5	48.3	54.0	60.0	66.2	74.2	79.5	79.4	77.2	70.1	60.1	52.9
	5%	DB	50.2	52.1	58.8	66.5	73.8	80.6	87.5	89.2	84.3	75.6	66.2	57.1
		MCWB	44.2	46.5	52.7	59.1	64.3	72.9	78.9	79.1	76.1	68.1	58.8	50.7
	10%	DB	48.5	50.3	55.8	64.5	71.9	78.6	85.8	87.6	82.5	73.7	64.5	55.3
		MCWB	42.6	45.0	49.7	57.8	63.7	71.8	78.0	78.7	75.1	66.3	57.3	49.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.8	54.8	58.5	64.7	70.7	78.5	82.2	82.5	80.3	74.5	65.2	59.1
		MCDB	52.1	57.6	61.6	68.8	75.7	84.5	88.7	88.7	86.3	77.9	67.7	61.4
	2%	WB	46.8	50.7	56.1	62.9	68.6	76.5	80.5	81.0	78.9	72.2	62.2	54.0
		MCDB	50.2	53.0	59.5	67.2	73.3	81.8	86.5	86.8	83.8	76.5	66.0	58.1
	5%	WB	45.1	48.4	53.3	60.8	67.0	74.6	79.7	80.1	77.7	70.0	60.2	51.6
		MCDB	48.9	51.5	57.4	65.1	71.9	79.0	85.2	85.6	82.3	74.4	64.3	55.9
	10%	WB	43.4	45.8	51.1	59.1	65.4	72.6	78.7	79.6	76.5	67.7	58.7	49.8
		MCDB	47.8	49.6	55.1	63.3	70.4	77.0	83.9	84.9	81.0	72.4	63.5	54.6
Mean Daily Temperature Range	5% DB	MDBR	9.1	9.9	11.4	11.9	11.3	8.9	8.6	9.2	9.1	9.5	9.9	9.3
		MCDBR	10.6	12.2	15.0	14.7	13.8	11.2	11.0	10.7	10.2	10.5	11.2	11.0
		MCWBR	7.9	9.2	10.7	9.2	7.9	5.8	5.3	4.9	5.5	6.8	8.1	8.7
	5% WB	MCDBR	9.7	10.1	13.5	12.2	11.3	9.6	10.0	9.7	9.2	8.8	9.3	10.1
MCWBR		8.1	8.8	11.4	8.6	7.5	5.1	5.3	4.9	5.7	7.1	8.3	9.5	
Clear-Sky Solar Irradiance	taub	0.390	0.431	0.493	0.536	0.544	0.568	0.561	0.533	0.494	0.462	0.416	0.389	
	taud	2.197	2.095	1.944	1.888	1.938	1.950	2.020	2.085	2.162	2.171	2.208	2.216	
	Ebn at Noon	250	252	246	243	242	236	237	241	244	240	239	241	
	Edh at Noon	36	44	56	62	60	59	55	50	45	41	36	33	
All-Sky Solar Radiation	RadAvg	780	994	1293	1528	1653	1480	1580	1625	1279	1027	818	700	
	RadStd	52	75	88	151	180	139	214	144	116	106	73	49	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page