

OMAEZAKI, Japan

WMO: 476550

Lat: 34.6047N

Lon: 138.2133E

Elev: 154

StdP: 14.61

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	32.3	34.2	11.8	10.1	38.8	14.9	11.8	39.0	31.1	44.9	29.0	45.1	13.6	290	0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.2	87.0	79.2	85.6	78.6	84.3	77.9	80.8	84.6	79.9	83.6	79.1	82.7	11.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.8	155.3	83.1	78.8	150.5	82.6	78.0	146.1	81.8	44.6	84.9	43.7	83.8	42.8	82.9	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.4	25.0	22.7	28.8	90.2	2.2	2.7	27.3	92.2	26.0	93.7	24.7	95.3	23.1	97.3
			24.0	81.7	1.9	1.3	22.6	82.7	21.5	83.5	20.4	84.2	19.0	85.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.2	44.3	45.4	50.6	58.4	65.7	71.1	77.8	80.8	76.3	68.0	58.4	48.9
	DBStd	13.12	4.32	5.00	5.08	4.72	3.13	3.01	3.55	2.54	3.73	4.17	5.18	5.34
	HDD50	476	183	144	56	3	0	0	0	0	0	3	87	
	HDD65	2589	642	548	447	201	29	1	0	0	18	203	500	
	CDD50	4940	7	16	74	256	486	632	860	955	788	559	255	52
	CDD65	1575	0	0	0	3	50	182	395	490	338	112	5	0
	CDH74	10416	0	0	0	0	23	332	2863	4779	2202	216	1	0
	CDH80	2057	0	0	0	0	0	11	537	1196	307	6	0	0
Wind	WSAvg	10.9	14.3	13.2	12.6	11.2	9.6	8.9	8.8	8.6	9.1	9.9	11.2	13.4
Precipitation	PrecAvg	81.8	3.1	3.9	6.6	7.8	8.5	10.4	8.3	7.4	8.9	8.2	5.5	2.9
	PrecMax	111.5	8.7	11.4	13.2	14.9	18.4	18.8	25.2	19.7	27.3	38.5	13.2	10.2
	PrecMin	46.2	0.0	0.4	0.3	1.3	3.1	3.3	0.7	0.0	1.7	0.9	0.5	0.1
	PrecStd	14.7	2.1	2.6	2.6	3.0	3.5	3.8	5.4	4.1	5.5	5.7	2.9	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.2	62.2	66.1	71.4	76.4	81.4	88.2	89.4	86.8	80.8	72.6	65.8
		MCWB	54.4	58.0	57.4	63.1	67.4	74.9	79.4	80.5	78.1	71.5	65.5	61.2
	2%	DB	56.0	59.0	63.3	69.3	74.3	79.0	86.2	87.5	84.7	78.3	70.0	61.9
		MCWB	49.6	53.1	56.3	62.3	66.3	72.7	78.8	79.7	77.2	70.4	62.8	55.8
	5%	DB	53.9	56.2	61.3	67.6	72.8	77.3	84.6	86.4	83.2	76.3	68.3	59.5
		MCWB	47.0	49.5	55.3	61.2	65.7	71.9	78.1	79.1	76.4	69.4	61.7	52.8
	10%	DB	51.9	53.9	59.4	66.0	71.2	75.9	83.1	85.2	81.8	74.7	66.4	57.5
		MCWB	44.8	47.2	53.4	59.7	64.8	71.0	77.4	78.6	75.6	68.1	59.9	50.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.6	59.5	61.3	67.7	71.2	76.8	81.4	82.4	80.4	75.5	68.4	62.8
		MCDB	58.2	61.2	62.9	68.8	73.5	79.5	85.7	86.1	83.9	77.1	70.2	64.5
	2%	WB	51.6	54.7	59.0	65.0	69.3	75.2	80.0	81.3	79.0	73.4	65.4	57.4
		MCDB	55.1	58.1	61.6	67.8	71.6	77.3	83.9	85.0	82.4	76.2	68.0	60.7
	5%	WB	48.2	51.3	57.0	62.9	67.9	73.7	79.1	80.5	78.0	71.2	63.2	54.2
		MCDB	52.2	54.4	60.2	65.7	70.6	76.0	82.8	84.3	81.4	75.4	66.6	58.1
	10%	WB	45.9	48.7	54.4	61.2	66.5	72.2	78.3	79.8	77.1	69.1	61.1	51.9
		MCDB	50.8	52.8	58.3	64.5	69.7	74.7	81.8	83.5	80.5	73.4	65.3	56.6
Mean Daily Temperature Range	5% DB	MDBR	12.2	13.0	12.9	11.5	10.0	8.1	7.8	8.2	8.6	9.6	11.1	12.0
		MCDBR	13.0	13.3	13.6	12.1	11.3	9.4	9.4	9.2	9.4	10.7	11.7	12.4
		MCWBR	10.8	11.3	11.7	9.5	7.3	5.2	4.4	4.2	5.1	7.3	9.2	10.1
	5% WB	MCDBR	11.2	11.6	12.4	10.0	9.2	7.5	8.6	8.4	8.5	9.5	10.3	11.2
		MCWBR	11.0	11.8	12.6	9.0	7.0	4.8	4.3	4.2	5.1	7.7	10.0	10.7
Clear-Sky Solar Irradiance	taub	0.373	0.421	0.478	0.525	0.535	0.553	0.544	0.528	0.487	0.467	0.412	0.373	
	taud	2.275	2.143	1.995	1.927	1.971	2.000	2.074	2.111	2.196	2.168	2.240	2.292	
	Ebn at Noon	258	257	251	246	245	239	241	243	246	239	241	250	
	Edh at Noon	33	43	53	60	58	56	52	49	43	41	35	31	
All-Sky Solar Radiation	RadAvg	871	1060	1345	1542	1667	1473	1669	1715	1333	1030	842	777	
	RadStd	60	89	86	166	172	148	226	136	116	106	74	55	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	+0.58	+0.88	N/A	N/A	N/A	N/A
Regional (38 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page