

YOKOHAMA, Japan

WMO: 476700

Lat: 35.4397N

Lon: 139.6525E

Elev: 140

StdP: 14.62

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 33.2	(c) 34.7	(d) 7.5	(e) 8.1	(f) 40.7	(g) 10.8	(h) 9.6	(i) 40.5	(j) 23.3	(k) 46.1	(l) 21.0	(m) 46.5	(n) 9.4	(o) 0	(p) 0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.8	91.1	78.3	89.1	77.4	87.3	76.7	79.7	87.7	78.8	86.0	77.9	84.7	9.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.6	144.2	83.9	76.7	140.0	83.2	75.9	135.9	82.6	43.4	88.0	42.4	86.0	41.6	84.9	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.9	18.4	16.1		DB	30.5	94.7	1.4	1.9	29.5	96.1	28.7	97.3	27.9	98.3	26.8	99.7
				WB	24.5	81.0	1.7	1.5	23.2	82.1	22.2	82.9	21.3	83.7	20.0	84.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.8	43.3	44.1	49.7	58.6	66.7	71.9	79.2	81.8	75.4	66.0	56.2	47.8	(6)
	DBStd	13.97	3.74	4.60	5.67	5.74	4.59	4.40	4.82	4.27	5.46	4.96	4.80	4.39	(7)
	HDD50	571	210	175	77	7	0	0	0	0	0	0	5	97	(8)
	HDD65	2818	672	585	474	202	36	4	0	0	2	45	265	533	(9)
	CDD50	4883	3	10	68	263	516	656	904	984	763	497	191	28	(10)
	CDD65	1657	0	0	0	9	87	210	439	519	315	77	1	0	(11)
	CDH74	12753	0	0	0	16	214	845	3896	5401	2171	210	0	0	(12)
	CDH80	3864	0	0	0	0	16	132	1232	1940	523	21	0	0	(13)
(14) Wind	WSAvg	7.8	8.0	8.3	8.8	8.6	8.0	7.1	7.6	7.6	7.5	7.5	7.3	7.6	(14)
(15) Precipitation	PrecAvg	61.7	2.3	2.5	4.4	5.2	5.8	6.7	6.3	5.2	8.3	7.8	4.5	2.7	(15)
	PrecMax	83.0	5.4	5.2	8.0	10.4	11.7	13.2	16.1	14.3	18.3	26.3	11.1	7.7	(16)
	PrecMin	44.2	0.0	0.0	0.9	1.6	2.4	2.3	1.1	0.3	1.2	0.2	0.3	0.3	(17)
	PrecStd	10.0	1.5	1.5	1.9	2.2	2.4	2.4	4.1	3.4	4.3	5.8	2.6	1.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.3	65.1	69.3	76.2	82.1	86.8	92.8	94.2	90.4	82.7	71.7	66.5	(19)
		MCWB	52.6	56.0	56.8	61.5	66.2	73.9	78.2	79.4	76.5	70.4	62.7	58.5	(20)
	2%	DB	55.9	59.6	65.5	72.5	78.5	83.5	90.4	91.8	87.6	78.6	69.0	61.2	(21)
		MCWB	47.1	51.7	55.4	60.0	65.1	71.9	77.8	78.9	75.7	69.1	60.3	51.7	(22)
	5%	DB	52.9	55.3	62.5	69.9	76.3	80.9	88.5	90.0	85.3	76.2	66.7	57.8	(23)
		MCWB	43.5	46.6	53.6	59.7	64.5	70.4	77.2	78.1	75.0	67.7	58.3	49.2	(24)
	10%	DB	50.4	52.1	59.7	67.6	74.1	78.7	86.5	88.2	83.0	73.7	64.4	55.3	(25)
		MCWB	41.3	43.4	51.5	57.9	63.6	69.8	76.4	77.6	74.3	65.4	56.8	47.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.1	58.8	61.0	68.0	71.4	76.5	80.2	81.5	79.1	74.3	66.3	61.4	(27)
		MCDB	58.6	63.3	64.4	70.4	75.5	84.0	89.2	90.5	85.4	78.6	70.1	65.8	(28)
	2%	WB	48.2	52.7	58.0	64.1	69.1	74.6	79.1	80.2	77.8	71.8	62.7	53.9	(29)
		MCDB	53.8	58.5	63.3	69.5	74.6	80.5	87.3	88.3	83.7	76.6	66.9	59.6	(30)
	5%	WB	45.0	47.9	55.4	61.7	67.3	73.0	78.1	79.4	76.8	69.4	60.4	50.5	(31)
		MCDB	51.2	53.6	61.2	67.5	73.0	78.6	85.7	86.8	82.6	74.4	64.9	56.0	(32)
	10%	WB	42.7	44.9	52.2	59.7	65.8	71.5	77.3	78.6	75.8	67.0	58.1	48.1	(33)
		MCDB	49.3	50.8	58.6	65.5	71.6	76.5	84.1	85.4	81.5	72.4	62.8	54.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.3	12.5	13.1	13.2	12.2	10.4	10.5	10.8	10.1	10.4	11.3	11.8	(35)
		MCDBR	15.8	16.7	16.4	15.5	15.0	13.6	12.9	12.7	12.0	12.9	14.0	15.5	(36)
	5% WB	MCWBR	11.4	13.0	11.9	9.2	7.6	6.1	5.0	4.7	5.4	7.7	10.2	11.4	(37)
		MCDWR	14.9	16.1	15.1	13.1	12.9	11.2	12.2	12.0	11.1	11.7	12.7	14.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.381	0.430	0.494	0.543	0.565	0.594	0.586	0.574	0.513	0.485	0.427	0.383	(40)
		taud	2.248	2.107	1.949	1.874	1.880	1.878	1.943	1.964	2.104	2.105	2.184	2.261	(41)
	Ebn at Noon		252	252	245	240	237	229	230	230	238	231	233	243	(42)
		Edh at Noon	34	44	56	63	63	63	59	57	47	43	36	32	(43)
(44) All-Sky Solar Radiation	RadAvg		889	1043	1300	1518	1630	1427	1578	1590	1227	964	799	776	(44)
	RadStd		65	108	84	153	173	137	268	146	111	104	77	62	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+130	N/A
Regional (39 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page