

ATSUGI AB, Japan

WMO: 476790

Lat: 35.455N

Lon: 139.450E

Elev: 65

StdP: 100.54

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 43319

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.9	0.1	-14.1	1.1	4.7	-12.2	1.3	4.4	11.3	6.6	10.2	6.8	2.3	0	0.471

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.4	33.1	25.6	32.1	25.1	31.0	24.8	26.3	30.9	25.9	30.2	25.5	29.6	5.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.4	28.4	24.8	20.0	28.4	24.1	19.1	28.3	82.3	31.1	80.2	30.4	78.2	29.5	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	9.3	8.3	DB	-3.3	35.8	1.5	1.1	-4.4	36.6	-5.2	37.2	-6.1	37.8	-7.1	38.6	(4)
(5)			WB	-5.7	27.5	1.1	0.7	-6.5	28.0	-7.1	28.4	-7.7	28.8	-8.5	29.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	5.6	6.4	9.5	14.7	19.2	22.3	26.4	27.6	24.1	18.9	13.2	8.1	(6)	
	DBStd	8.01	2.15	2.67	3.10	3.29	2.57	2.48	2.71	2.32	3.01	2.82	2.83	2.63	(7)	
	HDD10.0	371	137	106	48	4	0	0	0	0	0	0	5	71	(8)	
	HDD18.3	1641	393	334	274	116	21	2	0	0	1	27	156	317	(9)	
	CDD10.0	2703	1	5	33	144	286	369	507	547	424	275	99	12	(10)	
	CDD18.3	932	0	0	0	6	48	122	249	289	176	43	1	0	(11)	
	CDH23.3	7481	0	0	0	18	167	556	2276	3034	1276	153	1	0	(12)	
	CDH26.7	2403	0	0	0	1	17	107	788	1128	342	20	0	0	(13)	
(14) Wind	WSAvg	3.9	3.6	3.9	4.4	4.5	4.2	3.7	3.8	3.8	3.9	3.9	3.6	3.4	(14)	
(15) Precipitation	PrecAvg	1688	66	72	121	134	155	190	184	162	234	194	109	67	(15)	
	PrecMax	2283	146	153	232	262	304	298	410	431	447	718	264	163	(16)	
	PrecMin	1138	0	5	31	50	60	87	24	14	44	12	3	7	(17)	
	PrecStd	281	41	40	51	57	62	55	103	100	114	142	66	40	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.0	19.0	20.9	25.2	28.8	31.2	34.9	35.1	33.0	29.0	22.9	19.1	(19)	
		MCWB	10.9	12.9	13.5	16.5	19.0	23.5	25.7	26.3	24.5	20.8	16.7	13.6	(20)	
	2%	DB	13.2	15.9	18.8	23.1	26.8	29.2	33.0	33.8	31.2	26.4	21.1	16.2	(21)	
		MCWB	7.8	11.2	12.1	15.6	18.5	22.1	25.5	25.9	24.2	20.0	15.5	10.5	(22)	
	5%	DB	11.9	13.2	17.0	21.8	25.1	27.9	31.9	32.2	30.0	25.0	19.8	14.2	(23)	
		MCWB	6.3	7.7	11.6	15.1	17.9	21.5	25.2	25.3	23.6	19.3	14.3	8.9	(24)	
	10%	DB	10.2	11.2	15.2	20.1	23.9	26.2	30.8	31.2	28.8	23.8	18.1	13.0	(25)	
		MCWB	4.8	6.0	10.2	14.3	17.5	20.8	24.8	25.1	23.1	18.3	13.2	7.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	14.5	15.4	19.7	22.0	24.7	26.7	27.2	26.2	23.3	18.6	15.4	(27)	
		MCDB	15.0	17.7	17.8	21.9	24.9	29.4	32.2	32.3	29.7	26.2	21.0	17.9	(28)	
	2%	WB	8.9	11.2	13.9	17.5	20.4	23.6	26.1	26.6	25.5	21.7	16.8	11.7	(29)	
		MCDB	12.5	15.2	17.2	21.4	24.1	27.7	31.1	31.2	28.9	25.1	19.6	15.3	(30)	
	5%	WB	6.8	8.6	12.6	16.1	19.4	22.7	25.7	26.1	24.8	20.3	15.4	9.9	(31)	
		MCDB	10.8	12.2	16.3	20.0	23.3	26.3	30.3	30.4	28.3	23.9	18.2	13.3	(32)	
	10%	WB	5.5	6.8	10.7	15.2	18.5	21.8	25.2	25.7	24.2	19.0	14.0	8.5	(33)	
		MCDB	9.5	10.6	14.7	18.9	22.4	25.2	29.5	29.8	27.6	22.8	17.2	12.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.7	8.4	8.4	8.3	7.6	6.3	6.3	6.4	6.5	6.8	7.6	8.4	(35)	
		MCDBR	10.8	11.1	10.5	10.0	9.6	8.4	7.9	7.6	7.8	8.4	9.5	10.2	(36)	
	5% WB	MCWBR	7.3	7.9	7.4	5.8	4.8	3.7	3.3	3.1	3.6	4.7	6.0	6.9	(37)	
		MCWBR	9.8	10.1	9.3	8.2	7.9	6.9	7.2	6.8	6.9	7.4	8.0	9.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.377	0.426	0.490	0.540	0.564	0.596	0.587	0.578	0.515	0.484	0.423	0.379	(40)	
		taud	2.254	2.115	1.959	1.880	1.880	1.870	1.939	1.953	2.094	2.102	2.194	2.274	(41)	
	Ebn at Noon		800	797	777	760	748	722	725	722	748	729	740	772	(42)	
		Edh at Noon	106	136	173	197	200	202	187	181	150	137	112	99	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.84	3.34	4.14	4.82	5.16	4.50	4.94	4.97	3.86	3.07	2.55	2.47	(44)	
	RadStd		0.20	0.34	0.26	0.48	0.55	0.43	0.84	0.46	0.35	0.34	0.25	0.20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page