

TOTTORI, Japan

WMO: 477460

Lat: 35.4878N

Lon: 134.2383E

Elev: 16

StdP: 101.13

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.4	-0.5	-6.7	2.1	3.9	-5.4	2.4	4.1	10.2	4.3	9.2	4.1	3.6	110	0.423

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.4	34.4	25.4	33.2	25.0	32.0	24.7	26.2	32.0	25.7	31.2	25.2	30.4	4.3	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.8	19.8	28.8	24.2	19.2	28.5	23.7	18.6	28.2	81.7	32.1	79.6	31.4	77.5	30.7	28.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.9	7.6	6.6	-3.2	36.5	1.3	0.9	-4.2	37.1	-4.9	37.7	-5.7	38.2	-6.6	38.9
			-4.2	27.1	1.3	0.6	-5.1	27.5	-5.9	27.9	-6.7	28.2	-7.7	28.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.5	4.3	4.8	7.9	13.2	18.3	22.3	26.7	27.9	23.2	17.7	12.1	6.9
	DBStd	8.56	2.41	2.81	3.33	3.51	2.81	2.51	2.57	2.25	2.90	2.78	3.04	2.96
	HDD10.0	534	178	148	83	10	0	0	0	0	0	0	13	103
	HDD18.3	1919	435	378	322	158	36	1	0	0	1	46	188	354
	CDD10.0	2540	1	3	19	105	257	368	517	553	397	238	76	7
	CDD18.3	884	0	0	0	3	34	119	259	295	148	24	1	0
	CDH23.3	7854	0	0	0	28	243	711	2519	3205	1033	112	1	0
	CDH26.7	2971	0	0	0	3	38	163	1016	1429	306	15	0	0
Wind	WSAvg	3.0	3.2	3.2	3.4	3.4	3.2	2.7	2.8	2.8	2.6	2.7	3.0	3.2
Precipitation	PrecAvg	1758	161	124	129	105	138	156	195	128	203	132	129	160
	PrecMax	2177	298	201	210	176	344	283	431	349	451	296	247	279
	PrecMin	1329	100	77	57	38	48	67	21	32	64	41	56	74
	PrecStd	183	50	34	38	42	66	51	98	70	110	64	49	49
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.6	18.3	21.5	26.3	29.7	32.0	35.6	36.3	33.6	28.5	22.7	17.8
		MCWB	10.7	13.7	12.9	15.4	18.3	22.3	25.7	25.7	24.7	21.9	16.2	13.0
	2%	DB	11.9	14.4	18.5	23.6	27.7	30.0	34.0	35.0	31.6	26.0	20.8	15.2
		MCWB	7.7	9.8	11.6	14.9	17.6	21.7	25.3	25.5	24.2	19.9	15.5	11.0
	5%	DB	10.3	12.0	16.5	21.8	26.1	28.5	32.7	33.9	29.9	24.3	19.3	13.7
		MCWB	6.6	7.9	10.9	14.3	17.0	21.3	25.0	25.3	23.5	18.8	14.7	9.7
	10%	DB	8.6	10.1	14.6	19.9	24.4	27.2	31.5	32.7	28.4	22.9	17.7	12.2
		MCWB	5.5	6.7	10.1	13.6	16.7	20.8	24.7	25.0	22.7	17.8	13.7	8.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.1	13.8	14.7	18.9	21.2	24.4	26.7	27.2	25.8	22.9	18.2	14.3
		MCDB	13.8	17.5	18.2	22.2	25.1	29.0	32.8	33.1	30.8	27.3	20.5	16.2
	2%	WB	8.6	10.5	13.1	16.7	19.9	23.6	26.1	26.5	24.9	21.3	16.7	12.0
		MCDB	11.3	13.5	16.5	21.3	23.8	27.7	31.8	32.4	29.7	24.6	19.5	14.2
	5%	WB	7.0	8.6	11.7	15.5	18.8	22.9	25.6	26.0	24.2	20.0	15.5	10.3
		MCDB	9.4	11.2	15.3	19.9	23.2	26.6	31.0	31.8	28.4	22.9	18.4	12.9
	10%	WB	5.8	6.9	10.3	14.5	17.9	22.0	25.1	25.6	23.6	18.7	14.3	8.9
		MCDB	8.3	9.7	14.2	18.7	22.6	25.7	30.3	31.0	27.4	21.6	17.2	11.7
Mean Daily Temperature Range	5% DB	MDBR	6.4	7.4	9.2	10.4	10.1	8.1	7.6	8.4	8.0	8.8	8.3	7.0
		MCDBR	9.3	11.6	12.8	13.4	13.4	10.4	9.5	10.0	9.5	10.4	10.5	9.8
		MCWBR	6.2	7.7	7.8	6.8	5.8	4.3	3.4	3.5	3.9	5.3	6.1	6.3
	5% WB	MCDBR	8.6	10.0	10.6	10.0	9.5	7.4	8.7	9.0	8.0	8.0	8.6	8.8
MCWBR		6.2	7.4	7.4	5.8	5.2	3.4	3.4	3.5	3.5	4.6	5.8	6.5	
Clear-Sky Solar Irradiance	taub	0.439	0.474	0.541	0.562	0.561	0.583	0.582	0.549	0.500	0.459	0.439	0.431	
	taud	1.999	1.935	1.804	1.811	1.870	1.890	1.952	2.037	2.127	2.138	2.095	2.041	
	Ebn at Noon	717	743	730	742	750	732	729	745	761	754	717	696	
	Edh at Noon	137	163	203	211	202	198	185	167	145	132	124	124	
All-Sky Solar Radiation	RadAvg	1.70	2.42	3.51	4.66	5.16	4.77	4.73	4.92	3.80	3.08	2.12	1.57	
	RadStd	0.14	0.26	0.32	0.41	0.50	0.37	0.71	0.56	0.35	0.28	0.18	0.14	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	+0.42	N/A	N/A	N/A	N/A
Regional (28 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page