

NARA, Japan

WMO: 477800

Lat: 34.6737N

Lon: 135.8380E

Elev: 358

StdP: 14.51

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 28.3	(c) 29.7	(d) 16.4	(e) 12.8	(f) 37.4	(g) 19.5	(h) 14.8	(i) 39.1	(j) 12.1	(k) 41.0	(l) 10.9	(m) 41.4	(n) 2.8	(o) 50	(p) 0.352

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 16.4	(c) 93.6	(d) 77.1	(e) 91.8	(f) 76.7	(g) 89.7	(h) 76.2	(i) 78.9	(j) 89.5	(k) 78.1	(l) 88.0	(m) 77.2	(n) 86.5	(o) 5.0	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.3	139.1	82.8	75.4	134.8	82.3	74.6	131.0	81.8	42.7	89.7	41.8	88.3	41.0	86.8	82.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 11.4	(b) 9.4	(c) 7.8	(e) 25.2	(f) 96.6	(g) 1.3	(h) 2.0	(i) 24.2	(j) 98.1	(k) 23.4	(l) 99.2	(m) 22.7	(n) 100.3	(o) 21.7	(p) 101.8		
(a) 23.2	(b) 80.9	(c) 1.9	(e) 23.2	(f) 80.9	(g) 1.9	(h) 1.0	(i) 21.8	(j) 81.6	(k) 20.7	(l) 82.2	(m) 19.6	(n) 82.7	(o) 18.2	(p) 83.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.1	39.7	40.8	46.7	56.7	65.8	72.4	80.1	82.2	74.7	63.9	52.9	43.9
	DBStd	15.48	3.69	4.76	5.68	6.15	4.57	4.26	4.12	3.44	5.22	5.29	5.42	4.57
	HDD50	961	319	263	138	14	0	0	0	0	0	0	30	197
	HDD65	3434	784	679	568	255	45	1	0	0	2	83	363	654
	CDD50	4649	1	4	35	215	490	672	933	999	742	432	118	8
	CDD65	1645	0	0	0	6	70	223	468	534	294	50	0	0
	CDH74	14502	0	0	0	76	533	1423	4502	5672	2079	216	1	0
	CDH80	5469	0	0	0	5	86	364	1831	2506	654	23	0	0
	WSAvg	3.3	3.6	3.6	3.9	3.7	3.3	3.1	3.1	3.3	3.0	2.8	2.6	3.3
	PrecAvg	58.0	2.1	2.7	4.3	4.2	5.9	7.8	7.0	5.5	7.7	5.1	3.5	2.3
(15) Precipitation	PrecMax	73.1	4.9	5.6	7.4	8.9	14.7	14.5	15.7	14.8	16.9	11.8	8.7	4.4
	PrecMin	35.6	0.2	0.7	2.1	1.5	2.2	3.3	2.2	0.7	2.0	1.0	0.6	0.1
	PrecStd	9.4	1.2	1.3	1.5	1.7	3.1	2.8	3.6	3.1	3.5	2.4	2.0	1.2
	PrecStd	9.4	1.2	1.3	1.5	1.7	3.1	2.8	3.6	3.1	3.5	2.4	2.0	1.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.7	63.0	70.5	80.1	85.9	90.6	95.8	96.8	92.3	82.8	71.6	61.7
		MCWB	49.0	53.1	55.5	61.4	65.5	74.5	78.1	77.6	76.3	70.9	61.2	54.6
	2%	DB	52.4	57.3	65.9	76.1	82.4	86.6	93.2	94.5	89.0	79.0	68.1	57.8
		MCWB	45.2	48.4	52.7	58.9	64.6	71.8	77.1	77.1	75.2	68.2	59.0	51.1
	5%	DB	49.9	53.4	61.8	72.3	79.5	84.1	91.2	92.7	86.5	76.3	65.3	55.1
		MCWB	43.3	45.6	50.9	57.5	63.1	70.1	76.8	76.9	73.8	65.9	58.1	48.7
	10%	DB	47.5	50.2	58.1	68.9	76.8	81.6	89.1	90.7	83.9	73.4	62.6	52.7
		MCWB	41.5	44.1	49.7	56.5	62.3	69.5	76.1	76.5	72.6	64.5	56.8	47.0
	0.4%	WB	51.7	55.6	59.3	67.1	71.3	76.9	80.0	80.3	78.3	73.7	64.4	57.3
		MCDB	54.3	61.0	63.8	71.5	78.5	86.6	91.1	91.1	87.5	79.4	67.2	60.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	47.0	50.9	56.2	63.4	68.8	75.0	78.8	79.2	77.0	70.7	62.0	53.1
		MCDB	50.1	54.5	61.8	70.0	75.0	82.1	89.4	89.8	85.4	76.4	65.2	56.1
	5%	WB	44.4	47.5	53.4	60.9	66.7	73.7	77.9	78.3	75.7	68.4	59.9	50.0
		MCDB	48.4	51.3	59.0	68.3	74.0	80.1	87.8	88.5	83.0	73.5	63.8	53.6
	10%	WB	42.2	44.6	50.7	58.5	64.9	72.1	77.0	77.5	74.5	66.0	57.6	47.6
		MCDB	46.7	49.5	56.9	65.9	72.6	78.3	86.3	87.2	81.0	71.1	61.7	51.7
(35) Mean Daily Temperature Range	5% DB	MDBR	14.3	15.9	18.7	20.3	19.5	15.7	15.0	16.4	15.4	16.4	16.3	14.8
		MCDBR	18.3	22.1	24.9	25.9	24.7	20.1	18.3	19.0	17.9	18.9	18.7	18.2
		MCWBR	12.0	13.8	14.2	12.2	10.5	7.9	6.4	6.2	7.1	9.4	11.3	12.0
	5% WB	MCDBR	16.3	18.1	20.1	19.0	17.5	14.7	16.5	16.6	15.2	15.1	15.3	15.6
		MCWBR	12.2	13.5	14.0	11.7	10.0	7.0	6.4	6.1	6.7	8.8	10.8	12.1
(40) Clear-Sky Solar Irradiance	taub		0.402	0.442	0.502	0.536	0.541	0.560	0.562	0.529	0.486	0.448	0.417	0.397
	taud		2.146	2.049	1.909	1.877	1.931	1.955	2.002	2.083	2.171	2.194	2.189	2.173
	Ebn at Noon		245	248	244	243	243	238	236	242	246	245	239	238
	Edh at Noon		38	47	58	63	60	59	56	51	44	40	36	35
	RadAvg		731	937	1248	1510	1644	1478	1575	1614	1270	1024	793	663
(45) All-Sky Solar Radiation	RadStd		51	74	93	138	174	140	207	141	110	103	68	43

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page