

OZUKI AB, Japan

WMO: 477870

Lat: 34.047N

Lon: 131.052E

Elev: 7

StdP: 101.24

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.2	0.8	-8.1	1.9	3.3	-6.9	2.1	3.9	13.2	5.4	12.1	5.6	3.7	0	0.451

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.2	32.9	26.1	31.9	25.9	30.9	25.9	27.1	30.8	26.6	30.1	26.2	29.5	5.2	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.5	29.7	25.8	21.1	29.4	25.1	20.2	28.6	85.9	31.2	83.7	30.4	81.6	29.8	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.4	9.8	8.5	-2.7	34.3	1.2	1.0	-3.6	35.1	-4.3	35.6	-4.9	36.2	-5.7	36.9		
			-3.9	28.2	1.1	0.6	-4.7	28.6	-5.3	29.0	-5.9	29.3	-6.7	29.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.2	5.7	6.3	9.1	14.0	18.8	22.4	26.5	27.9	24.0	18.6	12.9	7.9	(6)
(7)		DBStd	8.03	2.30	2.63	2.85	2.88	2.19	1.93	2.21	1.83	2.56	2.69	3.06	2.79	(7)
(8)		HDD10.0	382	135	108	51	4	0	0	0	0	0	7	76	(8)	
(9)		HDD18.3	1683	392	338	286	131	21	0	0	0	29	163	322	(9)	
(10)		CDD10.0	2659	1	4	24	125	272	372	513	554	421	266	96	12	(10)
(11)		CDD18.3	917	0	0	0	2	34	122	254	296	171	37	1	0	(11)
(12)		CDH23.3	7438	0	0	0	8	114	482	2351	3207	1172	103	0	0	(12)
(13)		CDH26.7	2263	0	0	0	0	7	60	748	1190	253	4	0	0	(13)
(14)	Wind	WSAvg	3.7	4.0	3.8	4.1	4.0	3.8	3.4	3.4	3.7	3.6	3.5	3.5	4.0	(14)
(15)	Precipitation	PrecAvg	1777	83	83	126	144	173	251	296	184	175	91	93	78	(15)
(16)		PrecMax	2422	183	132	247	298	364	458	671	521	399	218	209	149	(16)
(17)		PrecMin	1203	28	26	62	47	54	54	49	37	50	11	29	14	(17)
(18)		PrecStd	321	38	27	50	62	72	112	184	112	87	58	49	34	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.0	16.1	19.8	24.2	27.8	30.0	33.8	34.2	31.9	27.1	22.0	17.1	(19)
(20)			MCWB	11.0	13.3	14.8	16.6	18.7	24.5	26.3	26.6	25.6	22.5	17.7	13.7	(20)
(21)		2%	DB	12.2	13.9	17.1	21.9	25.9	28.1	32.2	33.1	30.2	25.8	20.2	15.8	(21)
(22)			MCWB	9.1	10.6	12.6	15.7	17.9	22.8	25.9	26.2	25.1	21.8	16.8	12.5	(22)
(23)		5%	DB	11.1	12.2	15.8	20.2	24.8	27.1	31.2	32.2	29.1	24.2	19.2	14.1	(23)
(24)			MCWB	8.1	9.3	11.9	15.4	18.0	22.3	26.0	26.0	24.4	20.0	15.9	10.9	(24)
(25)		10%	DB	10.1	11.1	14.2	18.9	23.1	26.0	30.2	31.2	28.0	23.1	18.1	13.0	(25)
(26)			MCWB	7.1	8.3	10.8	14.7	17.6	21.8	25.7	26.0	23.8	18.9	15.0	10.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.3	14.3	16.0	19.7	21.9	25.6	27.6	28.0	26.7	24.4	19.5	15.2	(27)
(28)			MCDWB	13.3	16.0	17.8	22.0	23.8	28.2	31.1	31.8	29.9	26.1	20.9	16.3	(28)
(29)		2%	WB	10.4	11.8	14.0	17.7	20.6	24.6	26.9	27.3	26.1	22.7	18.2	13.0	(29)
(30)			MCDWB	11.7	13.1	16.1	20.3	23.0	27.0	30.5	31.1	29.1	24.8	19.8	14.8	(30)
(31)		5%	WB	8.8	10.3	12.7	16.4	19.6	23.7	26.5	26.9	25.4	21.1	16.8	11.7	(31)
(32)			MCDWB	10.4	11.7	15.0	19.0	22.6	25.8	29.9	30.5	28.1	23.7	18.7	13.6	(32)
(33)		10%	WB	7.5	8.9	11.4	15.5	18.7	22.9	26.1	26.5	24.7	19.7	15.6	10.4	(33)
(34)			MCDWB	9.5	10.5	13.9	17.9	21.9	24.9	29.3	30.0	27.3	22.4	17.8	12.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.8	7.3	8.0	8.3	8.1	6.2	5.7	6.2	6.4	7.6	7.6	7.3	(35)
(36)			MCDBR	8.3	8.9	10.0	10.5	10.5	8.0	7.2	7.2	7.0	8.0	8.0	8.6	(36)
(37)			MCWBR	6.1	6.7	6.8	6.2	5.7	4.2	3.2	3.1	3.4	4.7	5.5	6.4	(37)
(38)		5% WB	MCDWB	7.4	7.7	8.3	8.0	7.7	5.5	6.4	6.5	5.9	6.5	6.7	7.8	(38)
(39)			MCWBR	6.5	6.9	6.6	5.6	5.0	3.5	3.2	3.2	3.3	4.6	5.5	6.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.431	0.472	0.536	0.559	0.562	0.576	0.575	0.536	0.503	0.458	0.432	0.423	(40)	
(41)		taud	2.055	1.979	1.832	1.830	1.882	1.932	1.982	2.093	2.134	2.154	2.139	2.088	(41)	
(42)		Ebn at Noon	742	756	741	748	751	738	736	759	764	764	738	723	(42)	
(43)		Edh at Noon	133	159	199	209	200	190	180	159	146	132	121	122	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.12	2.85	3.94	4.81	5.27	4.57	4.90	5.13	4.06	3.42	2.52	1.97	(44)	
(45)		RadStd	0.19	0.28	0.29	0.41	0.60	0.48	0.74	0.57	0.41	0.35	0.23	0.13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+0.42	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page