

KYUSHU SAGA INTL, Japan

WMO: 478100

Lat: 33.150N

Lon: 130.302E

Elev: 5

StdP: 101.27

Time Zone: 9.00 (E09)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.1	-1.0	-7.1	2.1	2.6	-6.0	2.3	2.5	10.3	5.6	9.4	5.8	2.3	10	0.444

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.9	33.8	26.6	32.8	26.3	31.2	26.0	27.6	31.2	27.0	30.6	26.6	30.0	3.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.7	29.8	26.1	21.5	29.6	25.8	21.1	29.3	87.6	31.7	85.4	31.2	83.4	30.0	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.8	8.6	7.6	-4.9	35.1	1.0	0.4	-5.6	35.4	-6.2	35.6	-6.8	35.8	-7.5	36.1	
			DB												
			WB	-5.7	28.5	0.9	0.5	-6.3	28.9	-6.8	29.2	-7.3	29.5	-7.9	29.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.5	5.1	6.5	9.7	14.4	19.4	23.2	27.4	28.4	24.5	18.9	12.8	7.2	(6)
(7)		DBStd	8.41	2.46	3.13	3.11	2.81	2.24	1.93	2.02	1.75	2.42	2.70	3.32	3.06	(7)
(8)		HDD10.0	414	153	105	44	2	0	0	0	0	0	11	98		(8)
(9)		HDD18.3	1684	411	331	268	121	14	0	0	0	25	168	346		(9)
(10)		CDD10.0	2792	1	8	34	133	291	397	539	571	436	276	94	11	(10)
(11)		CDD18.3	1020	0	0	0	2	47	147	281	313	186	43	2	0	(11)
(12)		CDH23.3	9012	0	0	0	5	207	748	2872	3563	1409	206	1	0	(12)
(13)		CDH26.7	2976	0	0	0	0	22	108	980	1457	394	14	0	0	(13)
(14)	Wind	WSAvg	3.4	3.1	3.5	3.7	3.6	3.5	3.5	3.9	3.5	3.3	3.4	3.0	3.2	(14)
(15)	Precipitation	PrecAvg	1933	64	82	125	156	180	335	331	226	176	91	99	67	(15)
(16)		PrecMax	2645	179	157	280	310	365	546	629	599	547	198	198	143	(16)
(17)		PrecMin	1022	25	30	63	58	54	49	27	51	71	10	15	6	(17)
(18)		PrecStd	361	33	36	45	65	78	145	169	133	105	59	50	35	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.1	17.2	20.2	24.1	28.9	30.2	34.2	35.2	33.0	28.1	22.2	17.2	(19)
MCWB			11.7	13.6	15.5	16.6	19.7	23.6	26.7	26.7	25.7	22.1	17.8	13.4	(20)	
2%		DB	12.2	15.2	18.2	22.2	27.0	29.0	33.1	34.1	31.2	26.9	21.1	15.2	(21)	
		MCWB	9.4	12.1	13.8	16.2	19.4	23.1	26.4	26.7	24.8	21.4	16.7	12.2	(22)	
5%		DB	11.1	13.9	16.9	21.0	25.8	28.0	32.1	33.1	30.1	25.9	20.1	14.0	(23)	
		MCWB	8.1	11.1	13.5	16.0	18.9	22.7	26.2	26.5	24.4	20.3	16.3	11.0	(24)	
10%		DB	10.0	12.1	15.2	19.9	24.1	27.0	31.0	32.1	29.0	24.2	18.9	12.8	(25)	
		MCWB	7.2	9.2	12.1	15.5	18.7	22.9	26.3	26.2	23.8	19.1	15.5	10.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.7	15.3	16.8	19.5	22.6	26.3	28.2	28.4	26.8	24.7	19.7	15.2	(27)
MCDWB			13.6	16.3	18.9	21.7	25.0	28.4	31.6	32.3	30.5	26.8	21.4	16.0	(28)	
2%		WB	10.8	13.2	15.2	18.3	21.5	25.5	27.5	27.7	26.2	23.3	18.4	13.0	(29)	
		MCDWB	12.1	14.9	17.4	20.6	24.1	27.3	30.8	31.6	29.5	25.6	20.2	14.7	(30)	
5%		WB	8.9	11.5	14.0	17.3	20.6	24.7	27.0	27.2	25.5	21.6	17.2	11.7	(31)	
		MCDWB	10.4	13.3	16.3	19.6	23.4	26.4	30.2	31.1	28.8	24.2	19.3	13.6	(32)	
10%		WB	7.5	9.9	12.7	16.3	19.8	23.7	26.6	26.7	24.9	20.0	15.7	10.4	(33)	
		MCDWB	9.5	11.6	15.1	18.8	22.9	25.6	29.6	30.5	27.9	22.8	18.1	12.2	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.4	8.4	9.0	9.5	9.4	6.5	5.6	6.9	7.9	9.4	9.3	8.5	(35)
MCDBR			9.7	9.9	10.7	11.1	11.5	8.5	7.8	8.5	9.2	10.6	9.9	9.7	(36)	
MCWBR			7.1	7.5	7.5	7.0	6.2	4.3	3.7	3.7	4.3	5.6	6.3	7.2	(37)	
5% WB		MCDBR	8.2	8.7	8.4	8.3	8.5	4.7	6.2	7.1	7.1	6.9	7.5	8.2	(38)	
		MCWBR	7.1	7.6	6.9	6.2	5.5	3.2	3.3	3.5	3.8	4.6	5.8	6.8	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.439	0.481	0.543	0.562	0.572	0.584	0.573	0.544	0.514	0.466	0.436	0.431	(40)	
taud		2.031	1.959	1.814	1.821	1.858	1.911	1.982	2.055	2.092	2.127	2.124	2.069	(41)		
Ebn at Noon		740	752	738	748	745	734	739	754	757	760	741	722	(42)		
Edh at Noon		138	164	204	211	205	194	180	165	153	137	125	126	(43)		
(44)	All-Sky Solar Radiation	RadAvg	2.21	2.93	4.00	4.81	5.17	4.35	4.92	5.16	4.20	3.55	2.62	2.06	(44)	
(45)		RadStd	0.22	0.28	0.26	0.41	0.59	0.60	0.70	0.52	0.44	0.37	0.25	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47)	Regional (30 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page