

HITA, Japan

WMO: 478140

Lat: 33.3217N

Lon: 130.9292E

Elev: 277

StdP: 14.55

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 26.0	(c) 27.8	(d) 17.7	(e) 13.5	(f) 40.9	(g) 20.4	(h) 15.4	(i) 38.7	(j) 16.0	(k) 40.6	(l) 14.3	(m) 41.7	(n) 2.0	(o) 30	(p) 0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 17.4	(c) 95.4	(d) 77.5	(e) 93.5	(f) 76.9	(g) 91.3	(h) 76.1	(i) 79.6	(j) 89.8	(k) 78.5	(l) 88.3	(m) 77.7	(n) 86.9	(o) 8.0	(p) 280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.3	143.3	82.6	76.2	138.3	82.1	75.3	133.8	81.7	43.4	89.9	42.3	88.3	41.4	87.2	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.1	12.1	10.7	21.8	98.4	2.2	1.7	20.3	99.7	19.0	100.7	17.8	101.7	16.2	102.9
			20.9	80.8	2.2	1.4	19.4	81.7	18.1	82.5	16.9	83.3	15.3	84.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.4	40.3	42.9	49.0	58.5	67.6	74.2	81.5	82.8	75.7	65.1	53.9	43.9
	DBStd	15.58	4.81	5.91	5.98	6.03	4.34	4.08	3.87	3.23	5.01	5.47	6.34	5.66
	HDD50	850	304	213	92	8	0	0	0	0	0	0	30	203
	HDD65	3162	767	620	495	205	23	0	0	0	0	65	334	653
	CDD50	5010	3	14	61	264	547	725	976	1017	772	468	148	15
	CDD65	1847	0	0	0	11	105	275	511	552	322	68	3	0
	CDH74	16974	0	0	5	166	1001	1966	5157	5811	2436	419	13	0
	CDH80	6824	0	0	0	20	252	626	2311	2678	873	64	0	0
(14) Wind	WSAvg	3.8	3.5	3.8	4.3	4.4	4.2	3.9	4.0	4.1	3.6	3.4	3.1	3.4
(15) Precipitation	PrecAvg	73.2	2.7	3.2	4.7	5.3	6.4	13.7	13.3	7.6	6.7	3.3	3.6	2.6
	PrecMax	105.4	8.0	6.2	12.5	9.0	12.3	24.3	29.2	17.6	20.4	8.0	6.8	4.9
	PrecMin	40.8	0.7	1.2	2.2	1.3	1.7	1.9	1.9	2.2	1.9	0.6	1.1	0.2
	PrecStd	14.6	1.5	1.3	2.1	2.3	3.0	6.3	7.5	3.9	4.6	2.1	1.9	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.4	67.9	73.9	83.0	89.1	91.6	97.6	98.2	94.2	85.1	76.1	64.4
		MCWB	51.8	56.4	57.9	63.3	66.2	72.2	78.1	78.0	76.3	70.9	63.5	55.8
	2%	DB	55.7	62.4	69.5	78.5	85.5	88.8	95.3	95.9	90.9	81.5	71.6	60.4
		MCWB	48.0	53.1	55.8	60.0	64.8	70.9	77.7	77.6	74.9	67.9	61.0	52.1
	5%	DB	52.7	57.6	65.4	75.2	82.8	86.4	93.4	94.1	88.2	78.7	68.1	57.3
		MCWB	46.2	49.2	53.1	59.2	63.9	70.2	77.2	77.2	73.5	66.1	59.0	51.2
	10%	DB	49.9	54.1	61.5	71.7	80.0	83.8	91.1	92.0	85.3	75.6	65.2	54.4
		MCWB	44.1	47.1	52.0	57.7	63.2	69.9	76.6	76.8	72.7	64.6	58.0	48.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.3	60.0	62.3	68.9	72.8	77.3	81.4	80.8	79.1	75.1	66.7	58.7
		MCDB	58.2	64.8	67.5	75.6	79.6	83.4	92.0	91.8	87.3	80.6	71.3	61.5
	2%	WB	50.5	55.1	58.8	65.7	70.2	75.7	79.8	79.7	77.3	72.0	63.8	55.1
		MCDB	53.0	59.5	64.7	71.8	76.2	82.4	89.9	90.3	85.1	78.0	67.9	58.2
	5%	WB	47.4	51.7	56.1	62.8	68.3	74.5	78.6	78.7	76.1	69.5	61.7	52.0
		MCDB	51.1	56.0	62.7	69.9	75.6	81.2	88.3	89.1	83.7	75.2	66.1	55.7
	10%	WB	44.8	48.3	53.3	60.5	66.5	73.2	77.7	77.9	74.8	67.0	59.3	49.4
		MCDB	49.2	53.0	59.5	68.0	74.3	79.5	86.9	87.7	82.1	72.4	64.0	53.6
(35) Mean Daily Temperature Range	5% DB	MDBR	16.9	18.8	20.6	22.4	22.1	16.5	16.2	17.4	17.0	19.4	19.2	17.6
		MCDBR	22.2	25.4	27.9	29.2	28.6	22.5	20.7	21.1	20.7	22.8	22.7	22.0
		MCWBR	14.6	15.9	15.5	13.5	11.3	8.0	6.4	6.5	7.4	10.3	12.7	14.1
	5% WB	MCDBR	18.8	20.4	21.4	19.6	17.9	14.2	18.2	18.3	16.7	16.2	17.2	17.6
		MCWBR	14.1	15.1	14.2	11.3	9.8	6.4	6.3	6.2	6.6	8.2	11.0	13.0
(40) Clear-Sky Solar Irradiance	taub		0.435	0.479	0.545	0.565	0.572	0.582	0.580	0.547	0.516	0.468	0.436	0.427
	taud		2.027	1.953	1.800	1.807	1.847	1.900	1.950	2.028	2.073	2.114	2.115	2.068
	Ebn at Noon		235	239	233	236	236	233	233	238	239	240	235	230
	Edh at Noon		44	52	66	68	66	62	59	54	49	44	40	40
(44) All-Sky Solar Radiation	RadAvg		725	940	1276	1522	1636	1373	1537	1611	1301	1100	830	667
	RadStd		67	87	83	138	186	182	220	166	141	116	79	46

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page