

NAGASAKI, Japan

WMO: 478170

Lat: 32.7343N

Lon: 129.8680E

Elev: 36

StdP: 100.89

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.8	1.8	-7.3	2.0	4.9	-6.0	2.3	5.0	8.8	8.5	7.8	9.6	2.2	80	0.355

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.7	33.0	25.8	32.0	25.7	31.1	25.4	27.1	30.5	26.6	29.9	26.2	29.4	3.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	21.6	28.8	25.7	21.0	28.5	25.3	20.5	28.4	85.5	30.7	83.4	30.0	81.6	29.4	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.4	5.5	DB	-1.2	35.4	1.0	1.0	-1.9	36.1	-2.5	36.7	-3.1	37.3	-3.8	38.0	(4)
(5)			WB	-2.8	27.4	1.0	0.7	-3.5	27.9	-4.1	28.3	-4.6	28.7	-5.3	29.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	7.1	8.2	11.2	15.7	19.9	23.2	27.4	28.6	25.4	20.4	14.7	9.4	(6)	
	DBStd	7.73	2.77	3.15	3.03	2.74	1.95	1.89	1.97	1.68	2.27	2.61	3.18	3.04	(7)	
	HDD10.0	236	97	68	21	1	0	0	0	0	0	0	2	48	(8)	
	HDD18.3	1344	348	284	220	85	7	0	0	0	0	10	115	276	(9)	
	CDD10.0	3031	7	17	59	172	308	397	538	575	461	323	143	31	(10)	
	CDD18.3	1096	0	0	0	7	56	147	279	317	211	74	6	0	(11)	
	CDH23.3	9264	0	0	0	11	137	673	2862	3677	1639	262	3	0	(12)	
	CDH26.7	2891	0	0	0	1	7	78	921	1448	411	26	0	0	(13)	
(14) Wind	WSAvg	2.3	2.3	2.4	2.6	2.5	2.2	2.2	2.5	2.2	2.1	2.0	2.0	2.2	(14)	
(15) Precipitation	PrecAvg	1920	70	84	119	167	180	331	300	199	189	103	93	70	(15)	
	PrecMax	2846	237	192	350	348	390	789	1179	668	490	280	214	152	(16)	
	PrecMin	924	9	22	43	36	50	44	6	7	2	4	12	5	(17)	
	PrecStd	390	38	42	51	66	80	157	217	136	110	70	52	34	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.0	19.1	21.2	24.7	27.6	29.9	33.9	35.0	32.5	29.2	23.9	18.8	(19)	
		MCWB	14.2	15.4	15.5	17.9	20.0	23.6	25.6	25.8	24.8	22.4	18.9	15.4	(20)	
	2%	DB	14.9	17.2	19.3	22.8	25.9	28.5	32.4	33.5	31.2	27.2	22.2	17.2	(21)	
		MCWB	11.9	14.2	14.6	16.9	19.1	23.2	26.0	25.7	24.6	21.2	17.6	13.3	(22)	
	5%	DB	13.2	15.3	17.9	21.7	24.8	27.5	31.4	32.6	30.1	25.9	20.9	15.8	(23)	
		MCWB	9.6	12.1	13.8	16.4	18.8	23.0	25.7	25.8	23.9	20.1	16.9	12.0	(24)	
	10%	DB	11.7	13.5	16.5	20.4	23.8	26.6	30.5	31.7	29.0	24.7	19.7	14.4	(25)	
		MCWB	8.1	9.8	12.7	15.7	18.4	22.6	25.5	25.7	23.5	19.3	15.8	11.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.4	16.7	17.6	20.9	23.1	25.9	27.8	27.7	26.7	24.7	20.6	17.1	(27)	
		MCDB	16.6	17.9	19.2	22.7	25.0	28.1	31.0	31.2	29.6	26.9	22.2	18.1	(28)	
	2%	WB	12.6	14.8	16.0	19.1	21.7	25.2	27.0	27.2	25.9	23.2	19.2	14.3	(29)	
		MCDB	14.3	16.7	18.1	21.1	23.5	27.3	30.2	30.8	28.9	25.8	20.9	16.2	(30)	
	5%	WB	10.2	12.6	14.6	17.9	20.6	24.6	26.5	26.7	25.3	21.9	17.8	12.8	(31)	
		MCDB	12.4	14.9	17.2	20.2	22.8	26.6	29.5	30.3	28.5	24.6	20.2	15.0	(32)	
	10%	WB	8.7	10.4	13.2	16.7	19.6	23.7	26.1	26.4	24.6	20.4	16.5	11.4	(33)	
		MCDB	11.2	12.8	16.1	19.4	22.5	25.6	29.0	30.0	27.9	23.5	19.1	14.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.1	6.8	7.1	7.3	7.1	5.5	5.1	5.7	6.2	6.9	6.8	6.4	(35)	
		MCDBR	8.1	8.7	8.8	8.8	8.4	6.7	6.3	6.8	6.9	7.8	7.5	7.9	(36)	
	5% WB	MCWBR	6.1	6.7	6.1	5.0	4.3	3.2	2.4	2.4	2.9	3.7	4.6	5.5	(37)	
		MCWBR	7.6	7.7	7.4	6.6	6.0	4.5	5.4	5.8	5.8	6.0	6.2	7.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.445	0.484	0.543	0.562	0.571	0.582	0.564	0.539	0.512	0.468	0.438	0.434	(40)	
		taud	2.025	1.959	1.822	1.830	1.870	1.932	2.019	2.091	2.113	2.135	2.133	2.064	(41)	
	Ebn at Noon		737	752	740	749	746	735	746	759	761	762	743	722	(42)	
		Edh at Noon	139	164	203	210	203	190	174	160	150	136	124	128	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.17	2.93	4.03	4.84	5.15	4.33	5.17	5.38	4.36	3.63	2.61	2.02	(44)	
	RadStd		0.22	0.29	0.27	0.42	0.59	0.67	0.71	0.47	0.45	0.36	0.26	0.16	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (30 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page