

MIYAZAKI, Japan

WMO: 478300

Lat: 31.9383N

Lon: 131.4142E

Elev: 49

StdP: 14.67

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 31.9	(c) 34.0	(d) 16.2	(e) 12.5	(f) 43.8	(g) 19.2	(h) 14.5	(i) 42.9	(j) 24.6	(k) 50.4	(l) 22.2	(m) 49.2	(n) 6.5	(o) 290	(p) 0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 11.6	(c) 92.7	(d) 78.3	(e) 90.5	(f) 78.3	(g) 88.6	(h) 78.0	(i) 80.7	(j) 87.3	(k) 79.9	(l) 86.4	(m) 79.1	(n) 85.6	(o) 11.3	(p) 240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.1	151.4	83.8	78.2	146.8	83.3	77.4	142.7	82.8	44.4	87.3	43.5	86.5	42.8	85.8	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 20.7	(b) 17.8	(c) 15.4	(e) 28.0	(f) 96.5	(g) 2.0	(h) 1.6	(i) 26.5	(j) 97.7	(k) 25.4	(l) 98.7	(m) 24.2	(n) 99.6	(o) 22.8	(p) 100.8		
(4) 20.7	(5) 17.8	(6) 15.4	(7) 28.0	(8) 96.5	(9) 2.0	(10) 1.6	(11) 26.5	(12) 97.7	(13) 25.4	(14) 98.7	(15) 24.2	(16) 99.6	(17) 22.8	(18) 100.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.4	46.3	48.4	53.7	61.6	68.9	74.1	81.9	82.6	77.2	68.7	58.9	49.8	(6)	
(7)		DBStd	13.43	4.95	5.94	5.68	5.19	3.91	4.55	3.51	2.71	4.12	4.93	5.86	5.59	(7)	
(8)		HDD50	334	138	93	26	1	0	0	0	0	0	0	2	74	(8)	
(9)		HDD65	2222	581	464	352	126	10	0	0	0	0	20	196	473	(9)	
(10)		CDD50	5600	22	49	141	348	587	722	988	1010	817	579	270	67	(10)	
(11)		CDD65	2009	0	0	1	23	131	272	523	545	367	133	14	0	(11)	
(12)		CDH74	17551	0	1	6	74	511	1618	5650	6126	2953	586	26	0	(12)	
(13)		CDH80	5727	0	0	0	8	74	380	2119	2345	736	63	2	0	(13)	
(14)	Wind	WSAvg	7.0	7.7	7.3	7.5	7.3	6.8	6.4	7.2	7.2	6.5	6.2	6.2	7.2	(14)	
(15)	Precipitation	PrecAvg	99.8	2.6	3.4	6.1	8.3	10.0	17.7	11.7	11.4	13.6	7.6	4.1	2.5	(15)	
(16)		PrecMax	164.5	10.8	11.3	17.3	15.9	22.8	37.6	43.1	35.5	40.7	30.7	19.4	8.1	(16)	
(17)		PrecMin	70.6	0.1	0.6	1.3	0.8	2.6	6.8	1.2	0.5	3.1	0.4	0.4	0.0	(17)	
(18)		PrecStd	19.3	2.2	2.3	3.3	3.2	3.8	7.3	7.7	7.0	7.8	6.1	3.6	1.9	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.7	70.6	74.3	80.1	86.1	91.4	95.6	96.0	91.5	84.7	77.0	69.4	(19)	
(20)			MCWB	55.7	62.2	60.9	64.9	69.9	77.1	78.2	78.7	77.4	74.1	68.4	61.1	(20)	
(21)		2%	DB	61.5	65.7	69.6	75.7	81.8	87.7	93.1	92.6	88.2	81.7	73.7	65.4	(21)	
(22)			MCWB	53.7	59.1	58.7	64.2	67.5	76.6	78.0	78.8	77.0	72.0	64.7	57.5	(22)	
(23)		5%	DB	58.6	62.2	66.8	73.1	78.8	84.2	90.8	90.5	85.9	79.3	71.5	62.7	(23)	
(24)			MCWB	51.1	55.0	57.7	63.2	66.6	75.2	78.4	78.7	76.2	70.2	63.5	55.2	(24)	
(25)		10%	DB	56.1	59.0	64.2	70.9	76.6	81.4	88.6	88.7	84.1	77.2	69.1	60.0	(25)	
(26)			MCWB	49.0	51.8	56.2	61.6	66.4	73.7	78.2	78.4	75.4	68.6	62.0	53.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.6	63.9	65.4	71.0	74.9	79.0	81.7	81.9	80.4	77.3	70.5	63.8	(27)	
(28)			MCD B	63.6	68.5	69.9	75.4	81.1	86.4	88.1	88.5	86.3	81.7	74.7	66.6	(28)	
(29)		2%	WB	56.3	60.6	62.3	68.5	72.9	77.6	80.5	80.9	79.1	75.2	67.8	59.9	(29)	
(30)			MCD B	59.2	65.0	66.4	72.3	77.4	84.6	87.5	87.4	84.4	79.3	71.1	63.4	(30)	
(31)		5%	WB	52.9	57.1	60.3	65.9	70.9	76.5	79.7	80.2	78.2	73.2	65.7	57.0	(31)	
(32)			MCD B	56.9	61.0	64.7	70.5	74.8	82.7	86.6	86.6	83.3	77.4	69.2	61.2	(32)	
(33)		10%	WB	49.7	53.5	57.7	63.8	69.2	75.4	78.9	79.5	77.3	70.9	63.6	54.3	(33)	
(34)			MCD B	55.0	56.9	62.4	68.6	73.5	80.6	85.8	85.9	82.2	75.1	67.7	58.5	(34)	
(35)	Mean Daily Temperature Range			MDBR	16.6	16.2	16.1	15.5	14.0	10.8	11.6	11.6	11.9	14.3	15.9	16.7	(35)
(36)		5% DB	MCD BR	19.2	18.8	19.1	18.3	17.9	14.0	14.9	14.4	13.6	15.5	16.3	18.4	(36)	
(37)			MCWBR	12.9	12.6	11.7	10.3	9.0	5.9	5.0	4.9	5.6	7.7	9.7	11.7	(37)	
(38)		5% WB	MCD BR	16.8	16.1	15.6	14.1	12.8	12.2	12.3	12.1	11.2	11.6	12.6	15.1	(38)	
(39)			MCWBR	13.5	12.5	11.8	9.5	8.5	5.8	5.2	4.9	5.5	6.8	8.8	11.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.421	0.468	0.532	0.555	0.566	0.569	0.550	0.537	0.520	0.487	0.436	0.408	(40)	
(41)		taud		2.108	2.010	1.856	1.853	1.892	1.962	2.048	2.072	2.083	2.093	2.157	2.165	(41)	
(42)		Ebn at Noon		245	245	239	240	238	237	240	242	240	237	239	242	(42)	
(43)		Edh at Noon		41	50	62	65	63	59	54	52	49	45	39	37	(43)	
(44)	All-Sky Solar Radiation	RadAvg		859	1026	1318	1507	1550	1242	1632	1635	1334	1115	878	790	(44)	
(45)		RadStd		67	90	89	159	177	206	193	123	152	130	90	62	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47) Regional (24 neighbors)		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A

Nomenclature: See separate page