

TADOTSU, Japan

WMO: 478900

Lat: 34.2761N

Lon: 133.7525E

Elev: 5

StdP: 101.26

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.0	1.0	-8.0	1.9	3.4	-6.8	2.1	4.2	9.3	7.2	8.3	6.8	2.3	150	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.8	33.7	25.3	32.7	25.0	31.7	24.8	26.5	31.0	26.0	30.5	25.5	30.0	3.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.3	20.5	28.9	24.7	19.7	28.7	24.2	19.1	28.4	82.8	31.0	80.6	30.5	78.4	30.1	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.2	5.4	DB	-1.7	35.6	0.8	0.9	-2.2	36.2	-2.7	36.8	-3.2	37.3	-3.8	37.9	(4)
(5)			WB	-3.4	26.8	1.1	0.8	-4.2	27.4	-4.8	27.8	-5.5	28.2	-6.3	28.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	5.9	6.3	9.3	14.4	19.4	22.9	27.3	28.8	24.9	19.2	13.3	8.4		
	DBStd	8.24	2.01	2.34	2.71	2.88	2.18	2.06	2.22	1.78	2.69	2.75	2.88	2.43		
	HDD10.0	349	126	107	47	3	0	0	0	0	0	0	4	62		
	HDD18.3	1619	384	337	279	122	15	0	0	0	0	21	152	309		
	CDD10.0	2806	1	3	25	134	290	388	537	582	447	285	103	11		
	CDD18.3	1036	0	0	0	2	47	138	279	324	197	48	1	0		
	CDH23.3	9170	0	0	0	10	138	618	2789	3856	1597	162	0	0		
	CDH26.7	3248	0	0	0	1	11	105	1022	1649	447	14	0	0		
(14) Wind	WSAvg	2.4	3.0	2.6	2.5	2.4	2.1	2.0	2.1	2.2	2.2	2.2	2.4	2.8		
(15) Precipitation	PrecAvg	1135	41	49	85	81	117	154	158	96	145	103	64	41		
	PrecMax	1631	113	96	200	183	257	304	361	296	450	323	172	94		
	PrecMin	780	9	13	40	30	40	25	26	14	41	28	18	6		
	PrecStd	247	25	24	38	34	46	72	103	78	92	68	40	23		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	16.0	19.9	24.8	28.0	31.4	34.5	35.3	33.2	28.3	22.0	16.9		
		MCWB	9.4	11.7	12.5	15.7	18.0	23.6	25.3	25.5	24.6	22.8	16.8	13.3		
	2%	DB	11.9	13.2	17.2	22.4	26.2	29.1	33.2	34.1	31.6	26.4	20.7	15.1		
		MCWB	7.9	9.0	11.5	14.8	17.4	22.0	25.0	25.4	24.2	20.8	16.2	11.5		
	5%	DB	10.8	11.8	15.5	20.7	24.9	27.7	32.3	33.2	30.4	25.0	19.6	14.0		
		MCWB	7.1	8.2	10.5	14.0	17.0	21.1	24.8	25.3	23.8	19.6	15.4	10.1		
	10%	DB	9.8	10.5	14.0	19.2	23.6	26.5	31.2	32.3	29.2	23.9	18.4	12.8		
		MCWB	6.3	7.0	9.5	13.3	16.8	20.7	24.6	25.1	23.2	18.7	14.5	9.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.6	12.8	14.2	18.1	20.9	24.2	26.7	27.4	26.4	23.9	18.9	14.4		
		MCDB	12.1	15.5	17.0	21.5	24.1	28.6	31.4	32.1	30.4	27.1	20.5	15.7		
	2%	WB	8.9	10.4	12.7	16.6	19.7	23.5	26.1	26.7	25.5	22.3	17.5	12.3		
		MCDB	10.9	12.3	15.5	19.7	22.8	27.4	30.7	31.3	29.3	25.4	19.6	14.4		
	5%	WB	7.9	8.8	11.6	15.5	18.9	22.8	25.6	26.3	24.8	20.9	16.2	10.9		
		MCDB	10.2	10.9	14.4	18.9	22.3	26.2	30.2	30.8	28.7	23.8	18.8	13.2		
	10%	WB	6.7	7.6	10.4	14.6	18.1	22.0	25.1	25.8	24.2	19.6	15.0	9.6		
		MCDB	9.5	10.0	13.4	18.0	21.8	24.9	29.7	30.4	28.1	22.9	17.9	12.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.3	6.9	7.7	8.2	8.0	6.3	6.3	6.8	6.8	7.3	7.2	6.6		
		MCDBR	7.7	8.6	9.7	10.4	9.9	8.0	7.6	7.7	7.6	7.8	7.8	8.1		
	5% WB	MCWBR	5.6	5.9	6.0	5.1	4.4	3.1	2.4	2.7	3.2	4.2	5.3	5.8		
		MCWBR	7.3	7.4	8.5	7.9	7.4	6.4	7.1	7.1	6.8	6.4	6.9	7.2		
(40) Clear-Sky Solar Irradiance	taub	taub	0.396	0.441	0.499	0.528	0.530	0.550	0.551	0.524	0.484	0.442	0.415	0.390		
		taud	2.173	2.068	1.926	1.907	1.972	1.999	2.049	2.116	2.199	2.230	2.209	2.208		
	Ebn at Noon	Ebn at Noon	784	788	773	773	776	758	755	768	781	781	759	765		
		Edh at Noon	117	145	181	193	183	178	168	155	136	122	113	107		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.46	3.06	4.03	4.86	5.28	4.69	5.08	5.21	4.09	3.40	2.57	2.16		
	RadStd	RadStd	0.17	0.24	0.30	0.45	0.51	0.46	0.65	0.52	0.41	0.34	0.22	0.14		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	+0.67	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)		N/A	N/A	N/A	N/A	N/A	+0.27	N/A	N/A	N/A	N/A

Nomenclature: See separate page