

UWAJIMA, Japan

WMO: 478920

Lat: 33.2278N

Lon: 132.5531E

Elev: 48

StdP: 14.67

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	32.0	33.8	20.0	15.0	40.8	22.2	16.7	41.3	32.9	42.5	29.2	42.8	5.5	130	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.9	91.6	78.2	90.1	77.9	88.6	77.4	79.9	88.3	79.0	87.1	78.2	86.0	9.6	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.6	143.7	84.3	76.8	139.8	83.5	76.0	136.1	83.1	43.5	88.5	42.6	87.4	41.8	86.3	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
25.0	20.7	17.2	DB	28.7	94.4	1.6	1.6	27.6	95.5	26.7	96.4	25.8	97.3	24.6	98.5	
			WB	26.7	80.9	1.6	1.1	25.6	81.7	24.7	82.3	23.8	82.9	22.6	83.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	63.1	44.5	45.8	51.1	59.6	67.3	73.3	80.9	82.6	76.9	67.6	57.9	48.7	(6)
(7)		DBStd	13.90	4.47	5.50	5.38	5.20	3.77	3.97	3.34	2.57	4.16	4.87	5.60	5.11	(7)
(8)		HDD50	467	181	141	51	3	0	0	0	0	0	4	87		(8)
(9)		HDD65	2549	637	536	430	172	19	0	0	0	27	222	506		(9)
(10)		CDD50	5255	9	25	86	290	537	700	959	1012	807	545	239	46	(10)
(11)		CDD65	1864	0	0	0	10	91	250	494	547	357	107	8	0	(11)
(12)		CDH74	15778	0	0	1	28	340	1331	4931	5998	2708	432	9	0	(12)
(13)		CDH80	5172	0	0	0	0	22	249	1774	2359	724	44	0	0	(13)
(14)	Wind	WSAvg	6.2	8.1	7.5	7.1	6.6	5.7	5.2	5.3	5.2	5.3	6.0	7.7	(14)	
(15)	Precipitation	PrecAvg	72.8	2.5	3.3	4.9	5.3	6.8	12.0	9.0	8.8	5.4	3.9	2.8	(15)	
(16)		PrecMax	99.8	5.8	7.8	9.9	10.9	13.0	23.2	25.1	24.3	19.3	14.1	9.6	6.6	(16)
(17)		PrecMin	46.5	0.7	1.3	1.6	2.2	2.5	3.4	2.1	0.4	1.4	0.7	0.9	0.4	(17)
(18)		PrecStd	13.9	1.3	1.6	1.8	2.0	2.9	5.2	5.2	6.0	4.7	3.5	2.0	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.7	67.4	71.0	77.2	82.7	89.2	93.3	93.9	91.3	84.4	75.2	66.8	(19)
(20)		MCWB	57.2	60.1	58.9	64.1	67.7	76.7	78.5	78.5	77.0	74.4	65.5	59.6	(20)	
(21)		2%	DB	58.0	62.4	67.3	74.2	79.6	85.6	91.4	92.1	88.5	80.8	72.1	63.2	(21)
(22)		MCWB	51.4	55.7	58.0	63.0	66.4	75.0	78.2	78.4	76.5	70.6	63.6	55.7	(22)	
(23)		5%	DB	55.7	58.7	64.3	71.7	77.5	82.7	89.8	90.7	86.3	78.3	69.9	60.5	(23)
(24)		MCWB	49.3	52.3	56.1	61.3	65.5	72.8	77.8	78.2	75.4	68.7	62.1	53.3	(24)	
(25)		10%	DB	53.5	55.9	61.6	69.4	75.6	80.4	88.1	89.2	84.2	76.2	67.7	58.1	(25)
(26)		MCWB	46.8	49.5	53.8	59.9	65.0	72.0	77.4	77.9	74.3	67.2	61.0	51.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.4	61.6	64.0	69.3	73.3	77.9	81.4	81.2	79.3	75.9	68.5	62.3	(27)
(28)		MCDWB	61.6	65.5	68.1	73.4	77.7	85.4	89.9	89.9	86.9	81.6	71.7	64.9	(28)	
(29)		2%	WB	53.8	57.1	60.0	66.4	71.2	76.5	79.8	80.1	78.1	73.6	66.2	57.8	(29)
(30)		MCDWB	56.5	61.2	64.2	70.8	75.1	83.3	88.1	88.6	85.0	78.6	69.9	61.3	(30)	
(31)		5%	WB	50.4	53.9	57.6	63.6	69.2	75.3	78.8	79.4	77.0	71.4	64.1	54.8	(31)
(32)		MCDWB	54.3	57.7	62.7	69.4	73.7	81.1	86.9	87.6	83.3	76.0	68.2	59.1	(32)	
(33)		10%	WB	47.4	50.5	55.3	61.3	67.1	73.9	77.9	78.7	76.0	69.2	61.9	52.1	(33)
(34)		MCDWB	52.7	54.8	60.7	67.3	73.2	78.8	85.7	86.7	82.0	74.3	66.6	57.2	(34)	
(35)	Mean Daily Temperature Range		MDBR	13.9	14.9	16.2	16.6	15.6	11.9	12.3	12.9	13.2	15.2	15.2	14.3	(35)
(36)		5% DB	MCDBR	17.9	18.1	19.4	19.0	18.3	14.7	14.8	14.7	14.6	15.9	16.2	17.5	(36)
(37)		MCWBR	12.7	13.1	13.1	10.8	9.3	6.7	5.6	5.4	6.2	8.2	9.9	11.7	(37)	
(38)		5% WB	MCDBR	15.8	15.7	16.0	14.9	13.0	11.6	13.3	13.4	12.3	12.4	13.3	14.6	(38)
(39)		MCWBR	13.4	13.2	13.0	10.6	9.3	5.9	5.7	5.5	5.6	7.1	9.3	11.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.406	0.450	0.509	0.536	0.544	0.556	0.552	0.527	0.494	0.454	0.420	0.399	(40)	
(41)		taud	2.157	2.060	1.912	1.899	1.949	2.007	2.057	2.136	2.184	2.199	2.214	2.190	(41)	
(42)		Ebn at Noon	248	249	244	244	243	239	239	244	246	246	242	242	(42)	
(43)		Edh at Noon	38	47	59	62	60	56	53	48	44	40	36	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg	773	983	1316	1564	1664	1396	1663	1698	1366	1102	829	683	(44)	
(45)		RadStd	69	77	94	152	173	184	208	155	137	113	78	48	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	+1.53	N/A	+0.67	+0.85	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page