

UWAJIMA, Japan

WMO: 478920

Lat: 33.2278N

Lon: 132.5531E

Elev: 15

StdP: 101.15

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.0	1.0	-6.7	2.1	4.9	-5.4	2.4	5.2	14.7	5.8	13.1	6.0	2.5	130	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.2	33.1	25.7	32.3	25.5	31.4	25.2	26.6	31.3	26.1	30.6	25.7	30.0	4.3	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.3	20.5	29.0	24.9	20.0	28.6	24.5	19.4	28.4	83.4	31.4	81.2	30.8	79.4	30.1	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.2	9.2	7.7	-1.8	34.7	0.9	0.9	-2.5	35.3	-3.0	35.8	-3.5	36.3	-4.1	36.9		
			-2.9	27.2	0.9	0.6	-3.6	27.6	-4.1	27.9	-4.6	28.3	-5.2	28.7		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.3	6.9	7.7	10.6	15.3	19.6	23.0	27.2	28.1	24.9	19.8	14.4	9.3	(6)
	DBStd	7.72	2.48	3.05	2.99	2.89	2.09	2.20	1.86	1.43	2.31	2.70	3.11	2.84	(7)
	HDD10.0	259	101	78	28	2	0	0	0	0	0	0	2	48	(8)
	HDD18.3	1416	354	298	239	96	11	0	0	0	0	15	123	281	(9)
	CDD10.0	2919	5	14	48	161	298	389	533	562	448	303	133	26	(10)
	CDD18.3	1036	0	0	0	6	51	139	274	304	198	59	4	0	(11)
	CDH23.3	8766	0	0	1	16	189	739	2739	3332	1504	240	5	0	(12)
	CDH26.7	2873	0	0	0	0	12	138	986	1311	402	24	0	0	(13)
(14) Wind	WSAvg	2.8	3.6	3.4	3.2	3.0	2.5	2.3	2.3	2.4	2.3	2.4	2.7	3.4	(14)
(15) Precipitation	PrecAvg	1850	64	84	124	134	173	306	229	203	224	137	100	72	(15)
	PrecMax	2534	148	199	252	278	329	590	637	618	489	357	245	167	(16)
	PrecMin	1181	18	34	40	56	64	87	54	9	36	19	24	11	(17)
	PrecStd	353	34	40	45	50	73	133	132	153	120	90	51	37	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.0	19.6	21.7	25.1	28.2	31.8	34.1	34.4	32.9	29.1	24.0	19.4	(19)
		MCWB	14.0	15.6	15.0	17.8	19.9	24.8	25.8	25.8	25.0	23.6	18.6	15.3	(20)
	2%	DB	14.5	16.9	19.6	23.4	26.4	29.8	33.0	33.4	31.4	27.1	22.3	17.3	(21)
		MCWB	10.8	13.2	14.4	17.2	19.1	23.9	25.7	25.8	24.7	21.4	17.6	13.2	(22)
	5%	DB	13.2	14.8	17.9	22.1	25.3	28.1	32.1	32.6	30.1	25.7	21.0	15.9	(23)
		MCWB	9.6	11.3	13.4	16.3	18.6	22.7	25.4	25.7	24.1	20.4	16.7	11.8	(24)
	10%	DB	11.9	13.3	16.5	20.8	24.2	26.9	31.1	31.8	29.0	24.6	19.8	14.5	(25)
		MCWB	8.2	9.7	12.1	15.5	18.3	22.2	25.2	25.5	23.5	19.6	16.1	10.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.7	16.4	17.8	20.7	22.9	25.5	27.4	27.3	26.3	24.4	20.3	16.8	(27)
		MCDB	16.4	18.6	20.1	23.0	25.4	29.7	32.2	32.2	30.5	27.6	22.1	18.3	(28)
	2%	WB	12.1	14.0	15.6	19.1	21.8	24.7	26.5	26.7	25.6	23.1	19.0	14.3	(29)
		MCDB	13.6	16.2	17.9	21.6	24.0	28.5	31.2	31.4	29.5	25.9	21.1	16.3	(30)
	5%	WB	10.2	12.2	14.2	17.5	20.7	24.1	26.0	26.3	25.0	21.9	17.8	12.7	(31)
		MCDB	12.4	14.3	17.1	20.8	23.2	27.3	30.5	30.9	28.5	24.5	20.1	15.1	(32)
	10%	WB	8.5	10.3	13.0	16.3	19.5	23.3	25.5	25.9	24.4	20.7	16.6	11.2	(33)
		MCDB	11.5	12.7	16.0	19.6	22.9	26.0	29.8	30.4	27.8	23.5	19.2	14.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.7	8.3	9.0	9.2	8.7	6.6	6.8	7.2	7.3	8.4	8.4	8.0	(35)
		MCDBR	10.0	10.1	10.8	10.6	10.1	8.2	8.2	8.2	8.1	8.8	9.0	9.7	(36)
	5% WB	MCWBR	7.1	7.3	7.3	6.0	5.2	3.7	3.1	3.0	3.5	4.5	5.5	6.5	(37)
		MCWBR	8.8	8.7	8.9	8.3	7.2	6.5	7.4	7.5	6.8	6.9	7.4	8.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.406	0.450	0.509	0.536	0.544	0.556	0.552	0.527	0.494	0.454	0.420	0.399	(40)
		taud	2.157	2.060	1.912	1.899	1.949	2.007	2.057	2.136	2.184	2.199	2.214	2.190	(41)
	Ebn at Noon		781	785	768	769	767	754	755	768	776	774	762	764	(42)
		Edh at Noon	121	148	185	195	188	176	167	152	139	127	114	111	(43)
(44) All-Sky Solar Radiation	RadAvg		2.44	3.10	4.15	4.93	5.25	4.40	5.24	5.35	4.31	3.47	2.61	2.15	(44)
	RadStd		0.22	0.24	0.30	0.48	0.55	0.58	0.66	0.49	0.43	0.36	0.25	0.15	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	+0.85	N/A	+0.37	+0.47	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page