

NAZE, Japan

WMO: 479090

Lat: 28.3797N

Lon: 129.4956E

Elev: 26

StdP: 14.68

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	49.0	50.6	34.6	29.3	54.9	36.4	31.5	55.6	18.7	56.4	17.3	57.2	6.4	170	0.316

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	91.2	79.1	90.0	78.9	88.9	78.8	81.0	87.2	80.5	86.8	79.9	86.1	7.4	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.5	153.4	84.5	78.8	149.6	84.4	78.1	146.3	84.1	44.8	87.4	44.2	86.8	43.6	86.4	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.7	14.5	13.1	46.0	93.4	2.0	1.1	44.6	94.2	43.4	94.9	42.3	95.5	40.8	96.4		
(5)			41.9	82.1	1.8	1.5	40.7	83.2	39.6	84.1	38.7	84.9	37.4	86.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	71.4	58.7	59.5	62.6	67.6	73.2	79.3	84.2	83.9	81.0	75.4	68.9	62.0	(6)
(7)		DBStd	9.82	4.09	4.82	4.81	4.39	3.60	4.39	2.04	1.70	2.68	3.64	4.05	4.30	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	617	201	164	106	22	0	0	0	0	0	0	10	114	(9)
(10)		CDD50	7819	269	267	389	529	719	879	1060	1051	930	787	566	373	(10)
(11)		CDD65	2962	5	11	31	101	254	429	595	586	480	322	126	22	(11)
(12)		CDH74	26814	2	8	45	209	1103	3958	7301	7045	4878	1977	274	14	(12)
(13)		CDH80	8895	0	0	1	12	124	1229	3039	2789	1433	257	11	0	(13)
(14)	Wind	WSAvg	5.8	6.9	6.8	6.6	5.9	5.0	5.1	5.3	5.1	5.5	5.9	6.6	(14)	
(15)	Precipitation	PrecAvg	113.8	7.3	6.2	8.0	8.5	11.8	16.3	8.3	12.2	12.4	9.3	7.0	6.3	(15)
(16)		PrecMax	173.5	18.4	17.2	16.0	16.7	25.6	37.0	25.2	31.9	43.2	39.2	21.3	12.8	(16)
(17)		PrecMin	67.1	0.9	1.9	2.3	2.2	2.4	2.4	0.0	2.0	1.7	0.5	1.0	2.2	(17)
(18)		PrecStd	20.7	3.5	2.8	3.0	3.3	5.0	7.6	6.2	7.7	8.5	7.1	4.3	2.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.7	75.1	78.6	81.8	86.3	91.5	92.8	92.2	90.0	86.9	81.5	75.9	(19)
(20)			MCWB	65.4	67.0	69.5	72.7	76.3	78.4	78.8	79.6	79.0	77.3	73.7	68.6	(20)
(21)		2%	DB	69.9	72.0	74.6	78.5	83.2	89.9	91.5	90.8	88.4	84.5	78.7	73.1	(21)
(22)			MCWB	63.4	65.1	66.9	71.3	74.5	78.3	78.9	79.5	78.4	76.5	71.1	65.8	(22)
(23)		5%	DB	67.8	69.8	72.2	76.3	80.9	88.2	90.3	89.7	87.2	82.7	76.9	71.1	(23)
(24)			MCWB	61.5	63.8	65.4	69.6	73.2	78.1	78.9	79.2	77.9	75.1	69.6	64.2	(24)
(25)		10%	DB	65.8	67.6	69.9	74.4	79.1	86.3	89.1	88.6	86.0	81.2	75.4	69.1	(25)
(26)			MCWB	59.3	62.1	63.8	67.8	71.9	77.8	78.8	79.0	77.5	73.6	68.5	62.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.3	68.6	70.5	74.2	77.6	80.6	81.8	82.2	81.0	79.2	75.2	70.2	(27)
(28)			MCDWB	71.0	72.4	76.2	79.1	82.7	88.1	88.4	87.7	86.7	83.3	79.2	73.6	(28)
(29)		2%	WB	64.7	66.6	68.8	72.7	76.2	79.7	81.0	81.3	80.1	77.9	73.3	67.6	(29)
(30)			MCDWB	68.5	70.5	73.3	77.1	81.0	86.7	87.5	87.1	85.6	82.3	77.0	71.6	(30)
(31)		5%	WB	62.7	64.7	66.9	71.4	75.1	78.9	80.4	80.6	79.3	76.9	71.7	65.8	(31)
(32)			MCDWB	67.0	68.8	71.0	75.4	79.5	85.6	86.9	86.7	84.7	81.3	75.7	69.7	(32)
(33)		10%	WB	60.6	62.8	65.1	69.7	73.9	78.2	79.8	80.0	78.8	75.7	70.0	63.9	(33)
(34)			MCDWB	65.0	66.9	69.1	73.5	78.1	84.7	86.4	86.0	84.0	80.1	74.1	68.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.8	9.3	10.1	10.3	10.2	9.2	9.8	9.5	9.6	9.5	9.4	9.0	(35)
(36)			MCDBR	12.4	12.1	12.5	11.6	11.6	11.0	11.4	11.2	10.7	10.6	10.9	11.3	(36)
(37)			MCWBR	8.6	8.2	7.6	6.7	5.8	4.1	3.7	3.8	4.0	4.8	6.0	7.2	(37)
(38)		5% WB	MCDBR	10.5	10.6	10.4	9.8	9.7	10.1	9.9	9.7	9.3	8.9	8.7	9.2	(38)
(39)			MCWBR	8.8	9.1	8.1	7.0	5.8	4.2	3.8	3.8	4.1	4.4	6.3	7.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.462	0.494	0.551	0.560	0.524	0.491	0.481	0.488	0.484	0.479	0.459	0.453	(40)	
(41)		taud	2.078	2.018	1.889	1.924	2.095	2.274	2.304	2.281	2.256	2.201	2.187	2.107	(41)	
(42)		Ebn at Noon	240	244	238	241	250	257	259	257	254	246	240	236	(42)	
(43)		Edh at Noon	45	51	62	61	52	43	42	43	42	42	40	42	(43)	
(44)	All-Sky Solar Radiation	RadAvg	685	855	1120	1360	1506	1510	2023	1886	1597	1207	853	666	(44)	
(45)		RadStd	79	121	118	107	178	121	137	106	117	88	75	57	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+0.79	N/A	N/A	N/A	N/A	(46)
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	+0.54	+0.83	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page