

IRIOMOTEJIMA, Japan

WMO: 479170

Lat: 24.4278N

Lon: 123.7656E

Elev: 37

StdP: 14.68

Time Zone: 9.00 (E09)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	55.3	56.9	41.7	39.0	57.6	44.0	42.5	59.1	24.4	62.1	20.8	63.4	11.8	30	0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	90.2	80.8	89.3	80.7	88.5	80.4	82.5	87.7	81.8	87.0	81.4	86.5	9.4	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.0	161.1	85.9	80.4	158.1	85.4	79.9	155.2	85.1	46.5	88.0	45.7	87.3	45.2	86.7	93.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.5	19.0	17.2	DB	52.8	92.2	2.6	1.3	50.9	93.2	49.3	93.9	47.8	94.6	45.9	95.6
			WB	46.8	83.8	2.3	2.7	45.1	85.7	43.8	87.2	42.4	88.7	40.8	90.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	75.5	65.3	66.8	68.5	73.1	78.1	82.6	84.6	84.0	82.2	78.3	73.9	68.1
	DBStd	7.66	4.37	4.92	4.83	4.17	3.31	2.77	1.68	1.57	2.00	2.71	3.41	4.26
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	131	50	36	23	1	0	0	0	0	0	1	20	
	CDD50	9308	475	470	573	692	871	978	1071	1055	966	877	718	562
	CDD65	3964	60	86	131	243	406	528	606	590	516	412	269	117
	CDH74	35470	40	133	334	1115	3250	6021	7586	7146	5641	3047	1016	141
	CDH80	11107	0	0	7	99	622	2114	3212	2813	1718	453	66	3
Wind	WSAvg	8.9	10.1	9.5	9.0	8.2	7.4	8.8	8.1	7.1	8.0	10.1	10.3	10.6
Precipitation	PrecAvg	87.7	6.3	5.7	5.6	5.9	6.6	8.7	5.0	10.1	11.2	9.4	7.0	6.1
	PrecMax	135.6	12.5	9.1	10.2	10.9	17.3	22.9	14.8	24.2	33.9	25.4	18.1	16.0
	PrecMin	52.4	2.7	1.7	1.9	2.4	0.8	1.7	0.3	2.4	3.8	0.9	0.6	1.4
	PrecStd	18.0	2.7	2.0	2.5	2.0	4.4	5.2	3.6	5.4	7.1	6.7	4.1	3.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.7	79.4	81.1	84.2	87.5	90.3	92.2	91.1	89.7	87.6	83.8	79.8
		MCWB	70.4	73.1	74.3	77.7	79.6	81.1	80.8	81.0	80.8	79.9	76.6	73.2
	2%	DB	74.9	77.3	79.2	82.5	86.0	89.0	90.6	89.9	88.4	85.5	81.9	77.2
		MCWB	68.2	71.3	72.7	76.3	78.9	80.8	80.7	81.0	80.3	78.4	75.3	71.0
	5%	DB	72.9	75.6	77.5	81.0	84.7	87.9	89.6	89.0	87.2	84.0	80.2	75.5
		MCWB	67.1	70.0	71.5	75.5	78.3	80.4	80.5	80.8	79.7	77.2	74.1	69.7
	10%	DB	71.4	73.9	75.8	79.6	83.4	86.9	88.6	88.0	86.2	82.6	78.7	73.9
		MCWB	66.2	68.6	70.3	74.5	77.6	80.1	80.3	80.5	79.1	76.0	73.1	68.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.0	74.3	75.5	78.3	81.3	82.8	83.3	83.5	82.4	80.9	78.5	75.0
		MCDB	74.9	78.3	79.6	82.9	85.8	87.6	88.7	88.5	87.6	85.5	81.9	77.8
	2%	WB	70.2	72.5	74.0	77.3	79.9	81.8	82.3	82.6	81.4	79.8	76.5	72.9
		MCDB	73.2	76.1	78.2	81.6	84.5	86.8	87.9	87.7	86.4	84.0	80.1	75.9
	5%	WB	68.7	71.1	72.5	76.1	79.0	81.3	81.7	81.9	80.7	78.8	75.5	71.1
		MCDB	71.8	74.6	76.8	80.3	83.5	86.3	87.3	86.9	85.5	82.7	78.9	74.2
	10%	WB	67.3	69.6	70.9	75.0	78.1	80.7	81.1	81.2	80.0	77.6	74.4	69.5
		MCDB	70.7	73.1	75.0	79.0	82.5	85.7	86.7	86.2	84.6	81.4	77.8	72.9
Mean Daily Temperature Range	5% DB	MDBR	7.0	7.6	8.5	8.4	8.1	7.2	8.4	8.5	8.1	7.0	6.8	6.6
		MCDBR	9.2	9.8	10.4	9.1	8.8	7.7	9.5	9.5	9.0	8.6	8.8	8.6
		MCWBR	5.7	6.1	6.3	5.3	4.7	3.4	3.6	3.9	4.1	4.4	4.7	5.6
	5% WB	MCDBR	7.8	8.7	9.4	8.5	8.2	7.1	8.6	8.6	8.5	7.9	7.7	8.1
		MCWBR	5.9	6.4	6.9	5.6	4.8	3.7	3.8	3.9	4.1	4.1	4.8	6.3
Clear-Sky Solar Irradiance	taub	0.498	0.518	0.607	0.613	0.534	0.494	0.483	0.503	0.499	0.504	0.498	0.504	
	taud	2.042	2.017	1.820	1.860	2.123	2.270	2.301	2.232	2.212	2.140	2.124	2.034	
	Ebn at Noon	237	243	228	230	248	256	259	254	253	244	235	228	
	Edh at Noon	49	53	68	66	50	43	42	45	45	46	44	47	
All-Sky Solar Radiation	RadAvg	714	904	1114	1329	1591	1805	2033	1839	1613	1267	891	705	
	RadStd	119	170	151	176	197	148	133	138	167	142	104	98	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.41	N/A	N/A	+0.56	+0.77	+0.83	N/A	N/A	+135	+124

Nomenclature: See separate page