

OKINOERABU AP, Japan

WMO: 479420

Lat: 27.432N

Lon: 128.706E

Elev: 30

StdP: 100.97

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.3	12.3	2.4	4.5	13.1	3.4	4.8	13.5	14.0	15.5	12.9	15.3	7.8	330	0.503

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.0	31.9	27.1	31.4	26.9	30.9	26.8	28.1	30.2	27.7	29.9	27.4	29.7	5.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	23.6	29.0	27.1	23.0	29.0	26.7	22.4	28.9	90.3	30.1	88.7	30.0	87.2	29.8	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.7	11.9	10.6	9.4	32.7	1.1	0.6	8.6	33.2	8.0	33.6	7.4	33.9	6.5	34.4		
(5)			6.3	28.5	0.8	0.7	5.7	29.0	5.2	29.4	4.8	29.8	4.2	30.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	22.7	16.4	16.7	18.1	20.6	23.2	26.1	28.8	28.9	27.8	25.4	22.0	18.4	(6)
(7)		DBStd	4.88	2.39	2.53	2.50	2.08	1.71	1.89	1.00	1.05	1.29	1.75	2.07	2.41	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	198	69	57	36	5	0	0	0	0	0	0	1	30	(9)
(10)		CDD10.0	4647	199	188	252	317	409	483	582	584	535	476	361	259	(10)
(11)		CDD18.3	1803	10	12	29	72	151	233	324	326	285	218	112	31	(11)
(12)		CDH23.3	15282	1	2	12	76	494	1899	3872	3973	3121	1539	279	14	(12)
(13)		CDH26.7	4567	0	0	0	2	28	387	1452	1553	936	203	7	0	(13)
(14)	Wind	WSAvg	5.6	6.2	6.1	6.1	5.5	4.8	4.9	5.0	5.3	5.5	6.1	6.0	6.2	(14)
(15)	Precipitation	PrecAvg	1890	104	107	145	161	200	280	143	176	180	162	111	95	(15)
(16)		PrecMax	3248	251	396	361	435	457	713	460	654	394	553	215	237	(16)
(17)		PrecMin	1157	10	37	44	27	23	71	5	33	20	14	26	31	(17)
(18)		PrecStd	470	58	78	68	85	100	137	124	126	113	137	55	51	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.1	23.4	24.8	26.7	28.8	31.5	32.5	32.7	32.0	30.2	27.6	24.8	(19)
(20)			MCWB	19.5	20.3	21.8	24.0	25.9	27.5	27.3	27.3	27.2	25.9	23.9	21.1	(20)
(21)		2%	DB	21.9	22.2	23.2	25.1	27.4	30.6	31.8	32.0	31.1	29.4	26.4	23.5	(21)
(22)			MCWB	18.5	19.4	20.2	22.5	24.9	27.2	27.1	27.0	26.6	25.4	22.8	20.0	(22)
(23)		5%	DB	21.0	21.4	22.3	24.1	26.4	29.7	31.3	31.4	30.5	28.5	25.6	22.7	(23)
(24)			MCWB	17.8	18.7	19.6	21.5	23.9	27.0	26.9	26.9	26.2	24.7	22.1	19.1	(24)
(25)		10%	DB	20.1	20.5	21.5	23.4	25.6	28.9	30.8	30.9	29.9	27.8	24.9	21.9	(25)
(26)			MCWB	16.6	17.8	19.0	20.9	23.1	26.6	26.8	26.8	25.9	24.0	21.5	18.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.7	21.3	22.5	24.3	26.4	28.3	28.7	28.3	27.9	26.8	24.8	22.5	(27)
(28)			MCD B	22.3	22.6	24.0	25.9	27.8	29.9	30.1	30.5	30.7	29.0	26.6	23.9	(28)
(29)		2%	WB	19.4	20.3	21.4	23.3	25.4	27.7	28.1	27.9	27.4	26.1	24.0	20.9	(29)
(30)			MCD B	21.3	21.6	22.6	24.5	26.8	29.5	29.9	30.3	30.0	28.5	25.7	22.8	(30)
(31)		5%	WB	18.2	19.4	20.6	22.6	24.7	27.2	27.7	27.6	27.0	25.5	23.1	19.9	(31)
(32)			MCD B	20.5	21.0	21.8	23.7	25.8	29.0	29.8	30.1	29.5	27.9	25.1	22.1	(32)
(33)		10%	WB	17.1	18.2	19.6	21.7	24.1	26.8	27.4	27.2	26.6	25.0	22.2	18.9	(33)
(34)			MCD B	19.8	20.3	21.2	22.9	25.1	28.4	29.6	29.9	29.1	27.3	24.5	21.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.7	4.0	4.2	4.1	3.9	3.9	4.1	4.0	3.9	3.6	3.5	3.6	(35)
(36)			MCDBR	4.7	4.7	4.7	4.6	4.4	4.7	4.5	4.5	4.2	4.0	3.8	4.2	(36)
(37)			MCWBR	4.2	4.1	4.0	3.5	2.9	2.4	2.0	2.1	2.2	2.5	3.0	3.5	(37)
(38)		5% WB	MCD BR	4.5	4.5	4.4	4.4	4.1	4.5	4.1	4.1	3.9	3.7	3.7	4.1	(38)
(39)			MCWBR	4.6	4.7	4.6	3.7	3.1	2.5	2.2	2.1	2.2	2.5	3.4	3.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.456	0.487	0.551	0.558	0.516	0.476	0.470	0.483	0.480	0.475	0.460	0.450	(40)	
(41)		taud	2.118	2.055	1.908	1.948	2.137	2.328	2.345	2.300	2.275	2.225	2.204	2.140	(41)	
(42)		Ebn at Noon	770	780	754	763	794	821	826	814	807	784	763	754	(42)	
(43)		Edh at Noon	137	157	192	189	157	129	126	132	131	131	125	129	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.34	2.86	3.74	4.44	4.89	5.15	6.64	6.15	5.28	4.03	2.88	2.27	(44)	
(45)		RadStd	0.29	0.43	0.38	0.33	0.61	0.43	0.47	0.33	0.34	0.27	0.26	0.19	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	+0.31	+0.50	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	+0.37	+0.49	N/A	N/A	N/A	N/A

Nomenclature: See separate page