

MINAMIDAITOJIMA, Japan

WMO: 479450

Lat: 25.8289N

Lon: 131.2286E

Elev: 69

StdP: 14.66

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	51.7	54.7	40.8	37.7	59.7	42.5	40.1	60.0	25.3	65.8	23.2	64.6	3.2	50	0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	89.9	80.6	89.0	80.3	88.2	80.0	82.5	87.3	81.8	86.6	81.2	86.0	11.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.1	161.7	85.4	80.6	159.1	84.9	79.9	155.8	84.5	46.4	87.5	45.7	86.8	45.1	86.1	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
26.1	21.6	19.1	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			45.8	91.1	1.6	0.9	44.6	91.8	43.7	92.3	42.8	92.9	41.6	93.6
			44.3	82.9	1.4	1.1	43.3	83.7	42.5	84.4	41.7	85.0	40.7	85.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.3	64.0	64.5	66.7	70.9	75.4	80.7	83.7	83.7	82.3	78.7	73.5	67.2
	DBStd	8.00	3.88	4.28	4.29	3.98	3.73	3.06	1.83	1.96	2.36	3.10	3.75	4.20
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	188	66	58	33	4	0	0	0	0	0	1	26	
	CDD50	8883	435	406	517	627	788	922	1044	1043	970	891	706	534
	CDD65	3595	36	44	86	180	323	472	579	578	520	426	257	94
	CDH74	32123	16	28	84	434	1867	4697	7093	7038	5958	3711	1079	118
	CDH80	9927	0	0	1	16	231	1215	2813	2788	2062	737	63	1
Wind	WSAvg	10.2	10.1	10.1	10.1	10.0	9.3	9.7	9.7	10.5	10.5	10.7	10.7	10.5
Precipitation	PrecAvg	63.0	3.7	3.2	3.5	4.4	7.8	7.5	4.4	6.8	5.5	6.9	4.9	4.5
	PrecMax	105.0	11.6	12.0	9.4	11.3	20.4	23.0	18.9	26.3	19.9	19.3	15.7	11.5
	PrecMin	41.5	0.6	0.3	0.2	0.5	0.7	0.4	0.1	0.4	0.7	0.6	0.6	0.3
	PrecStd	12.7	2.2	2.6	2.2	2.8	4.5	4.9	4.0	4.9	4.2	4.1	3.5	2.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.0	76.7	78.4	81.9	86.3	89.2	90.8	91.2	90.4	87.8	83.7	78.9
		MCWB	69.7	70.7	72.7	76.0	79.6	81.4	80.8	81.1	80.9	79.2	76.9	72.5
	2%	DB	73.7	74.7	76.3	79.9	84.4	87.9	89.8	89.9	89.0	86.4	81.8	76.8
		MCWB	67.3	68.5	70.6	74.7	78.3	81.0	80.5	80.5	80.2	78.5	75.1	70.4
	5%	DB	72.1	72.8	74.5	78.0	82.6	86.7	89.0	88.9	88.0	85.1	80.4	75.2
		MCWB	65.7	67.0	69.1	72.9	77.3	80.6	80.2	80.2	79.6	77.6	73.7	68.6
	10%	DB	70.6	71.4	72.9	76.5	80.9	85.5	88.1	88.0	87.0	83.7	79.0	73.8
		MCWB	64.1	66.1	67.9	71.7	76.3	80.2	79.9	79.9	78.9	76.7	72.6	67.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.1	71.9	73.8	77.0	80.8	83.2	83.2	83.2	82.7	81.4	78.2	74.7
		MCDB	74.4	75.0	77.1	80.9	84.4	87.0	87.8	88.5	88.3	85.6	82.0	77.2
	2%	WB	69.3	70.2	72.0	75.6	79.2	82.1	82.2	82.3	81.7	80.0	76.7	72.4
		MCDB	72.6	73.2	74.8	78.5	82.6	85.8	87.4	87.3	86.9	84.3	80.2	75.4
	5%	WB	67.2	68.8	70.7	74.4	78.3	81.4	81.6	81.6	80.9	79.0	75.5	70.5
		MCDB	71.2	71.9	73.4	77.1	81.4	85.1	86.7	86.7	85.8	83.4	79.2	74.1
	10%	WB	65.1	67.1	69.3	73.1	77.3	80.7	80.9	80.9	80.1	78.1	74.3	68.5
		MCDB	69.6	70.7	72.1	75.6	80.3	84.3	86.0	86.1	85.0	82.5	78.1	72.8
Mean Daily Temperature Range	5% DB	MDBR	9.8	9.7	9.5	8.9	8.3	7.2	8.7	8.7	9.1	8.9	8.4	9.3
		MCDBR	11.1	10.6	10.1	9.1	8.9	8.2	9.7	9.6	9.7	9.6	9.2	10.0
		MCWBR	8.2	7.8	7.2	5.9	5.0	4.0	4.1	4.0	4.4	4.7	5.5	7.4
	5% WB	MCDBR	9.5	8.9	8.8	8.3	8.1	7.5	8.4	8.3	8.8	8.7	8.3	9.1
		MCWBR	8.8	7.6	7.4	5.9	5.1	4.2	4.1	3.9	4.3	4.7	5.8	7.9
Clear-Sky Solar Irradiance	taub	0.426	0.448	0.514	0.530	0.480	0.437	0.449	0.471	0.464	0.463	0.441	0.431	
	taud	2.270	2.222	2.032	2.053	2.280	2.459	2.415	2.344	2.339	2.303	2.327	2.267	
	Ebn at Noon	259	263	251	250	261	271	268	262	262	255	252	251	
	Edh at Noon	38	43	54	54	43	36	37	40	39	39	36	37	
All-Sky Solar Radiation	RadAvg	948	1177	1403	1575	1699	1900	2115	1973	1772	1392	1069	882	
	RadStd	86	137	127	169	208	184	145	111	108	116	80	82	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	+0.77	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page