

MINAMIDAITOJIMA, Japan

WMO: 479450

Lat: 25.8289N

Lon: 131.2286E

Elev: 21

StdP: 101.07

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.9	12.6	4.9	5.4	15.4	5.8	5.7	15.6	11.3	18.8	10.4	18.1	1.4	50	0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.8	32.2	27.0	31.7	26.8	31.2	26.7	28.1	30.7	27.7	30.3	27.4	30.0	5.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.3	23.1	29.6	27.0	22.7	29.4	26.6	22.3	29.2	90.1	30.9	88.4	30.5	86.9	30.1	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.7	9.7	8.5	DB	7.7	32.8	0.9	0.5	7.0	33.2	6.5	33.5	6.0	33.8	5.3	34.2
			WB	6.8	28.3	0.8	0.6	6.3	28.7	5.8	29.1	5.4	29.4	4.8	29.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	23.5	17.8	18.0	19.3	21.6	24.1	27.1	28.7	28.0	26.0	23.1	19.6
		DBStd	4.44	2.16	2.38	2.38	2.21	2.07	1.70	1.02	1.09	1.31	1.72	2.33
		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0
		HDD18.3	104	37	32	18	2	0	0	0	0	0	1	14
		CDD10.0	4935	242	226	287	348	438	512	580	579	539	495	392
		CDD18.3	1997	20	24	48	100	179	262	322	321	289	237	143
		CDH23.3	17846	9	16	47	241	1037	2609	3941	3910	3310	2062	599
(13)		CDH26.7	5515	0	0	1	9	128	675	1563	1549	1146	409	35
(14)	Wind	WSAvg	4.5	4.5	4.5	4.5	4.5	4.2	4.3	4.7	4.7	4.8	4.8	4.7
(15)	Precipitation	PrecAvg	1601	94	82	89	111	197	190	113	173	139	176	124
(16)		PrecMax	2666	294	305	240	287	518	584	481	668	506	491	399
(17)		PrecMin	1053	16	7	4	13	19	10	3	10	17	14	16
(18)		PrecStd	322	57	65	56	70	115	125	102	125	107	104	90
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	24.4	24.8	25.8	27.7	30.2	31.8	32.7	32.9	32.4	31.0	28.7	26.0
(20)		MCWB	21.0	21.5	22.6	24.4	26.4	27.4	27.1	27.3	27.2	26.2	24.9	22.5
(21)		DB	23.2	23.7	24.6	26.6	29.1	31.0	32.1	32.1	31.7	30.2	27.7	24.9
(22)		MCWB	19.6	20.3	21.5	23.7	25.7	27.2	26.9	26.9	26.8	25.8	24.0	21.3
(23)		DB	22.3	22.7	23.6	25.6	28.1	30.4	31.6	31.6	31.1	29.5	26.9	24.0
(24)		MCWB	18.7	19.4	20.6	22.7	25.2	27.0	26.8	26.8	26.4	25.4	23.2	20.3
(25)		DB	21.4	21.9	22.7	24.7	27.2	29.7	31.2	31.1	30.5	28.7	26.1	23.2
(26)		MCWB	17.8	18.9	19.9	22.0	24.6	26.8	26.6	26.6	26.1	24.8	22.6	19.6
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	21.7	22.2	23.2	25.0	27.1	28.4	28.4	28.5	28.2	27.4	25.7	23.7
(28)		MCDB	23.6	23.9	25.0	27.1	29.1	30.6	31.0	31.4	31.3	29.8	27.8	25.1
(29)		WB	20.7	21.2	22.2	24.2	26.2	27.8	27.9	27.9	27.6	26.7	24.8	22.4
(30)		MCDB	22.5	22.9	23.8	25.9	28.1	29.9	30.8	30.7	30.5	29.1	26.8	24.1
(31)		WB	19.5	20.4	21.5	23.6	25.7	27.4	27.5	27.6	27.2	26.1	24.2	21.4
(32)		MCDB	21.8	22.2	23.0	25.0	27.5	29.5	30.4	30.4	29.9	28.5	26.2	23.4
(33)		WB	18.4	19.5	20.7	22.9	25.2	27.0	27.2	27.2	26.7	25.6	23.5	20.3
(34)		MCDB	20.9	21.5	22.3	24.2	26.8	29.0	30.0	30.1	29.4	28.1	25.6	22.6
(35)	Mean Daily Temperature Range	MDBR	5.5	5.4	5.3	4.9	4.6	4.0	4.8	4.8	5.1	4.9	4.7	5.2
(36)		5% DB	6.2	5.9	5.6	5.1	4.9	4.5	5.4	5.3	5.4	5.3	5.1	5.5
(37)		MCWBR	4.6	4.3	4.0	3.3	2.8	2.2	2.3	2.2	2.4	2.6	3.0	4.1
(38)		5% WB	5.3	4.9	4.9	4.6	4.5	4.2	4.7	4.6	4.9	4.8	4.6	5.1
(39)		MCWBR	4.9	4.2	4.1	3.3	2.9	2.3	2.3	2.2	2.4	2.6	3.2	4.4
(40)	Clear-Sky Solar Irradiance	taub	0.426	0.448	0.514	0.530	0.480	0.437	0.449	0.471	0.464	0.463	0.441	0.431
(41)		taud	2.270	2.222	2.032	2.053	2.280	2.459	2.415	2.344	2.339	2.303	2.327	2.267
(42)		Ebn at Noon	815	828	790	788	824	855	844	827	825	804	796	791
(43)		Edh at Noon	120	134	171	171	136	113	118	126	124	123	113	116
(44)	All-Sky Solar Radiation	RadAvg	2.99	3.71	4.42	4.96	5.36	5.99	6.67	6.22	5.58	4.39	3.37	2.78
(45)		RadStd	0.27	0.43	0.40	0.53	0.66	0.58	0.46	0.35	0.34	0.37	0.25	0.26

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	+0.43	+0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page