

CHICHIJIMA, Japan

WMO: 479710

Lat: 27.0922N

Lon: 142.1914E

Elev: 27

StdP: 14.68

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 42402

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	56.0	57.8	40.6	37.3	60.4	42.3	39.8	61.0	23.8	69.3	21.4	68.8	4.4	320	0.337

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.4	87.4	79.2	86.6	79.0	85.8	78.9	81.1	84.7	80.7	84.3	80.1	83.8	7.6	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.2	156.7	83.5	79.6	153.6	83.2	79.0	150.8	83.0	44.9	84.8	44.3	84.5	43.8	84.1	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.4	18.3	15.8	DB	52.8	89.5	1.5	0.9	51.7	90.1	50.8	90.6	50.0	91.1	48.9	91.7	(4)
(5)			WB	47.6	82.0	1.3	1.1	46.6	82.7	45.9	83.4	45.2	84.0	44.2	84.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.1	64.7	64.3	66.3	69.6	74.2	79.3	82.1	82.5	81.9	79.7	74.7	68.8
	DBStd	7.34	3.01	3.38	3.50	3.52	3.45	2.99	1.62	1.50	1.70	2.28	3.34	3.64
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	133	43	50	27	5	0	0	0	0	0	0	0	8
	CDD50	8780	455	401	506	588	749	880	994	1006	958	919	741	583
	CDD65	3437	33	31	67	143	284	430	529	541	508	454	291	126
	CDH74	28721	3	3	23	182	1192	3836	5817	6175	5618	4234	1462	176
	CDH80	6725	0	0	0	1	57	716	1679	1906	1575	733	58	0
Wind	WSAvg	7.3	7.4	7.7	8.0	7.9	7.4	6.4	6.1	7.2	7.5	7.2	7.6	7.3
Precipitation	PrecAvg	50.9	2.8	2.3	2.9	4.8	5.5	4.6	3.1	5.1	5.5	5.6	4.6	3.9
	PrecMax	73.9	7.2	7.2	6.4	13.2	14.3	15.3	11.8	16.1	12.5	15.3	10.1	10.3
	PrecMin	35.0	0.9	0.1	0.2	0.5	1.3	0.2	0.0	1.2	0.6	1.4	1.0	0.4
	PrecStd	10.6	1.5	1.5	1.7	3.5	3.0	3.6	2.8	4.0	3.2	3.3	2.5	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.4	74.5	76.3	79.2	83.3	87.3	88.6	88.7	88.0	86.3	83.2	79.1
		MCWB	69.4	68.9	71.3	74.1	76.5	78.9	79.2	79.7	79.4	78.9	76.8	73.9
	2%	DB	72.7	72.7	74.4	77.4	81.6	85.9	87.3	87.3	86.8	85.1	81.6	77.4
		MCWB	67.6	67.8	69.9	73.1	76.0	78.7	79.0	79.3	79.3	78.4	75.9	72.3
	5%	DB	71.4	71.4	73.0	76.1	80.3	84.7	86.3	86.4	85.9	84.1	80.5	76.0
		MCWB	65.9	66.8	68.7	72.4	75.7	78.4	78.8	79.1	79.1	78.0	75.2	70.7
	10%	DB	70.0	70.2	71.8	74.8	79.1	83.6	85.4	85.5	85.0	83.2	79.4	74.6
		MCWB	63.5	65.2	67.7	71.4	75.2	78.2	78.6	78.9	78.8	77.6	74.2	69.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.7	70.4	72.7	75.4	78.2	81.0	81.8	81.9	81.8	80.6	78.4	75.6
		MCDB	73.4	72.8	74.9	77.7	80.5	84.4	85.1	85.2	85.2	84.0	81.0	78.0
	2%	WB	68.8	69.3	71.3	74.1	77.3	80.1	80.9	81.0	81.0	79.8	77.4	73.6
		MCDB	72.0	71.8	73.3	76.3	80.0	83.5	84.5	84.6	84.5	83.2	80.4	76.7
	5%	WB	66.9	67.9	70.1	73.2	76.5	79.5	80.1	80.6	80.4	79.1	76.4	71.9
		MCDB	70.7	71.0	72.3	75.4	79.2	82.9	84.0	84.3	84.0	82.6	79.7	75.2
	10%	WB	64.8	66.1	68.6	72.2	75.7	78.9	79.7	80.0	79.8	78.5	75.4	70.1
		MCDB	69.2	69.7	71.3	74.4	78.5	82.3	83.7	83.9	83.6	82.1	78.8	74.0
Mean Daily Temperature Range	5% DB	MDBR	7.6	7.6	7.5	6.9	6.4	6.3	7.1	6.4	6.3	6.4	6.6	7.1
		MCDBR	8.5	8.3	7.8	7.1	7.1	7.6	8.2	7.6	7.1	7.2	6.7	7.6
		MCWBR	8.2	7.6	6.9	5.1	4.0	3.5	3.5	3.4	3.4	3.7	4.7	6.5
	5% WB	MCDBR	8.0	7.5	7.0	6.5	6.3	6.5	6.8	6.2	6.2	6.2	6.4	7.0
MCWBR		8.8	8.1	7.0	5.5	4.1	3.7	3.5	3.3	3.5	3.8	5.0	7.1	
Clear-Sky Solar Irradiance	taub	0.391	0.408	0.463	0.487	0.458	0.416	0.429	0.434	0.432	0.422	0.410	0.404	
	taud	2.393	2.346	2.186	2.170	2.347	2.508	2.467	2.455	2.456	2.474	2.460	2.384	
	Ebn at Noon	269	274	264	261	267	277	273	272	270	267	262	259	
	Edh at Noon	33	37	46	48	40	34	36	36	35	33	31	32	
All-Sky Solar Radiation	RadAvg	1011	1290	1516	1660	1750	2030	2140	2010	1807	1475	1131	903	
	RadStd	64	102	113	190	190	212	108	103	99	82	78	82	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page