

CHICHIJIMA, Japan

WMO: 479710

Lat: 27.0922N

Lon: 142.1914E

Elev: 8

StdP: 101.23

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 42402

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	13.3	14.3	4.8	5.3	15.8	5.7	5.7	16.1	10.6	20.7	9.6	20.4	2.0	320	0.337

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	3.6	30.8	26.2	30.3	26.1	29.9	26.0	27.3	29.3	27.0	29.1	26.7	28.8	3.4	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.8	22.4	28.6	26.4	21.9	28.5	26.1	21.5	28.3	86.6	29.3	85.2	29.1	84.0	28.9	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.5	8.2	7.1	11.5	31.9	0.8	0.5	10.9	32.3	10.5	32.5	10.0	32.8	9.4	33.2		
(5)			8.6	27.8	0.7	0.6	8.1	28.2	7.7	28.5	7.3	28.9	6.8	29.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.4	18.1	18.0	19.1	20.9	23.4	26.3	27.8	28.0	27.7	26.5	23.7	20.4
	DBStd	4.08	1.67	1.88	1.94	1.96	1.92	1.66	0.90	0.83	0.94	1.27	1.85	2.02
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	74	24	28	15	3	0	0	0	0	0	0	0	4
	CDD10.0	4878	253	223	281	327	416	489	552	559	532	511	412	324
	CDD18.3	1909	18	17	37	79	158	239	294	301	282	252	162	70
	CDH23.3	15956	2	2	13	101	662	2131	3232	3431	3121	2352	812	98
CDH26.7	3736	0	0	0	1	32	398	933	1059	875	407	32	0	
Wind	WSAvg	3.3	3.3	3.4	3.6	3.5	3.3	2.9	2.7	3.2	3.3	3.2	3.4	3.3
Precipitation	PrecAvg	1294	70	58	73	121	139	118	78	129	140	142	116	100
	PrecMax	1878	183	184	163	335	362	388	300	409	317	388	257	262
	PrecMin	890	23	2	4	12	34	4	1	31	15	36	26	9
	PrecStd	270	39	38	44	90	76	92	72	102	81	83	63	56
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.5	23.6	24.6	26.2	28.5	30.7	31.5	31.5	31.1	30.2	28.4	26.2
		MCWB	20.8	20.5	21.8	23.4	24.7	26.1	26.2	26.5	26.3	26.1	24.9	23.3
	2%	DB	22.6	22.6	23.5	25.2	27.5	29.9	30.7	30.7	30.5	29.5	27.6	25.2
		MCWB	19.8	19.9	21.0	22.8	24.4	26.0	26.1	26.3	26.3	25.8	24.4	22.4
	5%	DB	21.9	21.9	22.8	24.5	26.8	29.3	30.2	30.2	30.0	29.0	26.9	24.4
		MCWB	18.9	19.3	20.4	22.4	24.3	25.8	26.0	26.2	26.2	25.5	24.0	21.5
	10%	DB	21.1	21.2	22.1	23.8	26.2	28.7	29.7	29.7	29.5	28.5	26.4	23.7
		MCWB	17.5	18.5	19.8	21.9	24.0	25.7	25.9	26.1	26.0	25.3	23.4	20.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.5	21.4	22.6	24.1	25.7	27.2	27.6	27.7	27.7	27.0	25.8	24.2
		MCDB	23.0	22.7	23.8	25.4	27.0	29.1	29.5	29.6	29.6	28.9	27.2	25.5
	2%	WB	20.4	20.7	21.8	23.4	25.2	26.7	27.2	27.2	27.2	26.6	25.2	23.1
		MCDB	22.2	22.1	23.0	24.6	26.6	28.6	29.2	29.2	29.2	28.5	26.9	24.8
	5%	WB	19.4	19.9	21.2	22.9	24.7	26.4	26.7	27.0	26.9	26.2	24.7	22.1
		MCDB	21.5	21.6	22.4	24.1	26.2	28.3	28.9	29.1	28.9	28.1	26.5	24.0
	10%	WB	18.2	18.9	20.4	22.3	24.3	26.1	26.5	26.7	26.6	25.8	24.1	21.1
		MCDB	20.7	20.9	21.8	23.6	25.8	27.9	28.7	28.8	28.7	27.9	26.0	23.3
Mean Daily Temperature Range	5% DB	MDBR	4.2	4.2	4.2	3.8	3.6	3.5	4.0	3.6	3.5	3.6	3.7	3.9
		MCDBR	4.7	4.6	4.3	3.9	4.0	4.2	4.6	4.2	3.9	4.0	3.7	4.2
		MCWBR	4.6	4.2	3.8	2.9	2.2	1.9	2.0	1.9	1.9	2.1	2.6	3.6
	5% WB	MCDBR	4.4	4.2	3.9	3.6	3.5	3.6	3.8	3.4	3.4	3.5	3.6	3.9
		MCWBR	4.9	4.5	3.9	3.0	2.3	2.0	1.9	1.8	1.9	2.1	2.8	3.9
Clear-Sky Solar Irradiance	taub	0.391	0.408	0.463	0.487	0.458	0.416	0.429	0.434	0.432	0.422	0.410	0.404	
	taud	2.393	2.346	2.186	2.170	2.347	2.508	2.467	2.455	2.456	2.474	2.460	2.384	
	Ebn at Noon	849	864	833	822	842	872	861	857	851	841	826	817	
	Edh at Noon	104	118	145	152	127	108	112	113	110	103	98	102	
All-Sky Solar Radiation	RadAvg	3.19	4.07	4.78	5.23	5.52	6.40	6.75	6.34	5.70	4.65	3.56	2.85	
	RadStd	0.20	0.32	0.36	0.60	0.60	0.67	0.34	0.33	0.31	0.26	0.25	0.26	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page