

YANGON, Myanmar

WMO: 480970

Lat: 16.8647N

Lon: 96.1536E

Elev: 66

StdP: 14.66

Time Zone: 6.50 (MYR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	63.6	65.8	53.6	61.2	84.8	56.9	69.1	79.6	11.8	81.1	10.9	82.6	3.4	40	0.319

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	21.0	100.7	78.6	98.9	78.1	97.1	77.6	83.5	92.0	82.6	90.8	81.9	89.6	6.7	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.0	161.6	86.6	80.8	160.5	86.1	80.5	158.9	85.4	47.4	92.3	46.6	89.6	45.8	90.0	91.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.0	11.2	10.0		59.7	103.6	1.7	1.6	58.5	104.8	57.5	105.8	56.6	106.7	55.4	107.9
			DB	57.3	86.2	1.8	1.4	56.0	87.2	54.9	88.0	53.9	88.8	52.5	89.8
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.5	78.2	81.5	85.2	88.5	85.5	82.0	81.1	81.0	81.9	83.4	82.5	79.3
	DBStd	3.71	2.75	2.69	2.17	2.34	4.04	2.11	2.10	2.01	2.15	1.96	2.50	2.99
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11868	875	883	1091	1155	1100	961	965	960	958	1036	974	910
	CDD65	6393	410	463	626	705	635	511	500	495	508	571	524	445
	CDH74	67596	3796	4969	7473	9450	7512	4903	4468	4348	4857	6118	5519	4183
	CDH80	28323	1670	2610	4080	5389	3533	1362	1040	948	1386	2264	2277	1764
Wind	WSAvg	4.6	3.8	4.1	4.9	5.5	5.4	5.0	5.1	5.0	4.5	4.1	4.1	4.0
Precipitation	PrecAvg	105.0	0.0	0.2	0.4	1.1	11.5	22.0	23.1	22.3	14.4	7.5	1.3	0.2
	PrecMax	127.1	0.9	2.6	4.9	12.2	17.9	28.3	31.9	32.1	23.6	14.1	9.2	1.6
	PrecMin	84.1	0.0	0.0	0.0	0.0	1.8	14.7	15.0	14.5	1.7	1.9	0.1	0.0
	PrecStd	13.0	0.2	0.5	1.1	2.5	4.2	3.6	5.2	4.7	5.6	3.4	2.0	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.6	98.7	100.6	104.1	103.6	91.8	91.5	90.9	91.8	93.6	94.8	93.4
		MCWB	72.7	74.6	76.6	78.7	80.8	81.3	80.7	80.9	80.9	81.2	79.6	76.9
	2%	DB	91.8	96.7	98.8	102.0	100.0	89.9	89.4	88.2	89.9	92.2	93.0	91.7
		MCWB	72.4	74.2	76.0	78.3	80.5	80.8	80.6	80.8	80.9	80.5	78.8	75.5
	5%	DB	90.4	94.9	97.2	100.3	97.0	88.2	87.5	86.4	88.2	91.2	91.5	90.0
		MCWB	72.3	73.7	76.1	78.8	80.9	80.8	80.4	79.6	80.7	80.1	77.9	74.9
	10%	DB	89.0	92.8	95.4	98.4	93.5	86.4	85.7	84.6	86.4	89.5	89.9	88.7
		MCWB	72.3	73.0	76.1	78.5	81.0	79.8	79.4	79.5	79.7	80.5	78.1	74.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.6	81.8	83.2	84.0	84.4	83.4	82.7	82.7	83.4	84.0	83.7	81.0
		MCDB	87.7	92.2	95.5	96.6	94.4	89.3	88.0	87.6	89.2	91.5	90.9	88.6
	2%	WB	77.5	79.0	80.6	82.3	83.0	82.1	81.3	81.4	82.0	82.8	81.8	79.2
		MCDB	86.5	90.2	93.8	95.8	92.5	87.5	85.9	85.8	87.7	89.9	89.4	87.6
	5%	WB	75.7	76.7	79.4	81.0	82.0	81.0	80.4	80.4	80.8	81.6	80.0	77.9
		MCDB	85.0	88.7	91.1	93.6	91.2	85.7	84.6	84.3	86.0	88.2	87.5	86.5
	10%	WB	74.2	75.4	78.3	80.2	81.0	80.1	79.8	79.7	80.0	80.2	79.4	76.3
		MCDB	83.8	86.8	89.0	91.9	89.8	84.3	83.5	83.2	84.5	85.8	86.4	84.5
Mean Daily Temperature Range	5% DB	MDBR	22.7	24.6	23.3	21.0	14.5	10.2	9.3	8.9	10.2	12.8	16.2	20.4
		MCDBR	24.3	26.3	24.9	23.2	19.4	12.3	11.9	11.2	12.5	15.1	17.6	21.0
		MCWBR	9.4	9.0	7.9	6.7	6.0	5.7	5.4	5.2	5.5	6.5	7.0	8.5
	5% WB	MCDBR	21.0	24.3	23.0	21.0	16.2	11.1	10.2	9.8	11.2	13.9	15.6	18.8
		MCWBR	11.1	10.8	8.9	6.9	6.6	5.7	5.4	5.2	5.5	6.6	7.1	9.7
Clear-Sky Solar Irradiance	taub	0.448	0.476	0.541	0.554	0.540	0.497	0.483	0.479	0.464	0.513	0.469	0.453	
	taud	2.175	2.111	1.952	1.994	2.079	2.221	2.270	2.282	2.326	2.136	2.216	2.195	
	Ebn at Noon	264	263	250	246	246	255	259	262	267	250	257	259	
	Edh at Noon	45	50	61	58	53	45	43	43	41	49	43	43	
All-Sky Solar Radiation	RadAvg	1597	1847	1982	2020	1539	1230	1162	1153	1337	1542	1597	1533	
	RadStd	49	41	89	136	141	92	121	78	91	90	83	58	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page