

YANGON, Myanmar

WMO: 480970

Lat: 16.8647N

Lon: 96.1536E

Elev: 20

StdP: 101.08

Time Zone: 6.50 (MYR)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.6	18.8	12.0	8.7	29.4	13.8	9.9	26.4	5.3	27.3	4.9	28.1	1.5	40	0.319

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	11.7	38.2	25.9	37.2	25.6	36.2	25.3	28.6	33.3	28.1	32.7	27.7	32.0	3.0	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.2	23.1	30.3	27.1	22.9	30.1	27.0	22.7	29.6	92.4	33.5	90.5	32.0	88.7	32.2	32.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.4	5.0	4.5	15.4	39.8	0.9	0.9	14.7	40.4	14.2	41.0	13.7	41.5	13.0	42.2
			14.1	30.1	1.0	0.8	13.3	30.7	12.7	31.1	12.1	31.6	11.4	32.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	25.7	27.5	29.5	31.4	29.7	27.8	27.3	27.2	27.7	28.6	28.0	26.3	(6)
(7)		DBStd	2.06	1.53	1.50	1.21	1.30	2.25	1.17	1.16	1.12	1.20	1.09	1.39	1.66	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6593	486	491	606	642	611	534	536	533	532	576	541	506	(10)
(11)		CDD18.3	3552	228	257	348	392	353	284	278	275	282	317	291	247	(11)
(12)		CDH23.3	37553	2109	2761	4152	5250	4173	2724	2482	2416	2698	3399	3066	2324	(12)
(13)	CDH26.7	15735	928	1450	2267	2994	1963	757	578	527	770	1258	1265	980	(13)	
(14)	Wind	WSAvg	2.1	1.7	1.8	2.2	2.4	2.4	2.2	2.3	2.2	2.0	1.8	1.8	(14)	
(15)	Precipitation	PrecAvg	2668	1	4	11	27	291	558	588	566	367	191	34	5	(15)
(16)		PrecMax	3229	22	65	125	310	454	718	810	815	600	357	233	41	(16)
(17)		PrecMin	2135	0	0	0	0	45	374	382	368	43	48	2	0	(17)
(18)		PrecStd	331	4	13	28	64	107	91	131	120	142	86	51	9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.2	37.1	38.1	40.0	39.8	33.2	33.1	32.7	33.2	34.2	34.9	34.1	(19)
(20)		MCWB	22.6	23.6	24.8	25.9	27.1	27.4	27.1	27.2	27.2	27.4	26.4	24.9	(20)	
(21)		2%	DB	33.2	35.9	37.1	38.9	37.8	32.2	31.9	31.2	32.2	33.4	33.9	33.2	(21)
(22)		MCWB	22.4	23.4	24.5	25.7	26.9	27.1	27.0	27.1	27.1	27.0	26.0	24.1	(22)	
(23)		5%	DB	32.5	34.9	36.2	37.9	36.1	31.2	30.8	30.2	31.2	32.9	33.1	32.2	(23)
(24)		MCWB	22.4	23.1	24.5	26.0	27.2	27.1	26.9	26.5	27.1	26.7	25.5	23.8	(24)	
(25)		10%	DB	31.7	33.8	35.2	36.9	34.1	30.2	29.8	29.2	30.2	31.9	32.2	31.5	(25)
(26)		MCWB	22.4	22.8	24.5	25.8	27.2	26.5	26.3	26.4	26.5	26.9	25.6	23.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.4	27.7	28.4	28.9	29.1	28.6	28.2	28.2	28.5	28.9	28.7	27.2	(27)
(28)		MCDWB	31.0	33.5	35.3	35.9	34.7	31.8	31.1	30.9	31.8	33.1	32.7	31.5	(28)	
(29)		2%	WB	25.3	26.1	27.0	28.0	28.3	27.9	27.4	27.4	27.8	28.2	27.7	26.2	(29)
(30)		MCDWB	30.3	32.4	34.3	35.4	33.6	30.8	30.0	29.9	31.0	32.2	31.9	30.9	(30)	
(31)		5%	WB	24.3	24.8	26.4	27.2	27.8	27.2	26.9	26.9	27.1	27.6	26.7	25.5	(31)
(32)		MCDWB	29.4	31.5	32.8	34.2	32.9	29.8	29.2	29.0	30.0	31.2	30.8	30.3	(32)	
(33)		10%	WB	23.5	24.1	25.7	26.8	27.2	26.7	26.6	26.5	26.7	26.8	26.3	24.6	(33)
(34)		MCDWB	28.8	30.4	31.7	33.3	32.1	29.0	28.6	28.4	29.2	29.9	30.2	29.2	(34)	
(35)	Mean Daily Temperature Range		MDBR	12.6	13.7	13.0	11.7	8.1	5.6	5.2	4.9	5.7	7.1	9.0	11.3	(35)
(36)		5% DB	MCDBR	13.5	14.6	13.8	12.9	10.8	6.8	6.6	6.2	7.0	8.4	9.8	11.7	(36)
(37)		MCWBR	5.2	5.0	4.4	3.7	3.3	3.1	3.0	2.9	3.1	3.6	3.9	4.7	(37)	
(38)		5% WB	MCDBR	11.7	13.5	12.8	11.6	9.0	6.2	5.6	5.5	6.2	7.7	8.7	10.4	(38)
(39)		MCWBR	6.2	6.0	5.0	3.8	3.7	3.2	3.0	2.9	3.1	3.7	4.0	5.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.448	0.476	0.541	0.554	0.540	0.497	0.483	0.479	0.464	0.513	0.469	0.453	(40)	
(41)		taud	2.175	2.111	1.952	1.994	2.079	2.221	2.270	2.282	2.326	2.136	2.216	2.195	(41)	
(42)		Ebn at Noon	833	830	787	777	777	803	816	826	842	787	809	816	(42)	
(43)		Edh at Noon	142	158	191	184	167	143	137	136	130	153	136	136	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.04	5.82	6.25	6.37	4.85	3.88	3.66	3.63	4.22	4.86	5.04	4.83	(44)	
(45)		RadStd	0.16	0.13	0.28	0.43	0.44	0.29	0.38	0.25	0.29	0.28	0.26	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page