

NAN AGROMET, Thailand

WMO: 483330

Lat: 18.8641N

Lon: 100.7416E

Elev: 265

StdP: 98.18

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.8	13.6	9.2	7.5	16.7	11.1	8.5	17.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	9.6	37.4	24.8	36.1	24.6	35.0	24.8	27.2	32.6	26.9	32.1	26.6	31.6	N/A	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	22.1	30.0	25.6	21.6	29.5	25.3	21.1	29.0	88.4	32.6	86.6	32.3	85.2	31.9	31.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) N/A	N/A	N/A	DB	8.3	38.7	2.0	1.6	6.9	39.9	5.7	40.8	4.6	41.7	3.1	42.9	(4)
(5)			WB	8.2	28.5	2.2	1.0	6.6	29.2	5.4	29.8	4.1	30.4	2.6	31.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.3	21.9	24.1	26.5	28.8	28.9	28.4	27.6	27.4	27.7	27.0	25.2	22.3	(6)	
	DBStd	2.91	2.36	1.87	2.14	1.80	1.65	1.39	1.39	1.12	1.02	1.23	1.99	2.39	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	8	4	0	1	0	0	0	0	0	0	0	0	3	(9)	
	CDD10.0	5956	369	393	511	563	585	553	547	539	531	528	454	383	(10)	
	CDD18.3	2922	115	160	253	313	327	303	288	281	281	270	204	127	(11)	
	CDH23.3	29661	931	1609	2817	3644	3649	3445	2952	2695	2754	2484	1732	948	(12)	
(13)	CDH26.7	12239	281	727	1510	1977	1713	1393	995	825	938	930	666	284	(13)	
(14)	Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(14)	
(15) Precipitation	PrecAvg	1317	12	10	42	96	180	145	225	287	217	69	22	13	(15)	
	PrecMax	1933	60	74	155	229	385	277	397	559	393	126	150	94	(16)	
	PrecMin	1013	0	0	0	22	66	58	94	132	123	7	0	0	(17)	
	PrecStd	206	17	16	39	49	78	57	76	102	67	28	30	23	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.8	35.0	37.6	39.5	38.6	36.4	35.4	33.5	33.8	34.0	33.6	32.0	(19)	
		MCWB	21.8	22.2	22.7	25.0	26.1	26.4	25.8	26.5	26.4	25.8	24.8	22.9	(20)	
	2%	DB	30.7	33.7	36.2	37.9	36.6	34.7	33.7	32.3	32.8	33.0	32.5	30.8	(21)	
		MCWB	21.4	22.1	22.9	24.9	25.9	26.3	26.1	26.3	26.3	25.6	24.6	22.7	(22)	
	5%	DB	29.6	32.5	35.3	36.6	35.1	33.4	32.2	31.4	32.0	32.2	31.6	29.7	(23)	
		MCWB	21.0	22.0	23.0	24.9	25.9	26.2	26.1	26.1	26.1	25.5	24.2	22.1	(24)	
	10%	DB	28.4	31.2	33.9	35.1	33.6	32.2	31.0	30.5	31.1	31.3	30.6	28.4	(25)	
		MCWB	20.7	21.6	22.9	24.9	25.9	26.1	25.9	25.9	25.9	25.2	23.8	21.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.9	24.5	25.8	27.6	27.7	27.6	27.2	27.5	27.5	27.1	26.0	25.1	(27)	
		MCDB	29.3	31.9	33.6	34.9	34.0	33.4	32.1	31.6	31.9	31.6	31.6	29.8	(28)	
	2%	WB	22.7	23.7	24.8	26.6	27.0	27.0	26.7	26.8	26.9	26.2	25.4	24.1	(29)	
		MCDB	28.1	30.9	33.0	34.3	33.5	32.4	31.3	30.8	31.3	31.0	30.7	28.4	(30)	
	5%	WB	22.0	23.0	24.2	26.0	26.5	26.6	26.3	26.4	26.5	25.9	25.0	23.1	(31)	
		MCDB	27.1	30.0	32.3	33.7	32.8	31.6	30.7	30.3	30.7	30.5	30.0	27.6	(32)	
	10%	WB	21.4	22.3	23.6	25.4	26.1	26.2	26.0	26.1	26.1	25.6	24.5	22.3	(33)	
		MCDB	26.4	29.2	31.4	32.9	32.1	30.9	30.1	29.8	30.1	29.9	29.1	26.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	13.6	15.7	15.2	12.8	9.6	7.5	6.5	6.4	7.4	9.0	11.4	12.7	(35)	
		MCDBR	15.2	17.5	17.6	15.3	12.3	9.6	8.8	7.9	8.6	10.4	12.2	13.5	(36)	
		MCWBR	6.4	6.7	5.8	4.4	3.3	2.6	2.6	2.8	3.0	3.8	4.9	5.9	(37)	
	5% WB	MCDBR	12.5	15.2	15.1	13.3	10.5	8.4	7.5	7.2	8.0	9.2	10.9	11.5	(38)	
		MCWBR	5.6	6.1	5.6	4.8	3.6	2.8	2.8	2.9	3.1	3.7	4.7	5.5	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.438	0.537	0.685	0.653	0.491	0.442	0.437	0.454	0.481	0.518	0.425	0.424	(40)	
	taud		2.200	1.936	1.623	1.744	2.212	2.378	2.383	2.317	2.225	2.079	2.301	2.263	(41)	
	Ebn at Noon		836	768	674	702	817	850	855	846	824	776	844	837	(42)	
	Edh at Noon		136	187	264	236	146	123	122	131	143	160	122	125	(43)	
(44) All-Sky Solar Radiation	RadAvg		4.45	5.13	5.33	5.79	5.29	4.74	4.36	4.32	4.56	4.58	4.61	4.25	(44)	
	RadStd		0.26	0.25	0.31	0.39	0.48	0.36	0.35	0.28	0.21	0.23	0.28	0.25	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (15 neighbors)	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+147	+149

Nomenclature: See separate page