

LOMSAK, Thailand

WMO: 483740

Lat: 16.7736N

Lon: 101.2453E

Elev: 476

StdP: 14.45

Time Zone: 7.00 (E07)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	59.0	61.9	47.0	48.6	66.9	51.0	56.4	69.5	9.5	82.1	8.4	82.5	0.1	N/A	0.300

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	20.1	99.8	77.7	97.8	77.5	96.0	77.2	81.6	92.4	80.8	90.9	80.1	89.6	3.1	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.0	153.4	86.4	78.3	149.7	85.0	77.8	147.3	84.3	45.8	92.5	44.9	90.8	44.2	90.1	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.3	8.0	7.2	DB	54.5	103.3	3.5	1.8	52.0	104.6	49.9	105.7	48.0	106.7	45.4	108.0	
			WB	50.8	83.3	3.7	1.6	48.2	84.5	46.0	85.4	44.0	86.4	41.3	87.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.1	76.9	80.5	83.9	86.7	85.6	84.6	82.9	82.3	82.7	82.2	80.2	76.9
	DBStd	4.28	3.94	3.57	3.52	3.14	2.94	2.48	2.53	2.18	1.94	2.18	3.41	4.32
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	1	1	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11718	835	853	1051	1100	1104	1039	1019	1001	980	997	905	834
	CDD65	6244	371	433	586	650	639	589	554	536	530	532	455	369
	CDH74	67309	3397	4534	6895	8130	7512	6814	5929	5471	5310	5392	4513	3412
	CDH80	29676	1415	2243	3664	4430	3574	2977	2198	1824	1829	2167	1977	1378
(14) Wind	WSAvg	0.8	0.6	0.6	0.8	0.9	1.0	1.4	1.4	1.3	0.6	0.4	0.5	0.6
(15) Precipitation	PrecAvg	42.5	0.3	0.7	1.7	2.6	5.8	5.2	5.9	8.0	8.3	3.3	0.6	0.2
	PrecMax	56.5	1.9	3.1	6.7	7.0	10.6	10.4	10.2	16.0	15.2	10.3	3.9	1.6
	PrecMin	25.9	0.0	0.0	0.1	0.4	0.8	2.1	2.4	3.2	3.1	0.0	0.0	0.0
	PrecStd	7.8	0.5	0.7	1.7	1.7	2.4	2.2	1.8	3.1	2.9	2.2	0.9	0.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.0	97.7	101.2	103.4	100.6	98.0	96.7	93.3	93.9	94.7	95.2	94.3
		MCWB	72.4	74.0	75.0	79.0	80.3	78.4	78.0	79.5	79.0	77.6	76.0	74.5
	2%	DB	91.8	95.4	98.7	100.6	97.6	95.0	93.0	91.1	91.8	92.5	93.3	92.0
		MCWB	72.4	73.9	75.3	78.5	79.4	78.9	78.9	79.3	79.1	77.4	75.9	73.7
	5%	DB	90.0	93.6	96.6	98.4	95.4	93.0	90.7	89.4	90.0	91.2	91.6	89.9
		MCWB	71.8	73.8	75.9	78.5	79.1	78.9	78.7	79.0	78.9	77.1	75.3	73.1
	10%	DB	87.8	91.5	94.6	96.1	93.1	91.1	88.8	87.7	88.3	89.6	89.6	87.6
		MCWB	71.0	73.4	75.6	78.2	78.9	78.9	78.5	78.5	78.7	76.8	74.3	72.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.0	78.3	80.0	83.3	83.1	81.8	81.7	81.2	81.2	80.5	79.0	78.1
		MCDB	88.3	91.4	94.6	98.3	95.4	91.1	90.2	89.2	89.7	89.8	90.7	88.0
	2%	WB	75.2	77.1	78.6	81.4	81.1	80.8	80.1	80.1	80.4	79.4	78.0	76.2
		MCDB	86.1	90.8	92.6	95.8	92.4	89.8	88.2	87.9	88.4	88.3	89.1	86.8
	5%	WB	73.9	76.0	77.6	80.0	80.2	80.1	79.4	79.6	79.8	78.8	77.0	74.9
		MCDB	84.8	89.3	91.9	94.1	91.1	88.8	87.2	86.9	87.2	87.4	87.6	85.7
	10%	WB	72.7	74.9	76.7	78.8	79.4	79.4	78.9	79.0	79.1	78.1	76.1	73.6
		MCDB	83.6	87.6	90.9	93.0	89.7	87.9	86.5	85.8	86.0	86.0	85.7	84.4
(35) Mean Daily Temperature Range	5% DB	MDBR	22.7	23.4	22.2	20.1	15.9	13.9	11.9	11.4	12.5	15.4	19.4	21.4
		MCDBR	25.2	26.2	25.5	22.8	19.0	16.2	15.0	13.9	14.9	17.7	21.3	23.3
	5% WB	MCWBR	9.0	8.9	8.0	6.8	5.0	4.1	4.2	4.5	4.7	5.2	6.5	7.7
		MCWBR	20.8	22.4	21.9	21.4	17.0	14.6	13.1	12.8	13.6	15.1	19.2	20.0
(40) Clear-Sky Solar Irradiance	taub		0.469	0.572	0.656	0.608	0.494	0.445	0.434	0.444	0.483	0.526	0.450	0.450
		taud	2.123	1.874	1.711	1.863	2.213	2.370	2.397	2.351	2.228	2.070	2.264	2.201
	Ebn at Noon		258	237	222	233	258	268	272	272	262	246	263	260
		Edh at Noon	48	64	77	67	46	39	38	40	45	52	41	43
(44) All-Sky Solar Radiation	RadAvg		1487	1620	1662	1785	1670	1568	1454	1406	1414	1479	1532	1454
	RadStd		101	75	104	92	105	113	91	79	85	106	69	56

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (19 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+189	+191

Nomenclature: See separate page