

LOMSAK, Thailand

WMO: 483740

Lat: 16.7736N

Lon: 101.2453E

Elev: 145

StdP: 99.60

Time Zone: 7.00 (E07)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.0	16.6	8.4	6.9	19.4	10.6	8.1	20.8	4.3	27.8	3.8	28.0	0.0	N/A	0.300

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	11.2	37.7	25.4	36.6	25.3	35.6	25.1	27.6	33.6	27.1	32.7	26.7	32.0	1.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	21.9	30.2	25.7	21.4	29.4	25.5	21.0	29.0	88.8	33.6	86.5	32.6	84.9	32.3	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
4.2	3.6	3.2	DB	12.5	39.6	1.9	1.0	11.1	40.3	10.0	40.9	8.9	41.5	7.5	42.2	
			WB	10.5	28.5	2.1	0.9	9.0	29.2	7.8	29.7	6.6	30.2	5.2	30.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	25.0	26.9	28.8	30.4	29.8	29.2	28.3	27.9	28.2	27.9	26.8	24.9
	DBStd	2.38	2.19	1.99	1.96	1.75	1.63	1.38	1.40	1.21	1.08	1.21	1.89	2.40
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	1	1	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6510	464	474	584	611	613	577	566	556	544	554	503	463
	CDD18.3	3469	206	241	326	361	355	327	308	298	294	296	253	205
	CDH23.3	37394	1887	2519	3831	4517	4173	3786	3294	3039	2950	2996	2507	1896
	CDH26.7	16487	786	1246	2036	2461	1986	1654	1221	1013	1016	1204	1098	766
Wind	WSAvg	0.4	0.2	0.3	0.4	0.4	0.4	0.6	0.6	0.6	0.3	0.2	0.2	0.2
Precipitation	PrecAvg	1079	7	17	43	65	148	132	149	203	210	83	15	6
	PrecMax	1434	47	78	169	178	269	263	260	407	385	262	99	40
	PrecMin	659	0	0	2	11	21	54	60	82	79	0	0	0
	PrecStd	197	13	19	43	44	60	56	45	78	74	56	22	10
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.5	36.5	38.5	39.7	38.1	36.7	35.9	34.0	34.4	34.8	35.1	34.6
		MCWB	22.4	23.3	23.9	26.1	26.9	25.8	25.6	26.4	26.1	25.4	24.4	23.6
	2%	DB	33.2	35.2	37.0	38.1	36.4	35.0	33.9	32.8	33.2	33.6	34.0	33.4
		MCWB	22.4	23.3	24.1	25.8	26.4	26.1	26.0	26.3	26.1	25.2	24.4	23.2
	5%	DB	32.2	34.2	35.9	36.9	35.2	33.9	32.6	31.9	32.2	32.9	33.1	32.2
		MCWB	22.1	23.2	24.4	25.8	26.2	26.1	25.9	26.1	26.1	25.1	24.1	22.8
	10%	DB	31.0	33.1	34.8	35.6	33.9	32.8	31.6	30.9	31.3	32.0	32.0	30.9
		MCWB	21.7	23.0	24.2	25.6	26.0	26.1	25.8	25.8	25.9	24.9	23.5	22.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.0	25.7	26.7	28.5	28.4	27.7	27.6	27.3	27.3	27.0	26.1	25.6
		MCDB	31.3	33.0	34.8	36.9	35.2	32.8	32.3	31.8	32.0	32.1	32.6	31.1
	2%	WB	24.0	25.1	25.9	27.4	27.3	27.1	26.7	26.7	26.9	26.3	25.5	24.6
		MCDB	30.1	32.6	33.7	35.4	33.6	32.1	31.2	31.1	31.3	31.3	31.7	30.4
	5%	WB	23.3	24.5	25.4	26.7	26.8	26.7	26.3	26.4	26.5	26.0	25.0	23.8
		MCDB	29.3	31.8	33.3	34.5	32.8	31.5	30.7	30.5	30.7	30.8	30.9	29.8
	10%	WB	22.6	23.8	24.9	26.0	26.3	26.3	26.0	26.1	26.2	25.6	24.5	23.1
		MCDB	28.7	30.9	32.7	33.9	32.1	31.0	30.3	29.9	30.0	30.0	29.8	29.1
Mean Daily Temperature Range	5% DB	MDBR	12.6	13.0	12.3	11.2	8.9	7.7	6.6	6.4	6.9	8.6	10.8	11.9
		MCDBR	14.0	14.6	14.2	12.7	10.6	9.0	8.3	7.7	8.3	9.9	11.8	13.0
		MCWBR	5.0	5.0	4.5	3.8	2.8	2.3	2.4	2.5	2.6	2.9	3.6	4.3
	5% WB	MCDBR	11.6	12.4	12.2	11.9	9.5	8.1	7.3	7.1	7.5	8.4	10.6	11.1
		MCWBR	4.5	4.6	4.3	4.2	3.0	2.6	2.6	2.6	2.7	2.8	3.6	4.3
Clear-Sky Solar Irradiance	taub		0.469	0.572	0.656	0.608	0.494	0.445	0.434	0.444	0.483	0.526	0.450	0.450
	taud		2.123	1.874	1.711	1.863	2.213	2.370	2.397	2.351	2.228	2.070	2.264	2.201
	Ebn at Noon		813	746	699	736	814	846	857	856	825	776	828	819
	Edh at Noon		150	201	243	210	146	123	120	127	143	163	129	135
All-Sky Solar Radiation	RadAvg		4.69	5.11	5.24	5.63	5.27	4.94	4.58	4.43	4.46	4.66	4.83	4.58
	RadStd		0.32	0.24	0.33	0.29	0.33	0.36	0.29	0.25	0.27	0.33	0.22	0.18

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)	+0.25	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+105	+106

Nomenclature: See separate page