

PICHIT AGROMET, Thailand

WMO: 483860

Lat: 16.3386N

Lon: 100.3669E

Elev: 129

StdP: 14.63

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	61.4	64.8	54.4	63.2	70.0	57.7	71.3	73.3	12.7	80.5	10.7	79.6	0.9	N/A	0.323

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	17.8	100.8	79.1	98.4	79.1	96.3	79.1	82.8	91.0	82.1	90.7	81.6	90.1	4.2	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.0	161.6	86.3	80.1	157.1	85.6	79.6	154.4	85.3	46.9	91.2	46.1	91.0	45.5	90.5	90.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max					
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.0	9.9	8.3	DB	57.1	101.8	3.5	3.0	54.6	103.9	52.6	105.7	50.6	107.3	48.1	109.5	
			WB	55.6	85.8	3.4	2.4	53.2	87.5	51.2	88.9	49.4	90.3	46.9	92.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.2	77.4	81.1	84.7	88.1	87.1	85.3	83.9	83.5	83.7	83.7	81.9	77.9
	DBStd	4.41	4.36	3.02	3.83	3.58	3.36	2.40	2.36	1.72	1.94	2.23	3.09	4.24
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	1	1	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12111	849	870	1076	1142	1149	1059	1050	1038	1011	1044	958	865
	CDD65	6637	385	450	611	692	684	609	585	573	561	579	508	400
	CDH74	75693	3310	4621	7308	9417	8985	7456	6645	6375	6353	6484	5233	3506
Wind	WSAvg	2.1	1.4	1.9	2.8	3.2	3.2	2.9	2.2	2.2	1.8	1.4	1.3	1.3
	PrecAvg	49.0	0.3	0.5	1.6	2.5	6.5	5.9	6.9	8.4	9.9	5.0	1.0	0.4
	PrecMax	65.7	1.4	2.5	5.9	6.6	13.1	9.3	12.0	15.2	14.7	11.9	4.0	2.3
	PrecMin	33.0	0.0	0.0	0.0	0.6	1.6	2.7	3.4	5.0	5.0	0.7	0.0	0.0
	PrecStd	7.6	0.4	0.6	1.4	1.6	2.7	2.0	1.8	2.4	2.7	2.6	1.0	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.7	95.6	100.4	104.9	103.7	98.8	97.4	93.4	94.1	94.5	94.4	93.7
		MCWB	75.6	76.3	76.6	79.1	80.3	80.0	79.6	80.3	80.9	79.7	78.5	76.2
	2%	DB	90.6	93.2	97.6	102.0	99.9	95.7	94.0	91.6	92.2	92.7	92.8	91.5
		MCWB	74.6	76.0	77.5	79.0	80.5	79.9	79.8	80.1	80.6	79.3	78.0	75.0
	5%	DB	88.6	91.5	95.6	99.3	97.4	93.6	91.5	90.3	90.7	91.5	91.4	89.5
		MCWB	74.1	76.3	77.6	78.9	80.3	80.1	79.6	80.0	80.5	79.1	77.5	75.1
	10%	DB	86.5	89.7	93.5	96.9	94.9	91.6	89.7	89.1	89.3	89.9	89.7	87.3
		MCWB	73.8	75.8	77.7	79.1	80.2	80.1	79.5	79.9	80.3	79.0	77.1	74.4
	0.4%	WB	79.7	80.9	81.7	84.8	83.8	82.8	82.5	82.7	82.8	82.5	81.4	79.1
		MCDB	86.4	89.4	92.1	92.1	91.6	90.9	90.2	88.9	89.1	89.2	88.5	86.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	78.3	79.6	80.6	82.3	82.6	82.1	81.4	81.8	82.0	81.5	80.4	78.0
		MCDB	85.5	88.3	91.1	93.4	92.8	90.3	89.1	88.2	88.6	88.3	87.8	85.2
	5%	WB	77.2	78.6	79.8	81.4	81.7	81.4	80.7	81.0	81.4	80.8	79.7	77.0
		MCDB	84.3	87.0	90.2	92.6	92.2	89.6	88.4	87.7	88.0	87.6	86.8	84.6
	10%	WB	76.1	77.7	79.0	80.6	81.0	80.8	80.1	80.4	80.8	80.2	78.9	76.0
		MCDB	82.7	85.9	89.3	92.0	91.3	89.0	87.2	87.1	87.4	86.6	85.9	83.8
Mean Daily Temperature Range	5% DB	MDBR	18.3	18.9	18.2	17.8	15.0	13.2	12.0	11.6	11.4	12.2	15.6	17.9
		MCDBR	20.0	20.6	21.0	20.6	18.3	15.7	14.4	13.2	13.2	14.3	17.1	19.3
		MCWBR	6.7	7.3	6.2	5.4	4.8	4.3	4.5	4.5	4.4	4.0	4.7	6.0
	5% WB	MCDBR	15.8	18.1	18.8	18.0	16.1	13.7	12.9	12.3	12.4	13.0	15.3	17.0
		MCWBR	6.5	7.2	6.4	6.0	5.5	5.0	4.8	4.9	4.8	4.4	4.9	5.9
Clear-Sky Solar Irradiance	taub		0.498	0.596	0.682	0.621	0.505	0.447	0.438	0.445	0.485	0.557	0.482	0.487
	taud		2.036	1.817	1.659	1.833	2.190	2.371	2.396	2.363	2.236	1.986	2.174	2.087
	Ebn at Noon		250	231	216	231	255	268	271	272	261	238	253	249
	Edh at Noon		52	68	82	69	47	39	38	40	45	56	45	48
All-Sky Solar Radiation	RadAvg		1501	1646	1721	1895	1785	1664	1565	1509	1493	1517	1539	1469
	RadStd		89	69	103	83	111	102	81	76	83	91	71	53

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (21 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.20	N/A	N/A	+207	+207

Nomenclature: See separate page