

PIC HIT AGROMET, Thailand

WMO: **483860**Lat: **16.3386N**Lon: **100.3669E**Elev: **39**StdP: **100.85**Time Zone: **7.00 (E07)**Period: **08-19**WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.4	18.2	12.4	9.0	21.1	14.3	10.2	23.0	5.7	26.9	4.8	26.4	0.4	N/A	0.323

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	9.9	38.2	26.2	36.9	26.2	35.7	26.2	28.2	32.8	27.8	32.6	27.6	32.3	1.9	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.1	30.2	26.7	22.4	29.8	26.5	22.1	29.6	91.2	32.9	89.4	32.8	88.0	32.5	32.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.4	4.4	3.7	14.0	38.8	1.9	1.6	12.6	40.0	11.4	40.9	10.4	41.9	8.9	43.1
			13.1	29.9	1.9	1.3	11.8	30.8	10.7	31.6	9.6	32.4	8.3	33.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.4	25.2	27.3	29.3	31.1	30.6	29.6	28.8	28.6	28.7	28.7	27.7	25.5
	DBStd	2.45	2.42	1.68	2.13	1.99	1.87	1.33	1.31	0.96	1.08	1.24	1.72	2.36
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	1	1	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6728	472	483	598	634	638	588	583	577	562	580	532	481
	CDD18.3	3687	214	250	339	384	380	338	325	318	312	322	282	222
	CDH23.3	42052	1839	2567	4060	5232	4992	4142	3692	3542	3529	3602	2907	1948
	CDH26.7	18846	666	1124	2028	2977	2625	1896	1483	1347	1357	1410	1197	737
(14) Wind	WSAvg	1.0	0.6	0.9	1.2	1.4	1.4	1.3	1.0	1.0	0.8	0.6	0.6	0.6
(15) Precipitation	PrecAvg	1244	7	13	40	63	165	151	175	214	252	128	25	10
	PrecMax	1668	36	64	150	167	332	237	304	387	373	301	101	59
	PrecMin	838	0	0	0	15	40	68	87	126	127	19	0	0
	PrecStd	194	10	15	35	40	68	50	45	62	69	67	26	17
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.7	35.3	38.0	40.5	39.9	37.1	36.3	34.1	34.5	34.7	34.7	34.3
		MCWB	24.2	24.6	24.8	26.2	26.8	26.7	26.5	26.8	27.2	26.5	25.8	24.6
	2%	DB	32.6	34.0	36.4	38.9	37.7	35.4	34.4	33.1	33.5	33.7	33.8	33.1
		MCWB	23.6	24.5	25.3	26.1	26.9	26.6	26.6	26.7	27.0	26.3	25.5	23.9
	5%	DB	31.4	33.1	35.3	37.4	36.3	34.2	33.1	32.4	32.6	33.0	33.0	32.0
		MCWB	23.4	24.6	25.3	26.1	26.8	26.7	26.4	26.7	27.0	26.2	25.3	23.9
	10%	DB	30.3	32.1	34.2	36.0	35.0	33.1	32.1	31.7	31.8	32.2	32.0	30.7
		MCWB	23.2	24.3	25.4	26.2	26.8	26.7	26.4	26.6	26.8	26.1	25.0	23.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.5	27.2	27.6	29.3	28.8	28.2	28.0	28.2	28.2	28.1	27.4	26.2
		MCDB	30.2	31.9	33.4	33.4	33.1	32.7	32.3	31.6	31.7	31.8	31.4	30.0
	2%	WB	25.7	26.4	27.0	27.9	28.1	27.8	27.4	27.6	27.8	27.5	26.9	25.5
		MCDB	29.7	31.3	32.8	34.1	33.8	32.4	31.7	31.2	31.4	31.3	31.0	29.6
	5%	WB	25.1	25.9	26.5	27.4	27.6	27.4	27.1	27.2	27.4	27.1	26.5	25.0
		MCDB	29.1	30.6	32.3	33.7	33.4	32.0	31.3	30.9	31.1	30.9	30.5	29.2
	10%	WB	24.5	25.4	26.1	27.0	27.2	27.1	26.7	26.9	27.1	26.8	26.0	24.5
		MCDB	28.2	30.0	31.8	33.3	32.9	31.7	30.7	30.6	30.8	30.3	29.9	28.8
(35) Mean Daily Temperature Range	5% DB	MDBR	10.2	10.5	10.1	9.9	8.3	7.3	6.7	6.5	6.3	6.8	8.7	9.9
		MCDBR	11.1	11.5	11.6	11.5	10.2	8.7	8.0	7.3	7.3	8.0	9.5	10.7
		MCWBR	3.7	4.0	3.4	3.0	2.7	2.4	2.5	2.5	2.5	2.2	2.6	3.3
	5% WB	MCDBR	8.8	10.1	10.5	10.0	9.0	7.6	7.2	6.8	6.9	7.2	8.5	9.5
		MCWBR	3.6	4.0	3.6	3.3	3.0	2.8	2.6	2.7	2.7	2.5	2.7	3.3
(40) Clear-Sky Solar Irradiance	taub		0.498	0.596	0.682	0.621	0.505	0.447	0.438	0.445	0.485	0.557	0.482	0.487
	taud		2.036	1.817	1.659	1.833	2.190	2.371	2.396	2.363	2.236	1.986	2.174	2.087
	Ebn at Noon		787	728	681	727	805	844	854	856	824	751	798	784
	Edh at Noon		164	214	257	216	149	123	120	126	142	178	142	152
(44) All-Sky Solar Radiation	RadAvg		4.73	5.19	5.43	5.97	5.63	5.25	4.93	4.76	4.71	4.78	4.85	4.63
	RadStd		0.28	0.22	0.33	0.26	0.35	0.32	0.25	0.24	0.26	0.29	0.22	0.17

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)		N/A	N/A	N/A	N/A	N/A	+0.11	N/A	N/A	+115	+115

Nomenclature: See separate page