

DOI MU SOE AGROMET, Thailand

WMO: 483870

Lat: 16.7522N

Lon: 98.9356E

Elev: 868

StdP: 91.33

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.8	11.4	5.8	6.3	19.1	8.0	7.4	18.3	5.4	20.2	4.8	20.1	0.4	N/A	0.224

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.2	32.2	21.1	31.1	20.9	30.1	20.7	23.7	27.7	23.4	27.2	23.1	26.8	2.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.7	19.4	25.4	22.3	18.9	24.9	22.1	18.6	24.6	76.3	27.8	74.7	27.5	73.4	27.0	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.8	5.1	4.4	DB	7.5	34.2	2.1	0.8	6.0	34.7	4.8	35.2	3.6	35.6	2.0	36.2	(4)
			WB	6.4	24.8	1.7	1.0	5.2	25.5	4.2	26.1	3.3	26.6	2.1	27.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	22.3	18.9	20.9	23.5	25.3	25.0	23.3	22.2	22.1	22.9	22.4	21.4	19.1	(6)
(7)		DBStd	2.43	2.16	1.76	1.51	1.83	1.53	1.18	1.01	0.96	0.93	1.00	1.19	2.22	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	38	18	2	0	0	0	0	0	0	0	0	0	18	(9)
(10)		CDD10.0	4476	276	307	419	459	465	399	378	376	387	386	341	283	(10)
(11)		CDD18.3	1472	35	76	161	209	207	149	120	118	137	127	91	43	(11)
(12)		CDH23.3	7104	229	674	1397	1651	1238	416	149	142	328	389	311	181	(12)
(13)		CDH26.7	1753	13	154	501	634	363	40	2	1	14	16	9	6	(13)
(14)	Wind	WSAvg	1.6	1.1	1.0	1.3	1.6	1.8	2.2	2.8	2.6	1.7	1.1	1.0	1.1	(14)
(15)	Precipitation	PrecAvg	1362	7	8	26	51	175	199	261	251	221	135	27	7	(15)
(16)		PrecMax	1813	59	88	154	181	372	410	569	407	417	237	115	58	(16)
(17)		PrecMin	764	0	0	0	4	42	78	130	139	105	7	0	0	(17)
(18)		PrecStd	230	14	18	34	43	91	83	94	62	76	64	31	13	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.8	30.5	32.3	34.1	33.8	29.2	27.0	26.8	28.1	28.1	27.7	27.4	(19)
(20)		MCWB	18.6	18.2	19.3	21.7	22.6	22.5	22.9	22.9	23.0	22.6	21.7	20.2	(20)	
(21)		2%	DB	26.8	29.7	31.4	32.7	31.4	27.8	25.9	25.8	27.0	27.0	26.8	26.4	(21)
(22)		MCWB	18.5	18.2	19.4	21.3	22.6	22.9	22.5	22.6	22.9	22.4	21.7	20.3	(22)	
(23)		5%	DB	25.7	28.8	30.6	31.6	30.0	26.7	25.0	24.9	26.2	26.3	26.1	25.5	(23)
(24)		MCWB	18.6	18.7	19.4	21.7	22.7	22.9	22.2	22.3	22.7	22.2	21.4	20.0	(24)	
(25)		10%	DB	24.6	27.4	29.7	30.3	28.7	25.7	24.1	24.1	25.3	25.5	25.3	24.2	(25)
(26)		MCWB	18.3	18.5	19.2	21.8	22.8	22.7	21.9	22.0	22.4	22.0	21.0	19.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.6	21.8	22.7	24.1	24.2	24.0	23.2	23.3	23.7	23.6	23.1	22.1	(27)
(28)		MCDWB	25.1	27.1	28.3	30.2	28.5	26.6	26.1	25.6	26.5	26.5	26.2	25.8	(28)	
(29)		2%	WB	20.7	21.1	22.1	23.4	23.7	23.4	22.7	22.7	23.2	23.0	22.5	21.3	(29)
(30)		MCDWB	24.3	26.1	27.8	29.4	28.1	26.1	25.2	24.9	26.1	25.9	25.7	24.9	(30)	
(31)		5%	WB	19.9	20.4	21.4	23.0	23.3	23.0	22.3	22.4	22.8	22.6	22.0	20.6	(31)
(32)		MCDWB	23.4	25.4	27.0	28.8	27.7	25.8	24.4	24.4	25.6	25.4	25.2	24.1	(32)	
(33)		10%	WB	19.3	19.5	20.7	22.5	23.0	22.7	22.0	22.1	22.5	22.2	21.5	19.9	(33)
(34)		MCDWB	22.9	24.7	26.2	28.1	27.4	25.1	23.8	23.8	24.9	24.8	24.3	23.0	(34)	
(35)	Mean Daily Temperature Range	MDBR	11.0	13.4	12.8	10.2	7.3	4.8	3.8	3.7	5.0	6.2	7.7	8.8	(35)	
(36)		5% DB	MCDDBR	13.1	15.2	13.9	11.7	9.4	6.5	5.3	5.1	6.2	7.6	9.1	11.0	(36)
(37)		MCWBR	5.9	5.4	4.5	3.5	3.0	2.7	2.5	2.6	2.9	3.8	4.6	5.5	(37)	
(38)		5% WB	MCDDBR	9.3	11.7	11.4	10.0	7.7	5.6	4.8	4.6	5.7	6.6	7.8	9.3	(38)
(39)		MCWBR	4.8	5.1	4.5	3.8	3.1	2.7	2.5	2.6	2.8	3.6	4.3	5.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.396	0.467	0.566	0.525	0.433	0.393	0.386	0.389	0.410	0.463	0.404	0.396	(40)	
(41)		taud	2.275	2.095	1.839	2.020	2.350	2.495	2.516	2.492	2.409	2.205	2.334	2.301	(41)	
(42)		Ebn at Noon	887	838	767	800	865	892	899	905	890	832	874	875	(42)	
(43)		Edh at Noon	128	161	214	179	127	109	107	110	119	142	120	122	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.69	5.27	5.53	5.93	5.23	4.46	4.12	4.09	4.50	4.63	4.76	4.53	(44)	
(45)		RadStd	0.21	0.21	0.35	0.34	0.47	0.43	0.39	0.30	0.26	0.27	0.27	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.16	N/A	N/A	N/A	N/A

Nomenclature: See separate page