

SI SAKET AGROMET, Thailand

WMO: 484090

Lat: 15.085N

Lon: 104.331E

Elev: 424

StdP: 14.47

Time Zone: 7.00 (E07)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 59.5	(c) 62.0	(d) 50.9	(e) 56.2	(f) 63.9	(g) 53.3	(h) 61.3	(i) 66.3	(j) 14.3	(k) 73.9	(l) 12.5	(m) 73.6	(n) 3.2	(o) N/A	(p) 0.319

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 4	(b) 18.5	(c) 100.2	(d) 79.7	(e) 98.1	(f) 79.3	(g) 96.3	(h) 78.9	(i) 82.4	(j) 91.8	(k) 81.8	(l) 91.1	(m) 81.3	(n) 90.5	(o) 2.9	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.3	159.8	86.2	79.7	156.7	85.9	79.1	153.5	85.6	46.6	91.8	46.0	91.4	45.5	90.5	92.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 12.2	(b) 10.4	(c) 8.7	(e) 55.3	(f) 102.4	(g) 2.7	(h) 2.4	(i) 53.3	(j) 104.2	(k) 51.7	(l) 105.6	(m) 50.2	(n) 106.9	(o) 48.2	(p) 108.7		
			DB	WB	52.2	85.6	2.6	3.1	50.3	87.8	48.7	89.7	47.2	91.4	45.3	93.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.3	76.2	79.8	84.1	86.8	86.1	85.3	83.7	83.4	82.7	82.1	80.5	76.5
	DBStd	4.79	4.47	4.97	4.50	3.69	2.87	2.42	2.61	1.93	2.34	2.16	3.30	4.57
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11779	812	833	1059	1103	1119	1058	1044	1036	980	996	916	823
	CDD65	6304	347	413	594	653	654	608	579	571	530	531	466	358
	CDH74	69575	3042	4338	7032	8363	8021	7378	6558	6304	5623	5437	4412	3067
	CDH80	30524	1185	2095	3672	4540	3930	3323	2618	2344	1963	1960	1727	1167
Wind	WSAvg	2.1	2.6	2.0	1.8	1.6	1.4	2.0	2.1	1.9	1.3	1.9	3.2	3.7
Precipitation	PrecAvg	59.8	0.2	0.6	1.4	3.1	8.0	8.9	10.6	10.7	11.1	4.3	0.9	0.2
	PrecMax	71.1	1.3	2.7	4.1	8.5	14.7	16.1	19.4	15.9	17.4	9.4	3.3	2.6
	PrecMin	44.4	0.0	0.0	0.1	1.1	3.8	4.7	4.8	4.8	6.3	0.0	0.0	0.0
	PrecStd	6.8	0.4	0.7	1.1	1.8	2.6	3.0	3.6	3.1	3.1	2.6	1.0	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.1	98.0	101.7	104.1	101.1	98.4	96.7	93.6	93.2	93.4	94.2	93.8
		MCWB	75.1	77.1	77.4	80.4	80.4	80.7	79.9	81.3	81.6	80.3	79.0	76.0
	2%	DB	91.3	95.7	99.0	101.2	98.4	95.4	93.6	91.8	91.4	91.4	92.1	91.7
		MCWB	74.2	76.0	78.3	80.4	80.2	80.6	79.9	80.8	80.8	79.0	77.8	75.6
	5%	DB	89.1	93.8	96.9	98.7	96.1	93.4	91.7	90.3	90.0	89.8	90.5	89.4
		MCWB	73.6	75.7	77.9	79.8	80.2	80.4	79.9	80.4	80.4	78.5	77.1	74.9
	10%	DB	86.7	91.1	94.6	96.1	93.7	91.5	89.8	88.9	88.4	88.4	88.5	86.7
		MCWB	72.6	75.1	77.7	79.3	80.1	80.1	79.8	80.0	80.1	78.1	76.3	73.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.2	79.9	81.3	82.9	82.8	82.8	81.9	82.6	82.7	81.9	80.1	77.9
		MCDB	89.6	92.9	95.6	99.4	94.1	91.6	90.4	90.4	89.5	89.3	89.7	89.7
	2%	WB	76.7	78.7	80.0	81.5	81.8	81.9	81.3	81.8	81.8	80.9	79.2	76.7
		MCDB	87.3	91.4	94.2	97.0	93.0	90.9	89.7	89.0	88.4	88.2	88.6	88.1
	5%	WB	75.3	77.7	79.1	80.7	81.1	81.2	80.7	81.0	81.3	80.0	78.6	75.7
		MCDB	85.1	89.7	93.0	95.3	91.9	90.1	89.0	88.2	87.7	86.9	87.7	86.7
	10%	WB	73.8	76.4	78.4	80.0	80.6	80.7	80.1	80.5	80.6	79.2	77.7	74.5
		MCDB	83.9	87.7	91.7	93.3	91.1	89.5	87.9	87.5	87.0	85.6	85.7	84.8
Mean Daily Temperature Range	5% DB	MDBR	21.2	22.5	20.5	18.5	15.4	13.0	11.9	11.4	10.8	12.7	15.6	19.0
		MCDBR	22.2	23.7	22.7	21.4	18.6	15.3	14.6	13.1	13.1	14.4	17.2	20.6
		MCWBR	8.0	7.5	6.7	6.4	4.9	4.4	4.7	5.0	5.1	5.3	5.8	7.2
	5% WB	MCDBR	19.8	21.1	20.5	19.7	16.1	13.9	13.2	12.5	12.2	13.4	15.8	19.3
		MCWBR	8.0	7.5	6.8	6.4	5.3	4.9	5.2	5.2	5.2	5.4	5.9	7.4
Clear-Sky Solar Irradiance	taub		0.482	0.603	0.669	0.608	0.501	0.467	0.462	0.462	0.497	0.515	0.464	0.455
	taud		2.086	1.777	1.675	1.853	2.188	2.295	2.306	2.296	2.189	2.111	2.236	2.204
	Ebn at Noon		256	230	220	233	256	262	264	267	259	251	260	261
	Edh at Noon		50	71	80	67	47	42	42	43	47	50	43	43
All-Sky Solar Radiation	RadAvg		1626	1708	1695	1787	1776	1669	1580	1517	1473	1599	1591	1557
	RadStd		84	76	56	78	90	74	117	97	122	107	63	54

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (13 neighbors)	+0.52	N/A	N/A	N/A	N/A	+0.40	+0.36	N/A	N/A	+185	+184