

LOP BURI, Thailand

WMO: 484260

Lat: 14.8000N

Lon: 100.6284E

Elev: 37

StdP: 14.68

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	65.3	68.0	48.8	51.0	73.4	52.3	58.2	74.9	14.2	77.7	12.3	78.0	1.8	60	0.343

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	16.9	99.3	79.1	97.7	79.0	96.2	78.9	82.4	93.1	81.7	92.0	81.2	91.0	3.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.9	155.3	86.7	79.2	151.8	86.0	78.9	150.0	85.5	46.2	93.2	45.6	92.6	45.0	91.5	90.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.8	9.0	7.5	61.0	101.1	3.0	1.8	58.8	102.4	57.1	103.5	55.4	104.5	53.2	105.8		
(5)			55.1	84.5	2.8	1.6	53.0	85.7	51.3	86.6	49.7	87.5	47.7	88.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	84.3	80.6	83.9	86.4	88.2	87.1	85.9	84.7	84.4	83.8	83.7	82.7	80.3
	DBStd	3.56	3.56	2.99	3.08	2.67	2.87	2.03	1.93	1.75	1.86	2.06	2.84	3.79
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12521	948	949	1130	1146	1151	1076	1075	1067	1013	1045	982	939
	CDD65	7046	483	529	665	696	686	626	610	602	563	580	532	474
	CDH74	83370	4924	6106	8443	9336	8917	7797	7246	6974	6299	6581	5913	4834
	CDH80	38629	2094	2899	4396	5198	4652	3696	3159	2927	2487	2661	2486	1974
Wind	WSAvg	1.8	1.8	1.8	2.2	2.1	1.8	1.9	1.7	1.5	1.1	1.3	2.2	2.5
Precipitation	PrecAvg	48.8	0.2	0.5	1.4	2.7	6.6	5.6	6.5	7.2	10.2	6.4	1.5	0.5
	PrecMax	65.3	2.3	3.1	5.5	7.2	13.9	11.1	12.5	12.9	20.4	11.3	4.3	2.7
	PrecMin	34.3	0.0	0.0	0.0	0.0	0.2	2.4	2.0	2.7	3.3	2.6	0.0	0.0
	PrecStd	8.3	0.6	0.8	1.4	2.0	3.8	1.9	2.4	3.2	4.3	2.8	1.4	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.4	97.1	99.6	101.6	101.2	98.4	96.1	95.1	94.1	94.2	94.4	94.5
		MCWB	74.6	75.6	77.2	79.2	80.1	79.2	79.1	80.0	80.3	78.5	77.5	76.0
	2%	DB	92.7	95.3	97.7	99.6	98.7	95.9	94.0	93.3	92.5	92.6	93.0	92.6
		MCWB	74.5	76.0	77.8	79.5	79.9	79.5	79.3	79.7	79.9	78.5	77.1	75.4
	5%	DB	91.2	93.8	96.2	98.0	96.7	94.1	92.5	91.9	91.1	91.4	91.7	91.0
		MCWB	74.3	76.2	78.0	79.6	80.0	79.6	79.2	79.4	79.7	78.4	76.6	74.6
	10%	DB	89.6	92.2	94.6	96.2	94.6	92.4	90.9	90.5	89.7	90.0	90.2	89.1
		MCWB	73.7	76.1	78.0	79.6	79.9	79.5	78.9	79.1	79.4	78.3	76.0	73.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.6	81.3	82.1	83.5	83.0	81.9	81.5	81.8	82.4	82.0	81.4	79.8
		MCDB	89.2	91.5	93.4	95.8	94.4	91.6	90.8	90.8	90.3	89.6	90.7	89.0
	2%	WB	78.4	80.0	81.0	82.4	82.0	81.3	80.7	80.9	81.4	81.0	80.1	78.3
		MCDB	87.7	90.4	92.7	94.5	93.0	90.7	90.0	89.6	89.1	88.7	88.8	87.8
	5%	WB	77.4	79.1	80.2	81.6	81.3	80.7	80.0	80.3	80.7	80.4	79.2	77.2
		MCDB	86.2	89.1	91.6	93.2	91.8	89.9	89.0	88.7	88.4	87.9	87.3	86.4
	10%	WB	76.4	78.3	79.5	80.9	80.7	80.1	79.5	79.8	80.0	79.7	78.2	76.0
		MCDB	84.8	87.7	90.2	91.9	90.8	88.9	88.1	87.9	87.2	86.7	85.9	85.3
Mean Daily Temperature Range	5% DB	MDBR	18.3	17.8	17.3	16.9	14.9	13.8	12.9	12.9	12.3	12.8	14.8	16.9
		MCDBR	19.7	18.9	18.8	18.4	17.1	15.9	14.8	14.6	14.1	14.5	16.3	18.3
		MCWBR	6.6	5.7	5.3	5.3	4.3	4.0	4.1	4.2	4.5	4.7	5.5	6.2
	5% WB	MCDBR	16.2	16.6	17.3	17.0	15.5	14.1	13.6	13.7	12.9	12.8	14.8	16.4
		MCWBR	5.6	5.2	5.4	5.6	4.8	4.3	4.2	4.5	4.6	4.8	5.2	6.0
Clear-Sky Solar Irradiance	taub	0.527	0.615	0.666	0.602	0.510	0.460	0.450	0.452	0.487	0.564	0.506	0.499	
	taud	1.973	1.792	1.709	1.893	2.198	2.338	2.367	2.347	2.237	1.977	2.116	2.071	
	Ebn at Noon	243	228	220	235	254	264	267	270	262	238	248	247	
	Edh at Noon	56	70	78	65	47	40	39	41	45	57	48	50	
All-Sky Solar Radiation	RadAvg	1546	1676	1752	1895	1792	1700	1605	1582	1534	1542	1561	1519	
	RadStd	93	64	114	91	117	90	77	102	78	88	84	59	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	+0.40	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.52	N/A	N/A	+212	+212

Nomenclature: See separate page