

LOP BURI, Thailand

WMO: 484260

Lat: 14.8000N

Lon: 100.6284E

Elev: 11

StdP: 101.19

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	18.5	20.0	9.3	7.3	23.0	11.3	8.3	23.8	6.3	25.4	5.5	25.6	0.8	60	0.343

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	9.4	37.4	26.2	36.5	26.1	35.7	26.0	28.0	33.9	27.6	33.3	27.3	32.8	1.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.6	22.2	30.4	26.2	21.7	30.0	26.0	21.4	29.7	89.7	34.0	88.1	33.6	86.7	33.0	32.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.8	4.0	3.4	16.1	38.4	1.7	1.0	14.9	39.1	13.9	39.7	13.0	40.3	11.8	41.0		
(5)			12.8	29.2	1.6	0.9	11.7	29.8	10.7	30.3	9.9	30.9	8.7	31.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	29.1	27.0	28.8	30.2	31.2	30.6	29.9	29.3	29.1	28.8	28.7	28.2	26.8	(6)
(7)		DBStd	1.98	1.98	1.66	1.71	1.48	1.60	1.13	1.07	0.97	1.04	1.15	1.58	2.10	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6956	527	527	628	637	639	598	597	593	563	581	546	522	(10)
(11)		CDD18.3	3914	268	294	369	387	381	348	339	334	313	322	296	263	(11)
(12)		CDH23.3	46317	2736	3392	4691	5187	4954	4332	4026	3874	3499	3656	3285	2686	(12)
(13)		CDH26.7	21461	1163	1611	2442	2888	2584	2053	1755	1626	1382	1478	1381	1097	(13)
(14)	Wind	WSAvg	0.8	0.8	0.8	1.0	0.9	0.8	0.8	0.8	0.7	0.5	0.6	1.0	1.1	(14)
(15)	Precipitation	PrecAvg	1239	6	13	35	69	168	143	166	182	259	163	38	12	(15)
(16)		PrecMax	1659	59	80	139	182	353	281	317	328	517	286	109	68	(16)
(17)		PrecMin	872	0	0	0	0	6	60	51	68	83	67	1	0	(17)
(18)		PrecStd	212	16	20	36	51	96	49	62	81	110	70	35	21	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.7	36.1	37.5	38.7	38.4	36.9	35.6	35.0	34.5	34.6	34.7	34.7	(19)
(20)			MCWB	23.7	24.2	25.1	26.2	26.7	26.2	26.2	26.6	26.9	25.8	25.3	24.4	(20)
(21)		2%	DB	33.7	35.2	36.5	37.6	37.1	35.5	34.4	34.1	33.6	33.7	33.9	33.7	(21)
(22)			MCWB	23.6	24.4	25.4	26.4	26.6	26.4	26.3	26.5	26.6	25.8	25.0	24.1	(22)
(23)		5%	DB	32.9	34.3	35.7	36.7	36.0	34.5	33.6	33.3	32.9	33.0	33.2	32.8	(23)
(24)			MCWB	23.5	24.6	25.5	26.4	26.6	26.4	26.2	26.3	26.5	25.8	24.8	23.7	(24)
(25)		10%	DB	32.0	33.5	34.8	35.7	34.8	33.6	32.7	32.5	32.1	32.2	32.4	31.7	(25)
(26)			MCWB	23.2	24.5	25.5	26.5	26.6	26.4	26.1	26.2	26.3	25.7	24.5	23.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.4	27.4	27.8	28.6	28.3	27.7	27.5	27.6	28.0	27.8	27.5	26.5	(27)
(28)			MADB	31.8	33.1	34.1	35.5	34.7	33.1	32.7	32.7	32.4	32.0	32.6	31.7	(28)
(29)		2%	WB	25.8	26.7	27.2	28.0	27.8	27.4	27.0	27.2	27.4	27.2	26.7	25.7	(29)
(30)			MADB	31.0	32.4	33.7	34.7	33.9	32.6	32.2	32.0	31.7	31.5	31.6	31.0	(30)
(31)		5%	WB	25.2	26.2	26.8	27.6	27.4	27.1	26.7	26.8	27.0	26.9	26.2	25.1	(31)
(32)			MADB	30.1	31.7	33.1	34.0	33.2	32.2	31.6	31.5	31.3	31.1	30.7	30.2	(32)
(33)		10%	WB	24.6	25.7	26.4	27.2	27.0	26.7	26.4	26.5	26.7	26.5	25.6	24.4	(33)
(34)			MADB	29.4	31.0	32.4	33.3	32.7	31.6	31.2	31.0	30.7	30.4	29.9	29.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.2	9.9	9.6	9.4	8.3	7.7	7.2	7.2	6.9	7.1	8.2	9.4	(35)
(36)			MCDBR	11.0	10.5	10.4	10.2	9.5	8.8	8.2	8.1	7.8	8.0	9.1	10.1	(36)
(37)			MCWBR	3.7	3.2	3.0	2.9	2.4	2.2	2.3	2.3	2.5	2.6	3.1	3.4	(37)
(38)		5% WB	MCDBR	9.0	9.2	9.6	9.5	8.6	7.9	7.6	7.6	7.2	7.1	8.2	9.1	(38)
(39)			MCWBR	3.1	2.9	3.0	3.1	2.7	2.4	2.3	2.5	2.6	2.6	2.9	3.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.527	0.615	0.666	0.602	0.510	0.460	0.450	0.452	0.487	0.564	0.506	0.499	(40)	
(41)		taud	1.973	1.792	1.709	1.893	2.198	2.338	2.367	2.347	2.237	1.977	2.116	2.071	(41)	
(42)		Ebn at Noon	766	718	695	741	800	832	843	850	825	749	782	779	(42)	
(43)		Edh at Noon	177	221	245	204	148	127	124	128	142	181	152	157	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.88	5.28	5.52	5.97	5.65	5.36	5.06	4.99	4.84	4.86	4.92	4.79	(44)	
(45)		RadStd	0.29	0.20	0.36	0.29	0.37	0.28	0.24	0.32	0.25	0.28	0.26	0.18	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (29 neighbors)		N/A	N/A	N/A	N/A	+0.22	N/A	N/A	N/A	N/A
		N/A	N/A	N/A	N/A	+0.29	N/A	N/A	+118	+118

Nomenclature: See separate page