

PRACHIN BURI, Thailand

WMO: 484300

Lat: 14.0511N

Lon: 101.3692E

Elev: 20

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	66.5	68.9	51.6	56.7	73.9	54.5	63.2	75.5	17.7	76.9	14.4	78.2	2.5	90	0.351

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	17.5	99.7	80.9	98.0	80.5	96.4	80.1	83.6	93.7	82.8	92.6	82.3	91.9	3.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.3	162.9	88.2	80.5	158.7	87.9	79.9	155.4	87.2	47.7	94.2	46.9	92.8	46.2	92.1	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.0	9.7	7.6	62.1	102.3	3.4	1.6	59.7	103.5	57.7	104.5	55.8	105.4	53.4	106.6
			55.8	84.7	3.2	0.9	53.5	85.4	51.6	85.9	49.7	86.4	47.4	87.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	84.5	81.2	84.2	86.8	88.2	87.0	85.6	84.5	84.3	84.0	84.3	83.2	81.0
	DBStd	3.43	3.37	3.12	2.82	2.85	2.92	2.29	2.23	1.99	1.96	1.99	2.72	3.73
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12602	967	959	1141	1145	1149	1069	1068	1062	1020	1064	996	962
	CDD65	7127	502	539	676	695	684	619	603	597	570	599	546	497
	CDH74	84260	5322	6316	8563	9098	8670	7572	7034	6825	6431	6922	6227	5280
	CDH80	38670	2348	3059	4496	4990	4404	3473	2910	2727	2514	2828	2662	2259
Wind	WSAvg	1.8	2.2	1.7	1.5	1.4	1.3	1.2	1.1	1.1	1.2	2.0	3.1	3.3
Precipitation	PrecAvg	81.2	0.2	1.0	2.6	5.6	8.5	11.5	12.6	15.5	14.1	7.5	1.7	0.4
	PrecMax	104.4	1.5	3.1	4.3	13.5	23.3	15.9	21.7	25.3	18.4	13.0	4.6	3.4
	PrecMin	62.2	0.0	0.0	0.0	2.8	2.8	3.0	5.7	9.6	8.5	2.4	0.0	0.0
	PrecStd	11.9	0.5	1.2	1.4	2.8	5.1	3.7	4.6	5.1	3.1	3.4	1.4	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.1	97.8	100.7	102.1	101.4	97.6	95.4	94.3	94.2	94.7	94.9	95.0
		MCWB	76.4	78.2	79.9	81.6	82.3	81.1	81.6	81.3	81.1	79.8	78.6	77.4
	2%	DB	93.4	96.1	98.7	100.2	98.5	95.1	93.5	92.7	92.5	92.9	93.4	93.3
		MCWB	76.3	77.9	79.5	81.3	81.9	81.6	81.2	80.9	80.8	79.3	77.9	76.6
	5%	DB	92.0	94.5	97.1	98.3	96.3	93.6	92.1	91.4	91.1	91.7	92.1	91.6
		MCWB	75.5	77.4	79.3	81.1	81.6	81.3	80.8	80.6	80.5	79.1	77.4	75.6
	10%	DB	90.3	92.9	95.3	96.4	94.2	91.9	90.4	90.0	89.6	90.3	90.6	89.8
		MCWB	74.6	76.9	79.2	80.8	81.4	81.0	80.4	80.3	80.1	78.8	76.9	74.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	81.6	82.8	84.4	85.3	83.7	83.6	82.8	82.7	82.4	81.8	80.5
		MCDB	90.8	92.9	95.6	96.8	94.7	92.5	92.0	90.7	90.9	91.1	90.8	90.8
	2%	WB	79.2	80.1	81.7	83.2	83.7	82.8	82.4	81.9	81.8	81.4	80.7	78.9
		MCDB	88.9	91.5	94.3	95.5	93.4	91.6	90.4	89.7	89.7	89.7	89.6	89.4
	5%	WB	78.1	79.3	80.9	82.4	82.8	82.2	81.6	81.3	81.0	80.7	79.7	77.8
		MCDB	87.3	90.3	93.0	94.5	92.3	90.7	89.4	89.0	88.8	88.8	88.1	87.7
	10%	WB	77.1	78.7	80.1	81.6	81.9	81.5	80.9	80.7	80.6	80.0	78.7	76.6
		MCDB	85.7	89.1	91.5	93.1	91.2	89.6	88.4	88.3	88.1	87.4	86.6	86.1
Mean Daily Temperature Range	5% DB	MDBR	18.6	18.4	18.1	17.5	14.7	13.0	11.9	11.8	11.9	12.5	14.3	16.9
		MCDBR	19.7	19.5	20.2	19.3	17.2	15.1	14.1	13.5	13.7	14.2	15.9	18.2
		MCWBR	6.6	5.6	5.4	5.3	4.8	4.8	4.7	4.6	4.9	5.0	5.4	6.1
	5% WB	MCDBR	17.0	17.9	18.6	18.4	15.8	13.9	13.1	12.7	12.8	13.1	14.5	16.4
		MCWBR	6.1	5.4	5.5	5.8	5.5	5.2	5.2	4.9	5.0	4.9	5.3	6.1
Clear-Sky Solar Irradiance	taub	0.530	0.620	0.651	0.593	0.511	0.482	0.474	0.475	0.497	0.553	0.493	0.482	
	taud	1.973	1.783	1.749	1.923	2.196	2.276	2.301	2.285	2.211	2.019	2.165	2.141	
	Ebn at Noon	243	227	225	237	253	258	261	264	259	241	253	254	
	Edh at Noon	56	71	75	63	47	43	42	43	47	55	46	47	
All-Sky Solar Radiation	RadAvg	1562	1647	1690	1786	1655	1582	1503	1492	1453	1481	1536	1534	
	RadStd	102	75	99	95	100	77	77	88	75	93	95	66	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.63	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+221	+221
Regional (34 neighbors)	N/A	N/A	N/A	N/A	+0.41	+0.45	N/A	N/A	N/A	N/A

Nomenclature: See separate page